

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
PETRO DIAMOND TERMINAL COMPANY
(PETRO-DIAMOND TANK NO. 10)**

**NPDES NO. CAG914001
CI-8737**

FACILITY ADDRESS

1920 Lugger Way
Long Beach, California

FACILITY MAILING ADDRESS

P.O. Box 19617
Long Beach, CA 90813

PROJECT DESCRIPTION:

Petro Diamond Terminal Company (Discharger) is constructing an above-ground storage tank (Tank No. 10) located at 1920 Lugger Way, Long Beach (See Figure 1 for site location). The Discharger will use potable water for the hydrostatic testing. The Discharger proposes to discharge hydrostatic test water from the tank under the general NPDES permit.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 2,1 million gallons of hydrostatic test water will be discharged to a nearby storm drain (Latitude: 33° 46' 32", Longitude: 118° 13' 54"). The discharge flows to Long Beach Harbor, a water of the United States. The Discharger will lay a hose down to the storm drain and control the flow rate so that no back flow or overflow will occur. The drain box and the area around it will be cleaned of foreign materials and debris prior to the discharge.

FREQUENCY OF DISCHARGE:

The groundwater will be discharged over approximately 10-day period with a maximum flow of 0.5 million gallons per day.

REUSE OF WATER:

Reuse of water at the facility for irrigation and dust control were evaluated. Due to intermittent flow and the inability to reuse the testing water economically, the wastewater will be discharged to the storm drain.

* Hydrostatic test will be conducted on the tank upon completion to verify that it does not leak.