

**STATE OF CALIFORNIA  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
LOS ANGELES REGION  
320 West 4<sup>th</sup> Street, Suite 200, Los Angeles, California 90013**

**FACT SHEET  
WASTE DISCHARGE REQUIREMENTS  
FOR  
CALLEGUAS MUNICIPAL WATER DISTRICT  
(OXNARD PLAIN BRINE LINE, PHASE 1B PROJECT)**

**NPDES NO. CAG674001  
CI-8979**

**FACILITY ADDRESS**

Along Hueneme Road, between Rice Avenue  
and Las Posas Road  
Oxnard, CA

**FACILITY MAILING ADDRESS**

2100 Olsen Road  
Thousand Oaks, CA 91360

**PROJECT DESCRIPTION:**

Calleguas Municipal Water District (Calleguas MWD) proposes to discharge hydrostatic test water from the newly constructed pipeline located along Hueneme Road, between Rice Avenue and Las Posas Road, Oxnard. Hydrostatic testing is required at the facility to test the pipelines for leaks and structural integrity. The total length of the 54-inch pipeline is approximately 9,050 feet. The wastewater from the pipeline will be discharged into Revolon Slough. Potable water from City of Oxnard will be used for the hydrostatic testing.

**VOLUME AND DESCRIPTION OF DISCHARGE:**

Approximately 288,000 gallons per day of hydrostatic test water will be discharged from the project site. The discharge will be released into local storm drains located along Hueneme Road, between Rice Avenue and Las Posas Road, thence into Revolon Slough, thence into the Calleguas Creek (below Potrero Road), waters of the United States. The site location is shown in Figure 1. The discharge outfalls locations are listed below:

<b>Outfall No.</b>	<b>Latitude</b>	<b>Longitude</b>
01	34° 09' 04"	119° 05' 18"
02	34° 08' 49"	119° 07' 06"
03	34° 08' 49"	119° 07' 53"

November 15, 2005

## APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided, the analytical data did not show reasonable potential for toxics to exist in hydrostatic test above the *Screening Levels for Potential Pollutants of Concern in Potable Water Used for Hydrostatic Testing in Attachment A*. In addition, the source of hydrostatic test water is from a potable water supply system that complies with the Department of Health Services Maximum Contaminant Levels for drinking water. The discharge flows into the Revolon Slough. The effluent limitations in Attachment B are not applicable to your discharge.

This Table lists the specific constituents and effluent limitations applicable to the discharge.

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD <sub>5</sub> 20°C	mg/L	30	20
Oil and Grease	mg/L	15	10
Settable Solids	ml/L	0.3	0.1
Residual Chlorine	mg/L	0.1	

## FREQUENCY OF DISCHARGE:

The discharge will be intermittent. Calleguas MWD anticipates conducting the hydrostatic testing during January 2006.

## REUSE OF WATER:

Reuse of water at the facility for irrigation and dust control was evaluated, but found to be infeasible at the site. Therefore, the hydrostatic test water will be discharged into Revolon Slough.