



California Regional Water Quality Control Board

Los Angeles Region



Recipient of the 2001 *Environmental Leadership Award* from Keep California Beautiful

Linda S. Adams
Agency Secretary

320 W. 4th Street, Suite 200, Los Angeles, California 90013
Phone (213) 576-6600 FAX (213) 576-6640 - Internet Address: <http://www.waterboards.ca.gov/losangeles>

Arnold Schwarzenegger
Governor

April 10, 2008

CERTIFIED MAIL No. 7002 0860 0004 5295 7328
RETURN RECEIPT REQUESTED

Mr. Michael Farnsworth, Terminal Manager
BP West Coast Products LLC
ARCO Vinvale Terminal
8601 S. Garfield Avenue
South Gate, CA 90280

COVERAGE UNDER GENERAL NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM AND WASTE DISCHARGE REQUIREMENTS—BP WEST COAST PRODUCTS COMPANY, LLC, ARCO VINVALE TERMINAL, 8601 S. GARFIELD AVENUE, SOUTH GATE, CALIFORNIA (NPDES NO. CAG674001, CI-9388)

Dear Mr. Farnsworth:

We have completed our review of your application for a permit to discharge hydrostatic test water under the National Pollutant Discharge Elimination System (NPDES).


Based on the attached Fact Sheet and other information provided, we have determined that the wastewater discharge meets the conditions to be regulated under Order No. R4-2004-0109, *General National Pollutant Discharge Elimination System and Waste Discharge Requirements for Discharges of Low Threat Hydrostatic Test Water to Surface Waters in Coastal Watersheds of Los Angeles and Ventura Counties*, adopted by this Board on July 1, 2004.

Enclosed are your Waste Discharge Requirements, which also serve as your NPDES permit, consisting of Order No. R4-2003-0109 and Monitoring and Reporting Program No. CI-9388. The discharge limitations in Part E.1 of Order No. R4-2004-0109 are applicable to your discharge. Discharge from the facility drains to the Los Angeles River between Figueroa St. and Willow Street. Therefore, the discharge limitations in Attachment B.7.d are applicable to your discharge.

The Monitoring and Reporting Program requires you to implement the monitoring program on the effective date of coverage under this permit. All monitoring reports should be sent to the Regional Board, ATTN: Information Technology Unit. When submitting monitoring or technical reports to the Regional Board per these requirements, please include a reference to "Compliance File No. CI-9388 and NPDES No. CAG674001", which will assure that the reports are directed to the appropriate file and staff. Also, please do not combine other reports with your monitoring reports. Submit each type of report as a separate document.

To avoid future annual fees, please submit written request for termination of your enrollment under the general permit in a separate letter, when the project has been completed and the permit is no longer needed. Be aware that the annual fee covers the fiscal year billing period beginning

California Environmental Protection Agency



Our mission is to preserve and enhance the quality of California's water resources for the benefit of present and future generations.

Mr. Michael Farnsworth
BP West Coast Products LLC

- 2 -


April 10, 2008

July 1 and ending June 30, the following year. You will pay full annual fee if your request for termination is made after the beginning of new fiscal year beginning July 1.

We are sending a copy of Order No. R4-2003-0111 only to the applicant. For those on the mailing list, please refer to the Board Order previously sent to you. A copy of the Order will be furnished to anyone who requests it, or it can be obtained at our web site address: http://www.waterboards.ca.gov/losangeles/html/permits/general_permits.html.

If you have any questions, please contact Gensen Kai at (213) 576-6651.

Sincerely,



Tracy J. Egoscue
Executive Officer

Enclosures:

Order No. R4-2004-0109
Fact Sheet
Monitoring and Reporting Program for No. CI-9388

cc: Environmental Protection Agency, Region 9, Permit Section (WTR-5)
U.S. Army Corps of Engineers
U.S. Fish and Wildlife Services, Division of Ecological Services
NOAA, National Marine Fisheries Service
Philip Isorena, SWRCB, NPDES Unit
California Department of Fish and Game, Marine Resources, Region 5
California Department of Health Services, Environmental Branch
Los Angeles County, Department of Public Works, Waste Management Division
Los Angeles County, Department of Health Services
City Manager, City of South Gate
Jae Kim, Tetrattech

California Environmental Protection Agency



Our mission is to preserve and enhance the quality of California's water resources for the benefit of present and future generations.

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
BP WEST COAST PRODUCTS COMPANY, LLC
(ARCO VINVALE TERMINAL)**

**NPDES NO. CAG674001
CI-9388**

FACILITY ADDRESS

8601 S. Garfield Avenue
South Gate, California

FACILITY MAILING ADDRESS

8601 S. Garfield Avenue
South Gate, CA 90280

PROJECT DESCRIPTION:

BP West Coast Products Company, LLC (BP West) proposes to discharge hydrostatic test water from above-ground fuel storage tanks located at the above-referenced address (See Figure 1 for site location). The hydrostatic testing will be conducted after the tank upgrade. BP West will use potable water supplied by the City of South Gate during the hydrostatic testing. BP West has submitted a Notice of Intent to apply for enrollment under the general NPDES permit.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 0.96 million gallons per day (8 hours per day) of wastewater will be discharged from the facility to Outfall No. Gate Valve 1 (Latitude: 33° 57' 00", Longitude: 118° 10' 00") which flows into the Los Angeles River, a water of the United States. Hydrostatic test discharge at the facility is a short-time discharge that lasts for approximately 6 days.

APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided in the NPDES Application Supplemental Requirements, the following constituents listed in the Table below have been determined to show reasonable potential to exist in the discharge. The discharge flows into the Los Angeles River, which is designated as MUN (Potential) beneficial use. Therefore, the discharge limitations under "Other Waters" column apply to the discharge.

This Table lists the specific constituents and effluent limitations applicable to the discharge.

| Constituents | Units | Discharge Limitations | |
|---|-------|-----------------------|-----------------|
| | | Daily Maximum | Monthly Average |
| Total Suspended Solids | mg/L | 150 | 50 |
| Turbidity | NTU | 150 | 50 |
| BOD ₅ 20°C | mg/L | 30 | 20 |
| Oil and Grease | mg/L | 15 | 10 |
| Settleable Solids | ml/L | 0.3 | 0.1 |
| Sulfides | mg/L | 1.0 | N/A |
| Phenols | mg/L | 1.0 | N/A |
| Residual Chlorine | mg/L | 0.1 | N/A |
| Methylene Blue Active Substances (MBAS) | mg/L | 0.5 | N/A |
| TDS | mg/L | 1500 | |
| Sulfate | mg/L | 350 | |
| Chloride | mg/L | 190 | |
| Nitrogen* | mg/L | 8 | |

* Nitrate-nitrogen plus nitrite-nitrogen (NO₃-N + NO₂-N)

FREQUENCY OF DISCHARGE:

Discharge at the facility is intermittent.

REUSE OF WATER:

There are no feasible reuse options because of the large volume of water that will be discharged over a short period of time. Offsite disposal of the discharge is not feasible due to high cost of disposal. The property and the immediate vicinity have no landscaped areas that require irrigation using the discharge. Therefore, the wastewater will be discharged to the Los Angeles River, in accordance with the attached Order.




Figure 1. Site Location

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION

**MONITORING AND REPORTING PROGRAM NO. CI-9388
FOR
BP WEST COAST PRODUCTS COMPANY, LLC
(ARCO VINVALE TERMINAL)
(NPDES NO. CAG674001, SERIES NO. 032))**

I. REPORTING REQUIREMENTS

- A. The discharger shall implement this monitoring program on the effective date of this permit. The discharger shall submit monitoring reports to the Regional Board by the dates in the following schedule:

| <u>Reporting Period</u> | <u>Report Due</u> |
|-------------------------|-------------------|
| January - March | May 15 |
| April - June | August 15 |
| July - September | November 15 |
| October - December | February 15 |

- B. The first monitoring report under this Program is due by August 15, 2008. If there is no discharge during any reporting period, the report shall so state.
- C. All monitoring reports shall include the discharge limitations in the Order, tabulated analytical data, the chain of custody form, and the laboratory report (including but not limited to date and time of sampling, date of analyses, method of analysis and detection limits).
- D. Each monitoring report shall contain a separate section titled "Summary of Non-compliance" which discusses the compliance record and corrective action taken or planned that may be needed to bring the discharge into full compliance with waste discharge requirements. This section shall clearly list all non-compliance with waste discharge requirements, as well as all excursions of effluent limitations.
- E. Before commencing a new discharge, a representative sample of the effluent shall be collected for all the constituents listed in the Fact Sheet and the test results must meet all applicable limitations of Order No. R4-2004-0109.

II. SAMPLE COLLECTION REQUIREMENTS (AS APPROPRIATE)

- A. Daily samples shall be collected each day.
- B. Weekly samples shall be collected on a representative day of each week.
- C. Monthly samples shall be collected on a representative day of each month.
- D. Quarterly samples shall be collected in February, May, August, and November.
- E. Semi-annual samples shall be collected in May and November.
- F. Annual samples shall be collected in November.

III. EFFLUENT MONITORING REQUIREMENTS

- A. Sampling station(s) shall be established at the discharge point and shall be located where representative samples of the effluent can be obtained. Provisions shall be made to enable visual inspections before discharge. In the event of presence of oil sheen, debris, and/or other objectionable materials or odors, discharge shall not commence until compliance with the requirements is demonstrated. All visual observations shall be included in the monitoring report.
- B. If monitoring result indicates an exceedance of a limit contained in Order R4-2004-0109, the discharge shall be terminated and shall only be resumed after remedial measures have been implemented and full compliance with the requirements has been ascertained.
- C. In addition, as applicable, following an effluent limit exceedance, the discharger shall implement the following accelerated monitoring program:
 - 1. Monthly monitoring shall be increased to weekly monitoring,
 - 2. Quarterly monitoring shall be increased to monthly monitoring,
 - 3. Semi-annually monitoring shall be increased to quarterly, and
 - 4. Annual monitoring shall be increased to semi-annually.

If three consecutive accelerated monitoring events demonstrate full compliance with effluent limits, the discharger may return to the regular monitoring frequency, with the approval of the Executive Officer of the Regional Board.

D. The following shall constitute the discharge monitoring program:

| Constituent | Unit | Sample Type | Minimum Frequency of Analysis |
|---|------------|-------------|-------------------------------|
| Flow | gal/day | totalizer | Continuously* |
| pH | pH units | grab | once per discharge event |
| Temperature | °F | grab | once per discharge event |
| Total Suspended Solids | mg/L | grab | once per discharge event |
| Turbidity | NTU | grab | once per discharge event |
| BOD ₅ 20°C | mg/L | grab | once per discharge event |
| Oil and Grease | mg/L | grab | once per discharge event |
| Settleable Solids | ml/L | grab | once per discharge event |
| Sulfides | mg/L | grab | once per discharge event |
| Phenols | mg/L | grab | once per discharge event |
| Residual Chlorine | mg/L | grab | once per discharge event |
| Methylene Blue Active Substances (MBAS) | mg/L | grab | once per discharge event |
| Total petroleum hydrocarbons | µg/L | grab | once per discharge event |
| TDS | mg/L | grab | once per discharge event |
| Sulfate | mg/L | grab | once per discharge event |
| Chloride | mg/L | grab | once per discharge event |
| Nitrogen* | mg/L | grab | once per discharge event |
| Acute Toxicity | % survival | grab | annually |

* Record the monthly total flow and report the calculated daily average flow and monthly flow in the quarterly and annual reports, as appropriate.

IV. EFFLUENT TOXICITY TESTING

- A. The discharger shall conduct acute toxicity testing tests on 100% effluent grab samples by methods specified in 40 CFR Part 136 which cites USEPA's *Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms*, October 2002, (EPA/821-R-02-012) or a more recent edition. Submission of bioassay results should include the information noted on pages 109-113 of the EPA/821-R-02-012 document.
- B. The fathead minnow, *Pimephales promelas*, shall be used as the test species for fresh water discharges and the topsmelt, *Atherinops affinis*, shall be used as the test species for brackish discharges. The method for topsmelt is found in USEPA's *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, Third Edition, October 2002, (EPA/821-R-02-014).

- C. If the results of the toxicity test yield a survival of less than 90%, then the frequency of analyses shall increase to monthly until at least three test results have been obtained and full compliance with effluent limitations has been demonstrated, after which the frequency of analyses shall revert to annually. Results of toxicity tests shall be included in the first monitoring report following sampling.

V. GENERAL PROVISIONS FOR REPORTING

- A. The discharger shall inform this Regional Board 24 hours before the start of the discharge.
- B. All chemical, bacteriological, and toxicity analyses shall be conducted at a laboratory certified for such analyses by the California Department of Health Services Environmental Laboratory Accreditation Program (ELAP) or approved by the Executive Officer. A copy of the laboratory certification shall be provided with the first monitoring report and each time a new and/or renewal is obtained from ELAP.
- C. Samples must be analyzed within allowable holding time limits as specified in 40 CFR Part 136.3. Proper chain of custody procedures must be followed and a copy shall be submitted with the report.
- D. As required in part H.5. of Order No. R4-2004-0109, the monitoring report shall specify the USEPA analytical method used, the Method Detection Limit and the Minimum Level for each pollutant.

VI. COMPLIANCE DETERMINATION (AS APPLICABLE)

- A. Compliance with single constituent effluent limitation – If the concentration of the pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reported Minimum Level (see Monitoring and Reporting Requirements Section H.5. of Order R4-2004-0109), then the Discharger is out of compliance.
- B. Compliance with monthly average limitations - In determining compliance with monthly average limitations, the following provisions shall apply to all constituents:
 - a. If the analytical result of a single sample, monitored monthly, quarterly, semiannually, or annually, does not exceed the monthly average limit for that constituent, the Discharger has demonstrated compliance with the monthly average limit for that month.
 - b. If the analytical result of a single sample, monitored monthly, quarterly, semiannually, or annually, exceeds the monthly average limit for any constituent, the Discharger shall collect four additional samples at approximately equal intervals during the month. All five analytical results shall be reported in the monitoring report for that

month, or 45 days after results for the additional samples were received, whichever is later.

When all sample results are greater than or equal to the reported Minimum Level (see Monitoring and Reporting Requirements Section H.5. of Order R4-2004-0109), the numerical average of the analytical results of these five samples will be used for compliance determination.

When one or more sample results are reported as "Not-Detected (ND)" or "Detected, but Not Quantified (DNQ)" (see Monitoring and Reporting Requirements Section H.5. of Order R4-2004-0109), the median value of these four samples shall be used for compliance determination. If one or both of the middle values is ND or DNQ, the median shall be the lower of the two middle values.

- c. In the event of noncompliance with a monthly average effluent limitation, the sampling frequency for that constituent shall be increased to weekly and shall continue at this level until compliance with the monthly average effluent limitation has been demonstrated.
 - d. If only one sample was obtained for the month or more than a monthly period and the result exceeded the monthly average, then the Discharger is in violation of the monthly average limit.
- C. Compliance with effluent limitations expressed as a sum of several constituents – If the sum of the individual pollutant concentrations is greater than the effluent limitation, then the Discharger is out of compliance. In calculating the sum of the concentrations of a group of pollutants, consider constituents reported as ND or DNQ to have concentrations equal to zero, provided that the applicable ML is used.
- D. Compliance with effluent limitations expressed as a median – in determining compliance with a median limitation, the analytical results in a set of data will be arranged in order of magnitude (either increasing or decreasing order); and
- a. If the number of measurements (n) is odd, then the median will be calculated as $= X_{(n+1)/2}$, or
 - b. If the number of measurements (n) is even, then the median will be calculated as $= [X_{n/2} + X_{(n/2)+1}]$, i.e. the midpoint between the $n/2$ and $n/2+1$ data points.
- E. In calculating mass emission rates from the monthly average concentrations, use one half of the method detection limit for "Not Detected" (ND) and the estimated concentration for "Detected, but Not Quantified" (DNQ) for the calculation of the monthly average concentration. To be consistent with section VI.C., if all pollutants belonging to the same

group are reported as ND or DNQ, the sum of the individual pollutant concentrations should be considered as zero for the calculation of the monthly average concentration.

VII. NOTIFICATION

A. The discharger shall notify the Executive Officer in writing prior to discharge of any chemical which may be toxic to aquatic life. Such notification shall include:

1. Name and general composition of the chemical,
2. Frequency of use,
3. Quantities to be used,
4. Proposed discharge concentrations and,
5. EPA registration number, if applicable.


No discharge of such chemical shall be made prior to obtaining the Executive Officer's approval.

B. The discharger shall notify the Regional Board via telephone and/or fax within 24 hours of noticing an exceedance above the effluent limits in Order No. R4-2004-0109. The discharger shall provide to the Regional Board within 14 days of observing the exceedance a detailed statement of the actions undertaken or proposed that will bring the discharge into full compliance with the requirements and submit a timetable for correction.

VIII. MONITORING FREQUENCIES

Monitoring frequencies may be adjusted by the Executive Officer to a less frequent basis if the discharger makes a request and the request is justified by statistical trends of monitoring data submitted. However, monitoring frequency may also increase based on site-specific conditions.

Ordered by:



Tracy J. Egoscue
Executive Officer

Date:

April 10, 2008



**RB4 Data Entry Form
Regulatory Measures – General NPDES Permits**

The IT Unit will use this form and the permit document to update CIWQS. Please complete this form and send it via e-mail or hard copy to Alex Carlos. Thank you

| | | |
|---|-----------------------------|-----------------------|
| Temporary WDID (see application): 4855 | Staff: Gensen Kai | CI No: 9388 |
| Regulatory Measure ID (see application): 341676 | | |

| General Information | |
|----------------------------|-------------------------|
| Discharger Name | BP West Coast Products |
| Facility Name | BP West Coast Products |
| Facility Address | 8601 S. Garfield Avenue |
| Facility City | South Gate |

| Additional Information | | |
|-------------------------------|-----------------------------|-------------------------|
| Effective Date | | |
| Order No.:CAG674001 | Series No.: 032 | |
| Waste Type:I_Miscel | SIC Code (4 digits)* 1542 | |
| Annual Fee | \$1,000 / \$2,900 / \$4,800 | |
| Mailing Contact | Ruthanne Walker | |
| Mailing Contact Phone: | 562-806-4105 | |
| Mailing Contact Email | | |
| Watershed | Ballona Creek | Malibu Creek |
| | Calleguas Creek | San Gabriel River |
| | Channel Islands | Santa Ana River |
| | Dominquez Channel | Santa Clara River |
| | LA Harbor/LB Harbor | Santa Monica Bay WMA |
| | Los Angeles River | Ventura River |
| | Los Cerritos Channel | Ventura Coastal Streams |

* For SIC Codes, see <http://www.osha.gov/pls/imis/sicsearch.html>