State of California Regional Water Quality Control Board San Diego Region

EXECUTIVE OFFICER SUMMARY REPORT September 8, 2010

ITEM:	11
SUBJECT:	Waste Discharge Requirements: An Order rescinding Cease and Desist Order No. 99-03, Ramona Municipal Water District, San Vicente Treatment Plant (Tentative Order No. R9-2010-0095) <i>(Cathryn Henning)</i>
PURPOSE:	To adopt tentative Order No. R9-2010-0095 rescinding Cease and Desist Order No. 99-03.
PUBLIC NOTICE:	All interested parties were notified of the action to rescind Cease and Desist Order No. 99-03 on July 15, 2010 with mailings of the tentative Order. In addition, the tentative Order was published on the San Diego Water Board's website. These public notification actions satisfy the requirements of California Water Code section 13167.5.
DISCUSSION:	Tentative Order No. R9-2010-0095 (Supporting Document No. 1) rescinds Cease and Desist Order No. 99-03 (Supporting Document No. 2), <i>Ramona Municipal Water</i> <i>District, San Vicente Treatment Plant, Ramona, San Diego</i> <i>County.</i> The purpose of this action is to document that the Ramona Municipal Water District has complied with the directives of the Cease and Desist Order.
	The Cease and Desist Order was issued in March 1999 to adopt a time schedule to control inflow and infiltration to the San Vicente Wastewater Treatment Plant collection system. The excessive inflow and infiltration caused the flow rate at the plant to exceed its design capacity during rain events. The time schedule also established a date by which the Ramona Municipal Water District would complete upgrades of the plant to increase its flow volume capacity.
	The District completed the measures for its collection system in August 1999 and the upgrades to its wastewater treatment facility in November 1999. The San Diego Water Board subsequently adopted Order No. R9-2009-0005, <i>Master</i> <i>Reclamation Permit, Ramona Municipal Water District, San</i>

Vicente Wastewater Treatment Plant, San Diego County in March 2009 that increased the limit on the flow volume to 0.8 million gallons per day.

The rescission of Cease and Desist Order No. 99-03 is a follow-up to the adoption of Order No. R9-2009-0005, which occurred in March 2009.

KEY ISSUES and LEGAL CONCERNS:	None
SUPPORTING DOCUMENTS:	1. Tentative Order No. R9-2010-0095
DOCOMENTS.	2. Cease and Desist Order No. 99-03
SIGNIFICANT CHANGES and COMPLIANCE RECORD:	None
RECOMMENDATION:	Adoption of tentative Order No. R9-2010-0095.