

**Response to Comments Regarding Tentative Order No. R9-2011-0019, NPDES No. CA0107395
Waste Discharge Requirements for the Encina Wastewater Authority, Encina Water Pollution Control Facility and
Satellite Wastewater Treatment Plant, Discharge to the Pacific Ocean via the Encina Ocean Outfall**

The Comments and Concerns listed below are paraphrased from the original comment documents to capture the substantive issues raised. Complete copies of all written comments are available on the San Diego Water Board's website at <http://www.waterboards.ca.gov/sandiego/>

Comment No.	Comments and/or Concerns	San Diego Water Board Response
March 3, 2011 letter from Encina Wastewater Authority		
1	<p>Receiving Water REC-1 Compliance Encina Wastewater Authority (EWA) has compiled the receiving water data collected from 2006 to 2010, within the State of California territorial marine waters, showing compliance with the REC-1 bacterial objectives during this time period. EWA will also ensure compliance with the REC-1 bacterial objectives by collecting samples early in the month, expediting testing, and conducting repeat sampling if a sample exceeds the 30-day geometric mean.</p>	<p>Modifications to the Tentative Order to accommodate the EWA's request have been incorporated into the errata sheet (See Errata Nos. 2, 4, and 5)</p>

Comment No.	Comments and/or Concerns	San Diego Water Board Response
2	<p>Initial Dilution Attachment H of the Tentative Order states that Visual Plumes and UM3 model package was used to simulate initial dilution under two Scenarios. However, only the results of one Scenario was presented in the attachment. EWA would like both results of both Scenarios presented and an explanation of why Scenario 2 modeling were used to determine the minimum initial dilution factor for this permit renewal</p>	<p>Modifications to the Tentative Order have been incorporated into the errata sheet to explain why alternative calculations were not presented or considered for this permit reissuance. (See Errata No. 3)</p>
3	<p>Collection System EWA would like the language modified to clarify who owns and operates the sewage collection system.</p>	<p>Modifications to the Tentative Order to accommodate the EWA's request have been incorporated into the errata sheet (See Errata No. 1)</p>