



EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

California Regional Water Quality Control Board, San Diego Region

August 20, 2012

Mr. Kevin M. Hardy
General Manager
Encina Wastewater Authority
6200 Avenida Encinas
Carlsbad, CA 92011-1095

In reply refer to / attn:
222754:JLLim

SUBJECT: Violation of Order No. R9-2011-0019, NPDES No. CA0107395

Mr. Hardy:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has noted the following violation for the November 2011 monthly self-monitoring report:

The Monitoring and Reported Program of Order No. R9-2011-0019 requires a monitoring frequency of three days per week for CBOD at Monitoring Location M-001. For the week of August 21-27, 2011, at Monitoring Location M-001, only two monitoring results were provided for CBOD.

In the subject line of any response, please include the reference number "222754:JLLim. For questions or comments, please contact Joann Lim by phone at 858-637-5589 or by email at jllim@waterboards.ca.gov.

Respectfully,

Robert W. Morris
Senior WRC Engineer

RWM: jll

Tech Staff Info & Use	
Order No.	R9-2011-0019
Party ID	14804 (Encina Wastewater Authority)
File No.	01-030
WDID	9 000000030
NPDES No.	CA0107395
Reg. Measure No.	378933 (R9-2011-0019), 387078 (SEL)
Place ID	222754 (Encina Ocean Outfall)
Person ID	535784 (Hardy), 525853 (Brian Benjamin)
Violation ID	910158

GRANT DESTACHE, CHAIR | DAVID GIBSON, EXECUTIVE OFFICER

9174 Sky Park Court, Suite 100, San Diego, CA 92123 | (858) 467-2952 | www.waterboards.ca.gov/sandiego

