

**California Regional Water Quality Control Board, San Diego Region**

May 6, 2013

**In reply refer to:**  
**205079:tkirkendall**

Mr. Larry Tardie  
All Seasons RV Park & Campground  
300012 Highway 395  
Escondido, CA. 92026

**Subject: Review of the 2012 Semi-Annual and Annual Monitoring Reports for All Seasons RV Park & Campground**

Mr. Tardie:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following monitoring reports submitted by All Seasons RV Park & Campground, in accordance with the Monitoring and Reporting Program of Order No. 94-05: (a) January-June 2012 and July-December 2012 semi-annual reports, and (b) the January-December 2012 annual reports.

The San Diego Water Board has the following comments on the reports referenced above:

- 1. As specified by section B.1 (Discharge Specifications) of Order No. 94-05, the daily maximum effluent limitation for Biochemical Oxygen Demand (BOD), established at 45 milligrams per liter (mg/L), was violated on the following occasions:

Date	BOD Value (mg/L)
February 28, 2012	78
April 3, 2012	55
April 30, 2012	58
May 17, 2012	57
June 20, 2012	70
July 2, 2012	>150

- 2. The next monitoring report required to be submitted is the January-June 2013 semi-annual monitoring report, which is due by July 30, 2013.


Please take steps to implement follow-up actions necessary to ensure that the violation noted above does not occur in the future. These violations subject All Seasons RV Park & Campground to possible further enforcement action by the San Diego Water Board including administrative enforcement orders requiring All Seasons RV Park & Campground to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of



pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

In the subject line of any response, please include reference **205079: tkirkendall**. Please contact Mr. Tyler Kirkendall at 858-627-3935, or at [tkirkendall@waterboards.ca.gov](mailto:tkirkendall@waterboards.ca.gov) if you have any questions or comments.

Respectfully,



John R. Odermatt, P.G  
Senior Engineering Geologist  
Land Discharge Unit

JRO: mm: tk

Tech Staff Info & Use	
Place ID	205079
Party ID	1214
Reg. Measure ID	390062
Violation ID	947151
	947152
	947153
	947154
	947155
	947156

<sup>1</sup> Under authority of California Water Code section 13350.