

California Regional Water Quality Control Board, San Diego Region

May 6, 2013

In reply refer to:
248439:tkirkendall

Ms. Milica Kaludjerski
Wastewater Management
County of San Diego, Department of Public Works
Pine Valley STP
5510 Overland Ave, Suite 410
San Diego, CA. 92123-1237

Subject: Review of the 2012 Quarterly, Semi-Annual, and Annual Monitoring Reports for Pine Valley STP

Ms. Kaludjerski:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following monitoring reports submitted by the County of San Diego, Department of Public Works (County), in accordance with the Monitoring and Reporting Program of Order No. 94-16: (a) April-June 2012, July-September 2012, October-December 2012 quarterly monitoring reports; (b) January-June 2012 and July-December 2012 semi-annual monitoring reports; and (c) January-December 2012 annual monitoring report.

The San Diego Water Board has the following comments on the reports referenced above:

1. As specified by section B.1 (Discharge Specifications) of Order No. 94-161, the maximum 12-month average effluent limitation for Total Dissolved Solids (TDS), established at 750 milligrams per liter (mg/L), was violated on the following occasions:

Date	TDS Value (mg/L)
January 18, 2012	753
July 11, 2012	872
October 17, 2012	908


2. The next monitoring report required to be submitted is the April-June 2013 quarterly monitoring report, which is due by July 30, 2013.

Please take steps to implement follow-up actions necessary to ensure that the violation noted above does not occur in the future. These violations subject the County to possible further enforcement action by the San Diego Water Board including administrative enforcement orders requiring the County to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil

liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

In the subject line of any response, please include reference **248439: tkirkendall**. Please contact Mr. Tyler Kirkendall at 858-627-3935, or at tkirkendall@waterboards.ca.gov if you have any questions or comments.

Respectfully,



John R. Odermatt, P.G
Senior Engineering Geologist
Land Discharge Unit

JRO: mm: tk

Tech Staff Info & Use	
Place ID	248439
Party ID	11763
Reg. Measure ID	390064
Violation ID	947160
	947161
	947162

¹ Under authority of California Water Code section 13350.