

EDMUND G. BROWN JR.  
GOVERNOR

MATTHEW RODRIGUEZ  
SECRETARY FOR  
ENVIRONMENTAL PROTECTION

---

## California Regional Water Quality Control Board, San Diego Region

February 14, 2014

Ms. Milica Kaludjerski, Unit Manager  
Wastewater Management  
County of San Diego  
550 Overland Ave Suite 315  
San Diego, CA. 92123

**In reply refer to:**  
**271519:acali**

**Subject: Review of the July-December 2013 Semi-Annual and 2013 Annual  
Monitoring Reports for Heise Park Campground**

Ms. Kaludjerski:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following monitoring reports submitted by the County of San Diego for Heise Park Campground, in accordance with the Monitoring and Reporting Program of Order No. 93-09: (a) July-December 2013 semi-annual monitoring report; and (b) 2013 annual monitoring report.

The San Diego Water Board has the following comments on the reports referenced above:

The sample results of effluent for Chloride was reported at a value of 110 mg/L on January 8, 2013; which exceeds the required maximum concentration limit of chloride of 90 mg/L specified by section B.1 (Discharge Specifications) of Order No. 99-04.

The next monitoring report required to be submitted is the January-June 2014 semi-annual monitoring report which is due by July 30, 2014.


Please take steps to implement follow-up actions necessary to ensure that the violation noted above does not occur in the future. These violations subject the Discharger to possible further enforcement action by the San Diego Water Board including administrative enforcement orders requiring the Discharger to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

---

<sup>1</sup> Under authority of California Water Code section 13350.

In the subject line of any response, please include reference **271519:acali**. Please contact Mr. Alex Cali at (619) 521-3355, or at [acali@waterboards.ca.gov](mailto:acali@waterboards.ca.gov) if you have any questions or comments.

Sincerely,



JOHN R. ODERMATT, P.G., Senior Engineering Geologist  
Groundwater Protection Branch

JRO: ac

Tech Staff Info & Use	
Place ID	271519
Party ID	11763
Reg. Measure ID	394886
Violation ID	962603