

STATE OF CALIFORNIA  
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN FRANCISCO BAY REGION

STAFF SUMMARY REPORT (John H. Madigan)  
MEETING DATE: August 13, 2008

ITEM: 5A

SUBJECT: City of Millbrae, Water Pollution Control Plant and North Bayside System Unit (NBSU), Millbrae, San Mateo County - Reissuance of NPDES Permit

CHRONOLOGY: November 2001 - Permit Reissued

DISCUSSION: The Revised Tentative Order (Appendix A) would reissue the NPDES permit for the City of Millbrae's Water Pollution Control Plant. The plant serves a population of approximately 22,000 people. During dry weather, the plant discharges up to 3.0 million gallons per day of secondary-treated wastewater to San Francisco Bay through the NBSU force main and outfall. The NBSU outfall is a deep-water outfall located approximately 5,300 feet northeast of Point San Bruno.

The City and the Bay Area Clean Water Agencies (BACWA) submitted comments (Appendix B) on a draft permit. Appendix C contains our responses and describes changes to the draft permit that resolve many of the City's and BACWA's concerns. All the changes are reflected in the attached Revised Tentative Order. The only significant remaining concern relates to the dioxins limits and compliance schedule. The dioxins comments are similar to those the Board has considered at previous permit hearings. We continue to work with BACWA to develop strategies for resolving impairment of San Francisco Bay and the wastewater treatment plant's compliance problems with dioxins through development of a Total Maximum Daily Load or other means that considers multimedia sources. Because of this ongoing effort, despite the fact that dioxins remain a concern, we expect no testimony at the hearing on this item.

RECOMMENDATION: Adoption of the Revised Tentative Order.

File Number: 2179.7019 (JHM)

Appendices: A. Revised Tentative Order  
B. Comments  
C. Response to Comments

**APPENDIX A**

**Revised Tentative Order**



Linda S. Adams  
Secretary for  
Environmental Protection

# California Regional Water Quality Control Board

## San Francisco Bay Region

1515 Clay Street, Suite 1400  
(510) 622-2300 • Fax (510) 622-2460  
<http://www.waterboards.ca.gov/sanfranciscobay>



Arnold Schwarzenegger  
Governor

### REVISED TENTATIVE ORDER NO. R2-2008-XXXX NPDES NO. CA0037532

The following Discharger is subject to waste discharge requirements set forth in this Order.

**Table 1. Discharger Information**

<b>Discharger</b>	City of Millbrae and North Bayside System Unit (NBSU)
<b>Name of Facility</b>	City of Millbrae Water Pollution Control Plant and collection system
<b>Facility Address</b>	400 East Millbrae Avenue
	Millbrae, CA 94030
	San Mateo County
The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a major discharge.	

The discharge by the City of Millbrae Water Pollution Control Plant and the North Bayside System Unit from the discharge point identified below is subject to waste discharge requirements as set forth in this Order.

**Table 2. Discharge Location**

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
E-002	POTW Effluent	37 °, 39', 55" N	122 °, 21', 41" W	Lower San Francisco Bay

**Table 3. Administrative Information**

This Order was adopted by the Regional Water Board on:	<b>August 13, 2008</b>
This Order shall become effective on:	<b>October 1, 2008</b>
This Order shall expire on:	<b>September 30, 2013</b>
The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than:	<b><u>180 days prior to the Order expiration date</u></b>

IT IS HEREBY ORDERED, that this Order supersedes Order No. 01-143 except for enforcement purposes, and, in order to meet the provisions contained in Division 7 of the California Water Code (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

I, Bruce H. Wolfe, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on **August 13, 2008**.

\_\_\_\_\_  
Bruce H. Wolfe, Executive Officer

## Table of Contents

I. Facility Information.....	4
II. Findings.....	4
III. Discharge Prohibitions.....	9
IV. Effluent Limitations and Discharge Specifications.....	10
A. Effluent Limitations – Discharge Point E-001.....	10
V. Receiving Water Limitations.....	13
A. Surface Water Limitations.....	13
VI. Provisions.....	14
A. Standard Provisions.....	14
B. Monitoring and Reporting Program Requirements.....	14
C. Special Provisions.....	14
1. Reopener Provisions.....	14
2. Special Studies, Technical Reports and Additional Monitoring Requirements.....	15
3. Best Management Practices and Pollution Minimization.....	16
4. Construction, Operation, and Maintenance Specifications.....	18
5. Special Provisions for POTWs.....	20
6. Compliance Schedules.....	22
7. Action Plan for Cyanide.....	23
8. Action Plan for Copper.....	23
VII. Compliance Determination.....	24

## Tables

Table 1. Discharger Information.....	1
Table 2. Discharge Location.....	1
Table 3. Administrative Information.....	1
Table 4. Facility Information.....	4
Table 5. Basin Plan Beneficial Uses of Lower San Francisco Bay.....	6
Table 6. Effluent Limitations – Discharge Point E-001.....	10
Table 7. Minimum Levels for Pollutants with Effluent Limitations.....	11
Table 8. Dioxin-TEQ Compliance Schedule.....	22
Table 9. Cyanide Action Plan.....	23
Table 10. Copper Action Plan.....	23

## Attachments

Attachment A – Definitions.....	A-1
Attachment B – Facility Map.....	B-1
Attachment C – Process Flow Diagram.....	C-1
Attachment D – Federal Standard Provisions.....	D-1
Attachment E – Monitoring and Reporting Program (MRP).....	E-1
Attachment F – Fact Sheet.....	F-1

Attachment G – The following documents are part of this Permit, but are not physically attached due to volume. They are available on the internet at

[www.waterboards.ca.gov/sanfranciscobay/](http://www.waterboards.ca.gov/sanfranciscobay/)

- Self-Monitoring Program, Part A, adopted August 1993
- Standard Provisions and Reporting Requirements, August 1993
- August 6, 2001 Staff Letter: *Requirement for Priority Pollutant Monitoring in Receiving Water and Wastewater Discharges*

Attachment H – Pretreatment Requirements ..... H-1

**I. FACILITY INFORMATION**

The following Discharger is subject to the waste discharge requirements set forth in this Order:

**Table 4. Facility Information**

<b>Discharger</b>	City of Millbrae and North Bayside System Unit
<b>Name of Facility</b>	City of Millbrae Water Pollution Control Plant
<b>Facility Address</b>	400 East Millbrae Avenue
	Millbrae, CA 94030
	San Mateo County
<b>Facility Contact, Title, and Phone</b>	Joseph Magner, Superintendent, (650) 259-2388
<b>Mailing Address</b>	621 Magnolia Avenue Millbrae, CA 94030
<b>Type of Facility</b>	Publicly Owned Treatment Works (POTW)
<b>Facility Design Flow</b>	3.0 million gallons per day (MGD) (average daily dry weather design flow), 9.0 MGD ( peak daily wet weather design flow)

**II. FINDINGS**

The California Regional Water Quality Control Board, San Francisco Bay Region (hereinafter the Regional Water Board), finds:

- A. Background.** The City of Millbrae Water Pollution Control Plant (Millbrae WPCP) and the North Bayside System Unit (NBSU) (hereinafter the Discharger) is currently discharging under Order No. 01-143 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0037532. The Discharger submitted a Report of Waste Discharge dated March 24, 2006, and applied to renew its NPDES permit to discharge up to 3.0 million gallons per day (MGD) of treated wastewater from the Millbrae WPCP.

For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B. Facility Description.** The Discharger owns and operates the Millbrae WPCP, which provides secondary treatment of domestic and commercial wastewater collected from the City of Millbrae (population 22,000). The Millbrae WPCP has an average dry weather design treatment capacity of 3.0 MGD and can treat up to 9 MGD during wet weather.

Wastewater treatment processes at the Millbrae WPCP include grinding, primary sedimentation in rectangular clarifiers, biological activated sludge treatment, secondary clarification, disinfection with sodium hypochlorite, and final effluent skimming. Electricity is generated for on-site use from methane gas produced by sludge digesters. Standby generators supply power to Millbrae WPCP systems during power outages. Recycled water is produced for restricted use applications.

Chlorinated secondary effluent is discharged through Outfall E-001 to the North Bayside System Unit (NBSU) force main. The effluent is dechlorinated at the City of South San Francisco Water Quality Control Plant prior to discharge into Lower San Francisco Bay, a water of the State and the United States, through the NBSU outfall (Outfall E-002). Outfall E-002 is a submerged diffuser

located northeast of Point San Bruno about 5,300 feet offshore at a depth of 20 feet below mean lower low water (37 degrees, 39 minutes, 55 seconds N latitude and 122 degrees, 21 minutes, 41 seconds W longitude). The NBSU is a joint powers authority and includes the Cities of Burlingame, Millbrae, South San Francisco and San Bruno, and San Francisco International Airport (both industrial and domestic waste treatment plants).

Biosolids collected from the wastewater treatment process are thickened in a gravity thickener, anaerobically digested, and dewatered by a belt filter press. On average, the Millbrae WPCP generates 186 dry metric tons of Class B biosolids per year. Approximately 90 dry metric tons of dewatered biosolids are beneficially reused at various land application sites. The remaining biosolids are disposed of at the Potrero Hills and Altamont landfills.

Attachment B provides a map of the area around the Millbrae WPCP. Attachment C provides a flow schematic of the Millbrae WPCP.

- C. Legal Authorities.** This Order is issued pursuant to Clean Water Act (CWA) section 402 and implements regulations adopted by the United States Environmental Protection Agency (USEPA) and Chapters 5.5, Division 7 of the California Water Code (CWC) (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from the Millbrae WPCP to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to Article 4, Chapter 4, Division 7 of the CWC (commencing with section 13260).
- D. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F) containing background information and rationales for Order requirements is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through E and G through H are also incorporated into this Order.
- E. California Environmental Quality Act (CEQA).** Under CWC section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA.
- F. Technology-Based Effluent Limitations.** CWA Section 301(b) and NPDES regulations at 40 CFR 122.44 require that permits include conditions meeting applicable technology-based requirements at minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Secondary Treatment Standards at 40 CFR 133. A detailed discussion of technology-based effluent limitation development is included in the Fact Sheet.
- G. Water Quality-Based Effluent Limitations.** CWA section 301(b) and NPDES regulations at 40 CFR 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards.

NPDES regulations at 40 CFR 122.44(d)(1)(i) mandate that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant that has no numeric criterion or objective, water quality-based effluent limitations (WQBELs) must be

established using (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR 122.44(d)(1)(vi).

**H. Water Quality Control Plans.** *The Water Quality Control Plan for the San Francisco Bay Basin* (the Basin Plan) is the Regional Water Board's master water quality control planning document. It designates beneficial uses and water quality objectives for waters of the State, including surface waters and groundwater. It also includes programs of implementation to achieve water quality objectives. The Basin Plan was duly adopted by the Regional Water Board and approved by the State Water Resources Control Board (State Water Board), USEPA, and the Office of Administrative Law, as required. Requirements of this Order implement the Basin Plan.

The Basin Plan implements State Water Board Resolution No. 88-63, which establishes State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply (MUN). Because of the marine influence on receiving waters of San Francisco Bay, total dissolved solids levels in San Francisco Bay usually (and often significantly) exceed 3,000 milligrams per liter (mg/L) and thereby meet an exception to State Water Board Resolution No. 88-63. Therefore, the MUN designation is not applicable to Lower San Francisco Bay.

Beneficial uses applicable to Lower San Francisco Bay are as follows.

**Table 5. Basin Plan Beneficial Uses of Lower San Francisco Bay**

Discharge Point	Receiving Water Name	Beneficial Uses
E-002	Lower San Francisco Bay	Industrial Service Supply (IND) Navigation (NAV) Water Contact Recreation (REC1) Non-Contact Water Recreation (REC2) Ocean, Commercial and Sport Fishing (COMM) Wildlife Habitat (WILD) Preservation of Rare and Endangered Species (RARE) Fish Migration (MIGR) Shellfish Harvesting (SHELL) Estuarine Habitat (EST)

**I. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. About forty criteria in the NTR apply in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the State. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants.

**J. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR



and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.

- K. Compliance Schedules and Interim Requirements.** Section 2.1 of the SIP provides that, based on an existing Discharger's request and demonstration that it is infeasible for it to achieve immediate compliance with an effluent limitation derived from a CTR criterion, a compliance schedule may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed 5 years from the date that the permit is issued or reissued, nor may it extend beyond 10 years from the effective date of the SIP (or May 18, 2010) to establish and comply with CTR criterion-based effluent limitations. Where a compliance schedule for a final effluent limitation exceeds 1 year, the Order must include interim numeric limitations for that constituent or parameter. Where allowed by the Basin Plan, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to implement a new or revised water quality objective. This Order includes compliance schedules and discharge specifications. A detailed discussion of the basis for the compliance schedules and discharge specifications is included in the Fact Sheet.
- L. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards become effective for CWA purposes. [65 Fed. Reg. 24641 (April 27, 2000) (codified at 40 CFR 131.21)]. Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- M. Stringency of Requirements for Individual Pollutants.** This Order contains both technology-based and WQBELs for individual pollutants. The technology-based effluent limitations consist of restrictions on oil and grease, pH, total suspended solids (TSS), and carbonaceous biochemical oxygen demand (CBOD). Derivation of these technology-based limitations is discussed in the Fact Sheet (Attachment F). This Order's technology-based pollutant restrictions implement the minimum applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum federal technology-based requirements as necessary to meet water quality standards.
- N. Antidegradation Policy.** NPDES regulations at 40 CFR 131.12 require that the State water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law and requires that existing water quality be maintained unless degradation is justified based on specific findings. The Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. As discussed in detail in the Fact Sheet, the permitted discharge is consistent with the antidegradation provisions of 40 CFR 131.12 and State Water Board Resolution No. 68-16.

- O. Anti-Backsliding Requirements.** CWA Sections 402(o)(2) and 303(d)(4) and NPDES regulations at 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. Some effluent limitations in this Order are less stringent than those in Order No. 01-143. As discussed in detail in the Fact Sheet, this relaxation of effluent limitations is consistent with the anti-backsliding requirements of the CWA and federal regulations.
- P. Monitoring and Reporting.** NPDES regulations at 40 CFR 122.48 require that all NPDES permits specify requirements for recording and reporting monitoring results. CWC sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.
- Q. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR 122.42, are provided in Attachment D. The Discharger must comply with all standard provisions and with those additional conditions that are applicable under 40 CFR 122.42. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. A rationale for the special provisions contained in this Order is provided in the attached Fact Sheet.
- R. Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet.
- S. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet.

**III. DISCHARGE PROHIBITIONS**

- A.** Discharge of wastewater at a location or in a manner different from that described in this Order is prohibited.
- B.** The average dry weather flow, as measured at station E-001 described in the attached Monitoring and Reporting Plan (MRP) (Attachment E), shall not exceed 3.0 MGD. The average dry weather flow shall be determined for compliance with this prohibition over three consecutive dry weather months each year.
- C.** Discharge of wastewater into Lower San Francisco Bay at any point where it does not receive an initial dilution of at least 10:1 is prohibited.
- D.** The bypass of untreated or partially treated wastewater to waters of the United States is prohibited, except as provided for in the conditions stated in 40 CFR 122.41(m)(4) and in section A.13 of the Standard Provisions and Reporting Requirements for NPDES Surface Water Discharge Permits, August 1993 (Attachment G).
- E.** Any sanitary sewer overflow that results in a discharge of untreated or partially treated wastewater to waters of the United States is prohibited.

**IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS****A. Effluent Limitations – Discharge Point E-001****1. Effluent Limitations for Specific Pollutants**

- a. The Discharger shall maintain compliance with the following effluent limitations at Discharge Point E-001 with compliance measured at Monitoring Location E-001 as described in the attached MRP (Attachment E).

**Table 6. Effluent Limitations – Discharge Point E-001**

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Oil and Grease	mg/L	10	---	20	---	---
pH <sup>(1)</sup>	standard units	---	---	---	6.0	9.0
Total Suspended Solids (TSS)	mg/L	30	45	---	---	---
Carbonaceous Biochemical Oxygen Demand (CBOD)	mg/L	25	40	---	---	---
Ammonia (as Nitrogen)	mg/L N	110	---	160	---	---
Chlorine, Total Residual	mg/L	---	---	---	---	0.0 <sup>(2)</sup>
Copper <sup>(3), (4), (5)</sup>	µg/L	71	---	100	---	---
Cyanide <sup>(3), (5)</sup>	µg/L	20	---	44	---	---
Dioxin-TEQ <sup>(3), (5), (6)</sup>	µg/L	1.4 x 10 <sup>-8</sup>	---	2.8 x 10 <sup>-8</sup>	---	---

- <sup>(1)</sup> If the Discharger monitors pH continuously, pursuant to 40 CFR 401.17, the Discharger shall be in compliance with the pH limitation specified herein, provided that both of the following conditions are satisfied: (i) the total time during which the pH values are outside the required range of pH values shall not exceed 7 hours and 26 minutes in any calendar month; and (ii) no individual excursion from the range of pH values shall exceed 60 minutes.
- <sup>(2)</sup> This requirement is defined as below the limit of detection in standard test methods as defined in the latest edition of *Standard Methods for the Examination of Water and Wastewater*. The Discharger may elect to use a continuous on-line monitoring system(s) for measuring flows, sodium hypochlorite, and sodium bisulfite dosage (including a safety factor) and concentration to prove that chlorine residual exceedances are false positives. If convincing evidence is provided, Regional Water Board staff will conclude that these chlorine residual exceedances are false positives and are not violations of the Order's Total Residual Chlorine limit. Chlorine residual compliance may be demonstrated by monitoring at the NBSU common outfall (E-002).
- <sup>(3)</sup> a. Limitations for toxic pollutants apply to the average concentration of all samples collected during the averaging period (daily = 24-hour period; monthly = calendar month).  
b. All metals limitations are expressed as total recoverable metal.
- <sup>(4)</sup> Alternate Effluent Limits for Copper:  
a. If copper Site Specific Objectives (SSOs) for the receiving water become legally effective, resulting in an adjusted saltwater Criterion Continuous Concentration (CCC) of 2.5 micrograms per liter (µg/L) and a Criterion Maximum Concentration (CMC) of 3.9 µg/L, as documented in the Basin Plan Amendment Resolution R2-2007-0042 and in *Copper Site-Specific Objectives in San Francisco Bay: Proposed Basin Plan Amendment and Draft Staff Report* (dated June 6, 2007), then upon their effective date, the following limitations shall supersede those copper limitations listed in Table 7 (the rationale for these effluent limitations can be found in the Fact Sheet [Attachment F]).  
Maximum Daily Effluent Limitation (MDEL) = 77 µg/L, and Average Monthly Effluent Limitation (AMEL) = 53 µg/L.  
b. If a different copper SSO for the receiving water is adopted, alternate WQBELs based on the SSO will be determined after the SSO effective date.
- <sup>(5)</sup> A daily maximum or average monthly value for a given constituent shall be considered noncompliant with the effluent limitations only if it exceeds the effluent limitation and the Reporting Level for that constituent. As outlined in Section 2.4.5 of the SIP, Table 7, below, indicates the Minimum Level (ML) for compliance determination purposes. An ML is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is

equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

- (6) Final effluent limitations for dioxin toxic equivalents (dioxin-TEQ) shall become effective in accordance with the compliance schedule established by Section VI.C.7 of this Order.

- b. **CBOD and TSS 85 Percent Removal:** The concentration-based average monthly percent removal of CBOD and TSS shall not be less than 85 percent.
- c. **Fecal Coliform Bacteria:** The treated wastewater shall meet the following bacteriological limits:
- (1) The geometric mean value for all samples analyzed for fecal coliform bacteria within each calendar month shall not exceed a Most Probable Number (MPN) of 200 organisms per 100 milliliters (MPN/100 mL); and
  - (2) No more than ten percent (10%) of all samples collected within each calendar month shall exceed a fecal coliform bacteria level of 400 MPN/100 mL.
- d. **Enterococci Bacteria:** The monthly geometric mean enterococci bacteria concentration shall not exceed 35 MPN/100 mL.

**Table 7. Minimum Levels for Pollutants with Effluent Limitations**

Parameter	Minimum Level	Units
Copper	2	µg/L
Cyanide	5	µg/L
2,3,7,8-TCDD	5	pg/L
1,2,3,7,8-PeCDD	25	pg/L
1,2,3,4,7,8-HxCDD	25	pg/L
1,2,3,6,7,8-HxCDD	25	pg/L
1,2,3,7,8,9-HxCDD	25	pg/L
1,2,3,4,6,7,8-HpCDD	25	pg/L
OCDD	50	pg/L
2,3,7,8-TCDF	5	pg/L
1,2,3,7,8-PeCDF	25	pg/L
2,3,4,7,8-PeCDF	25	pg/L
1,2,3,4,7,8-HxCDF	25	pg/L
1,2,3,6,7,8-HxCDF	25	pg/L
1,2,3,7,8,9-HxCDF	25	pg/L
2,3,4,6,7,8-HxCDF	25	pg/L
1,2,3,4,6,7,8-HpCDF	25	pg/L
1,2,3,4,7,8,9-HpCDF	25	pg/L
OCDF	50	pg/L

### 3. Acute Toxicity:

- a. Representative samples of the effluent at Discharge Point E-001 shall meet the following limits for acute toxicity: Bioassays shall be conducted in compliance with Section V.A of the MRP (Attachment E).

The survival of organisms in undiluted combined effluent shall be:

- an eleven (11) sample median value of not less than 90 percent survival, and
  - an eleven (11) sample 90 percentile value of not less than 70 percent survival.
- b. These acute toxicity limitations are further defined as follows:
- 11 sample median:** A bioassay test showing survival of less than 90 percent represents a violation of this effluent limit, if five or more of the past ten or less bioassay tests show less than 90 percent survival.
- 90th percentile:** A bioassay test showing survival of less than 70 percent represents a violation of this effluent limit, if one or more of the past ten or less bioassay tests show less than 70 percent survival.
- c. Bioassays shall be performed using the most up-to-date USEPA protocol and the most sensitive species based on the most recent screening test results. Bioassays shall be conducted in compliance with *Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms*, currently 5th Edition (EPA-821-R-02-012).
- d. If the Discharger can demonstrate to the satisfaction of the Executive Officer that toxicity exceeding the levels cited above is caused by ammonia and that the ammonia in the discharge is in compliance with effluent limits, then such toxicity does not constitute a violation of this effluent limitation.

### 4. Chronic Toxicity

- a. Compliance with the Basin Plan narrative chronic toxicity objective shall be demonstrated according to the following tiered requirements based on results from representative samples of the treated final effluent at Discharge Point E-001 meeting test acceptability criteria and Section V.B of the MRP (Attachment E). Failure to conduct the required toxicity tests or a TRE within a designated period shall result in the establishment of effluent limitations for chronic toxicity.
- (1) Conduct routine monitoring.
  - (2) Accelerate monitoring after exceeding a single-sample maximum of 10 chronic toxicity units (TUc), consistent with Table 4-5 of the Basin Plan for dischargers monitoring chronic toxicity annually. Accelerated monitoring shall consist of monthly monitoring.

- (3) Return to routine monitoring if accelerated monitoring does not exceed the “trigger” in (2), above.
- (4) If accelerated monitoring confirms consistent toxicity above the “trigger” in (2), above, initiate toxicity identification evaluation/toxicity reduction evaluation (TIE/TRE) in accordance with a workplan submitted in accordance with Section V.B.3 of the MRP (Attachment E) that incorporates any and all comments from the Executive Officer.
- (5) Return to routine monitoring after appropriate elements of the TRE workplan are implemented and either the toxicity drops below the “trigger” level in (2), above, or, based on the results of the TRE, the Executive Officer authorizes a return to routine monitoring.

b. Test Species and Methods

The Discharger shall conduct routine monitoring with the test species and protocols specified in Section V.B of the MRP (Attachment E). The Discharger shall also perform Chronic Toxicity Screening Phase monitoring as described in the Appendix E-1 of the MRP (Attachment E). Chronic Toxicity Monitoring Screening Phase Requirements, Critical Life Stage Toxicity Tests and definitions of terms used in the chronic toxicity monitoring are identified in Appendices E-1 and E-2 of the MRP (Attachment E).

## V. RECEIVING WATER LIMITATIONS

### A. Surface Water Limitations

1. Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharges shall not cause the following in Lower San Francisco Bay:
  - a. Floating, suspended, or deposited macroscopic particulate matter or foams;
  - b. Bottom deposits or aquatic growths to the extent that such deposits or growths cause nuisance or adversely affect beneficial uses;
  - c. Alteration of temperature, turbidity, or apparent color beyond present natural background levels;
  - d. Visible, floating, suspended, or deposited oil and other products of petroleum origin; or
  - e. Toxic or other deleterious substances to be present in concentrations or quantities that will cause deleterious effects on wildlife, waterfowl, or other aquatic biota, or that render any of these unfit for human consumption, either at levels created in the receiving waters or as a result of biological concentration.
2. The discharge of waste shall not cause the following limits to be exceeded in waters of the State within one foot of the water surface:

- a. Dissolved Oxygen                      5.0 mg/L, minimum

The median dissolved oxygen concentration for any three consecutive months shall not be less than 80% of the dissolved oxygen content at saturation. When natural factors cause concentrations less than that specified above, the discharge shall not cause further reduction in ambient dissolved oxygen concentrations.

- b. Dissolved Sulfide                      Natural background levels
- c. pH    Within a range from 6.5 to 8.5

## VI. PROVISIONS

### A. Standard Provisions

1. The Discharger shall comply with Federal Standard Provisions included in Attachment D of this Order.
2. The Discharger shall comply with all applicable items of the Standard Provisions and Reporting Requirements for NPDES Surface Water Discharge Permits, August 1993 (Standard Provisions, Attachment G). Where provisions or reporting requirements specified in this Order and Attachment G are different from equivalent or related provisions or reporting requirements given in the Standard Provisions in Attachment D, the specifications of this Order and/or Attachment G shall apply in areas where those provisions are more stringent. Duplicative requirements in the federal Standard Provisions in VI.A.1.2, above (Attachment D), and the regional Standard Provisions (Attachment G) are not separate requirements. A violation of a duplicative requirement does not constitute two separate violations.

### B. Monitoring and Reporting Program Requirements

The Discharger shall comply with the MRP (Attachment E) and future revisions thereto. The Discharger shall also comply with the requirements contained in *Self Monitoring Programs, Part A*, August 1993 (Attachment G).

### C. Special Provisions

#### 1. Reopener Provisions

The Regional Water Board may modify or reopen this Order prior to its expiration date in any of the following circumstances as allowed by law:

- a. If present or future investigations demonstrate that the discharges governed by this Order will have, or will cease to have, a reasonable potential to cause or contribute to adverse impacts on water quality and/or beneficial uses of the receiving waters.
- b. If new or revised WQOs or Total Maximum Daily Loads (TMDLs) come into effect for the San Francisco Bay estuary and contiguous water bodies (whether statewide, regional, or site-specific). In such cases, effluent limitations in this Order will be modified as necessary to reflect updated WQOs and waste load allocations in TMDLs. Adoption of



effluent limitations contained in this Order is not intended to restrict in any way future modifications based on legally adopted WQOs, TMDLs, or as otherwise permitted under Federal regulations governing NPDES permit modifications.

- c. If translator or other water quality studies provide a basis for determining that a permit condition(s) should be modified.
- d. If an administrative or judicial decision on a separate NPDES permit or WDR addresses requirements similar to this discharge.
- e. Or as otherwise authorized by law.

The Discharger may request permit modification based on the above. The Discharger shall include in any such request an antidegradation and antibacksliding analysis.

## **2. Special Studies, Technical Reports and Additional Monitoring Requirements**

### **a. Effluent Characterization for Selected Constituents**

The Discharger shall continue to monitor and evaluate the discharge from Discharge Point E-001 (measured at E-001) for the constituents listed in Enclosure A of the Regional Water Board's August 6, 2001, Letter entitled, *Requirement for Monitoring of Pollutants in Effluent and Receiving Water to Implement New Statewide Regulations and Policy (Attachment G)*, according to the sampling frequency specified in the attached MRP (Attachment E). Compliance with this requirement shall be achieved in accordance with the specifications stated in the Regional Water Board's August 6, 2001, Letter under Effluent Monitoring for Major Dischargers.

The Discharger shall evaluate on an annual basis if concentrations of any constituent increase over past performance. The Discharger shall investigate the cause of the increase. The investigation may include, but need not be limited to, an increase in the effluent monitoring frequency, monitoring of internal process streams, and monitoring of influent sources. This may be satisfied through identification of these constituents as "Pollutants of Concern" in the Discharger's Pollutant Minimization Program described in Provision C.3.b, below. A summary of the annual evaluation of data and source investigation activities shall also be reported in the annual self-monitoring report.

A final report that presents all the data shall be submitted to the Regional Water Board no later than 180 days prior to the Order expiration date. This final report shall be submitted with the application for permit reissuance.

### **b. Ambient Background Receiving Water Study**

The Discharger shall collect or participate in collecting background ambient receiving water monitoring data for priority pollutants for which the Regional Water Board is required to perform reasonable potential analyses and calculate effluent limitations. The data on the conventional water quality parameters (pH, salinity, and hardness) shall be sufficient to characterize these parameters in the receiving water at a point after the discharge has mixed with the receiving waters. This provision may be met through

monitoring through a Collaborative Bay Area Clean Water Agencies (BACWA) Study or a similar ambient monitoring program for San Francisco Bay. This Order may be reopened, as appropriate, to incorporate effluent limits or other requirements based on Regional Water Board review of these data.

The Discharger shall submit a final report that presents all this data to the Regional Water Board 180 days prior to Order expiration, or cause one to be submitted on its behalf. This final report shall be submitted prior to or with the application for permit reissuance.

**c. Optional Mass Offset**

If the Discharger can demonstrate that further net reductions of the total mass loadings of 303(d)-listed pollutants to the receiving water cannot be achieved through economically feasible measures such as aggressive source control, wastewater reuse, and treatment plant optimization, but only through a mass offset program, the Discharger may submit to the Regional Water Board for approval a mass offset plan to reduce 303(d)-listed pollutants to the same watershed or drainage basin. The Regional Water Board may modify this Order to allow an approved mass offset program.

**3. Best Management Practices and Pollution Minimization**

**a. Pollution Minimization Program**

The Discharger shall continue to improve, in a manner acceptable to the Executive Officer, its existing Pollutant Minimization Program to promote minimization of pollutant loadings to the treatment plant and therefore to the receiving waters.

**b. Annual Pollution Prevention Report**

The Discharger shall submit an annual report, acceptable to the Executive Officer, no later than February 28th of each calendar year. The annual report shall cover January through December of the preceding year. Each annual report shall include at least the following information:

- (1) *A brief description of its treatment plant, treatment plant processes and service area.*
- (2) *A discussion of the current pollutants of concern.* Periodically, the Discharger shall determine which pollutants are currently a problem and/or which pollutants may be potential future problems. This discussion shall include the reasons why the pollutants were chosen.
- (3) *Identification of sources for the pollutants of concern.* This discussion shall include how the Discharger intends to estimate and identify pollutant sources. The Discharger should also identify sources or potential sources not directly within the ability or authority of the Discharger to control, such as pollutants in the potable water supply and air deposition.
- (4) *Identification of tasks to reduce the sources of the pollutants of concern.* This discussion shall identify and prioritize tasks to address the Discharger's pollutants of

concern. The Discharger may implement the tasks themselves or participate in group, regional, or national tasks that will address its pollutants of concern whenever it is efficient and appropriate to do so. A time line shall be included for the implementation of each task.

- (5) *Outreach to employees.* The Discharger shall inform its employees about the pollutants of concern, potential sources, and how they might be able to help reduce the discharge of these pollutants. The Discharger may provide a forum for employees to provide input to the program.
  - (6) *Continuation of Public Outreach Program.* The Discharger shall prepare a public outreach program to communicate pollution minimization measures to its service area. Outreach may include participation in existing community events such as county fairs, initiating new community events such as displays and contests during Pollution Prevention Week, conducting school outreach programs, conducting plant tours, and providing public information in various media. Information shall be specific to target audiences. The Discharger shall coordinate with other agencies as appropriate.
  - (7) *Discussion of criteria used to measure Program's and tasks' effectiveness.* The Discharger shall establish criteria to evaluate the effectiveness of its Pollution Minimization Program. This shall include discussion of the specific criteria used to measure the effectiveness of each of the tasks in item b(3), (4), (5), and (6).
  - (8) *Documentation of efforts and progress.* This discussion shall detail all of the Discharger's activities in the Pollution Minimization Program during the reporting year.
  - (9) *Evaluation of Program's and tasks' effectiveness.* The Discharger shall use the criteria established in b. to evaluate the Pollutant Minimization Program's and tasks' effectiveness.
  - (10) *Identification of specific tasks and time schedules for future efforts.* Based on the evaluation in (9) above, the Discharger shall detail how it intends to continue or change its tasks to more effectively reduce pollutant loadings to the treatment plant and subsequently to receiving waters.
- c. Pollutant Minimization Program for Reportable Priority Pollutants

The Discharger shall develop and conduct a Pollutant Minimization Program as further described below when there is evidence (e.g., sample results reported as Detected but Not Quantified [DNQ] when the effluent limitation is less than the method detection limit [MDL]), sample results from analytical methods more sensitive than those methods required by this Order, presence of whole effluent toxicity, health advisories for fish consumption, results of benthic or aquatic organism tissue sampling) that a priority pollutant is present in the effluent above an effluent limitation and either:

- (1) A sample result is reported as DNQ and the effluent limitation is less than the Reporting Limit (RL); or

- (2) A sample result is reported as Not Detected (ND) and the effluent limitation is less than the MDL, using definitions described in the SIP.
- d.** If triggered by the reasons in c. above, the Discharger's Pollutant Minimization Program shall include, but not be limited to, the following actions and submittals acceptable to the Regional Water Board:
- (1) An annual review and semi-annual monitoring of potential sources of the reportable priority pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling, or alternative measures approved by the Executive Officer when it is demonstrated that source monitoring is unlikely to produce useful analytical data;
  - (2) Quarterly monitoring for the reportable priority pollutant(s) in the influent to the wastewater treatment system, or alternative measures approved by the Executive Officer when it is demonstrated that influent monitoring is unlikely to produce useful analytical data;
  - (3) Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable priority pollutant(s) in the effluent at or below the effluent limitation;
  - (4) Implementation of appropriate cost-effective control measures for the reportable priority pollutant(s), consistent with the control strategy; and
  - (5) The annual report required by 3.b. above, shall specifically address the following items:
    - i. All PMP monitoring results for the previous year;
    - ii. A list of potential sources of the reportable priority pollutant(s);
    - iii. A summary of all actions undertaken pursuant to the control strategy; and
    - iv. A description of actions to be taken in the following year.

#### **4. Construction, Operation, and Maintenance Specifications**

##### **a. Wastewater Facilities Review and Evaluation and Status Reports**

- (1) The Discharger shall operate and maintain its wastewater collection, treatment, and disposal facilities in a manner to ensure that all facilities are adequately staffed, supervised, financed, operated, maintained, repaired, and upgraded as necessary, in order to provide adequate and reliable transport, treatment, and disposal of all wastewater from both existing and planned future wastewater sources under the Discharger's service responsibilities.
- (2) The Discharger shall regularly review and evaluate its wastewater facilities and operation practices in accordance with (1) above. Reviews and evaluations shall be conducted as an ongoing component of the Discharger's administration of its wastewater facilities.

- (3) The Discharger shall provide the Executive Officer, upon request, a report describing the current status of its wastewater facilities and operation practices, including any recommended or planned actions and an estimated time schedule for these actions. The Discharger shall also include, in each annual Self-Monitoring Report, a description or summary of review and evaluation procedures, and applicable wastewater facility programs or capital improvement projects.

**b. Operations and Maintenance Manual, Review and Status Reports**

- (1) The Discharger shall maintain an Operations and Maintenance (O&M) manual for its wastewater facilities. The O&M Manual shall be maintained in usable condition and be available for reference and use by all applicable personnel.
- (2) The Discharger shall regularly review, revise, or update, as necessary, the O&M Manual(s) to ensure that the document(s) may remain useful and relevant to current equipment and operation practices. Reviews shall be conducted annually, and revisions or updates shall be completed as necessary. Applicable revisions of the O&M manual shall be completed within 90 days of any significant changes being made in Millbrae WPCP equipment or operation practices.
- (3) The Discharger shall provide the Executive Officer a report describing the current status of its O&M manual, including any recommended or planned actions and an estimated time schedule for these actions, upon request. The Discharger shall also include a description or summary of review and evaluation procedures and applicable changes to its O&M manual in each Annual Self-Monitoring Report.

**c. Contingency Plan, Review and Status Reports**

- (1) The Discharger shall maintain a Contingency Plan as required by Regional Water Board Resolution 74-10 (Attachment G) and as prudent in accordance with current municipal facility emergency planning. The discharge of pollutants in violation of this Order where the Discharger has failed to develop and/or adequately implement a Contingency Plan will be the basis for considering such discharge a willful and negligent violation of this Order pursuant to Section 13387 of the California CWC.
- (2) The Discharger shall regularly review the Contingency Plan so that the plan may remain useful and relevant to current equipment and operation practices. Reviews shall be conducted annually, and updates shall be completed as necessary.
- (3) The Discharger shall provide the Executive Officer a report describing the current status of its review and update of the Contingency Plan upon request. The Discharger shall also include a description or summary of review and evaluation procedures and applicable changes to its Contingency Plan in each Annual Self-Monitoring Report.

## 5. Special Provisions for POTWs

### a. Pretreatment Program

- (1) The Discharger shall implement and enforce its approved pretreatment program in accordance with federal Pretreatment Regulations (40 CFR 403), pretreatment standards promulgated under Sections 307(b), 307(c), and 307(d) of the Clean Water Act, pretreatment requirements specified under 40 CFR 122.44(j), and the requirements in Attachment H, "Pretreatment Requirements." The Discharger's responsibilities include, but are not limited to:
  - i. Enforcement of National Pretreatment Standards of 40 CFR 403.5 and 403.6;
  - ii. Implementation of its pretreatment program in accordance with legal authorities, policies, procedures, and financial provisions described in the General Pretreatment regulations (40 CFR 403) and its approved pretreatment program;
  - iii. Submission of reports to USEPA, the State Water Board, and the Regional Water Board, as described in Attachment H "Pretreatment Requirements."
  - iv. Evaluate the need to revise local limits under 40 CFR 403.5(c)(1); and within 180 days after the effective date of this Order, submit a report describing the changes with a plan and schedule for implementation. To ensure no significant increase in the discharge of copper, and thus compliance with antidegradation requirements, the Discharger shall not consider eliminating or relaxing local limits for copper in this evaluation.
- (2) The Discharger shall implement its approved pretreatment program and the program shall be an enforceable condition of this Order. If the Discharger fails to perform the pretreatment functions, the Regional Water Board, the State Water Board, or the USEPA may take enforcement actions against the Discharger as authorized by the Clean Water Act.

### b. Sludge Management Practices Requirements

- (1) All sludge generated by the Discharger must be disposed of in a municipal solid waste landfill, reused by land application, or disposed of in a sludge-only landfill in accordance with 40 CFR 503. If the Discharger desires to dispose of sludge by a different method, a request for permit modification must be submitted to USEPA 180 days before start-up of the alternative disposal practice. All the requirements in 40 CFR 503 are enforceable by USEPA whether or not they are stated in an NPDES permit or other permit issued to the Discharger. The Regional Water Board should be copied on relevant correspondence and reports forwarded to USEPA regarding sludge management practices.
- (2) Sludge treatment, storage and disposal or reuse shall not create a nuisance, such as objectionable odors or flies, or result in groundwater contamination.

- (3) The Discharger shall take all reasonable steps to prevent or minimize any sludge use or disposal which has a likelihood of adversely affecting human health or the environment.
- (4) The discharge of sludge shall not cause waste material to be in a position where it is or can be carried from the sludge treatment and storage site and deposited in waters of the State.
- (5) The sludge treatment and storage site shall have facilities adequate to divert surface runoff from adjacent areas, to protect boundaries of the site from erosion, and to prevent any conditions that would cause drainage from the materials in the temporary storage site. Adequate protection is defined as protection from at least a 100-year storm and protection from the highest possible tidal stage that may occur.
- (6) For sludge that is applied to the land, placed on a surface disposal site, or fired in a sludge incinerator as defined in 40 CFR 503, the Discharger shall submit an annual report to USEPA and the Regional Water Board containing monitoring results and pathogen and vector attraction reduction requirements as specified by 40 CFR 503, postmarked February 15 of each year, for the period covering the previous calendar year.
- (7) Sludge that is disposed of in a municipal solid waste landfill must meet the requirements of 40 CFR 258. In the annual Self-Monitoring Report, the Discharger shall include the amount of sludge disposed of and the landfill(s) to which it was sent.
- (8) Permanent on-site sludge storage or disposal activities are not authorized by this Order. A report of Waste Discharge shall be filed and the site brought into compliance with all applicable regulations prior to commencement of any such activity by the Discharger.
- (9) Sludge Monitoring and Reporting Provisions of this Regional Water Board's Standard Provisions (Attachment G), apply to sludge handling, disposal and reporting practices.
- (10) The Regional Water Board may amend this Order prior to expiration if changes occur in applicable state and federal sludge regulations.

**c. Sanitary Sewer Overflows and Sewer System Management Plan**

The Discharger's collection system is part of the facility that is subject to this Order. As such, the Discharger must properly operate and maintain its collection system (Attachment D, Standard Provisions - Permit Compliance, subsection I.D). The Discharger must report any noncompliance (Attachment D, Standard Provision - Reporting, subsections V.E.1 and V.E.2), and mitigate any discharge from the Discharger's collection system in violation of this Order (Attachment D, Standard Provisions - Permit Compliance, subsection I.C). The General Waste Discharge Requirements for Collection System Agencies (Order No. 2006-0003 DWQ) has requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. While the Discharger must comply with both the

General Waste Discharge Requirements for Collection System Agencies (General Collection System WDR) and this Order, the General Collection System WDR more clearly and specifically stipulates requirements for operation and maintenance and for reporting and mitigating sanitary sewer overflows.

Implementation of the General Collection System WDR requirements for proper operation and maintenance and mitigation of spills will satisfy the corresponding federal NPDES requirements specified in this Order. Following reporting requirements in the General Collection System WDR will satisfy NPDES reporting requirements for sewage spills. Furthermore, the Discharger shall comply with the schedule for development of sewer system management plans (SSMPs) as indicated in the letter issued by the Regional Water Board on July 7, 2005, pursuant to CWC Section 13267; and with the sanitary sewer overflow and unauthorized discharge notification and reporting requirements of the letter issued by the Regional Water Board on May 1, 2008, pursuant to CWC Section 13267. The Discharger shall report sanitary sewer overflows electronically using the State Water Board's on-line reporting system.

## 6. Compliance Schedules

The following table outlines actions to be completed in order to meet the final limit for dioxin-TEQ.

**Table 8. Dioxin-TEQ Compliance Schedule**

Task	Deadline
1. Continue source control measures identified in the Discharger's Infeasibility Report to reduce concentrations of dioxin-TEQ to the treatment plant, and therefore to receiving waters.	Upon the effective date of this Order.
2. Evaluate and report on the effectiveness of source control measures in reducing concentrations of dioxin-TEQ to the treatment plant. If previous measures have not been successful in enabling the Discharger to comply with final limits for dioxin-TEQ, the Discharger shall also identify and implement additional source control measures to further reduce concentrations of these pollutants.	Annually by February 28 <sup>th</sup> with the Annual Pollution Prevention Report required by Section VI.C.3.b, above.
3. In the event that source control measures are insufficient for meeting the final water quality based effluent limit specified in Effluent Limitations and Discharge Specifications A.2 for dioxin-TEQ, submit a schedule for implementation of additional actions to reduce the concentrations of these pollutants.	No later than 12 months after a detection of dioxin-TEQ that is out of compliance with the final effluent limits.
4. Commence implementation of the identified additional actions in accordance with the schedule submitted in task 3, above.	Annually by February 28 <sup>th</sup> with the Annual Pollution Prevention Report required by Section VI.C.3.b, above.
5. Comply with IV. Effluent Limitations and Discharger Specifications A.2 for dioxin-TEQ. Alternatively, the Discharger may comply with the limit through implementation of a mass offset strategy for dioxin-TEQ in accordance with policies in effect at that time (see Provision VI.C.2c).	10 years following the effective date of this Order



## 7. Action Plan for Cyanide

The Discharger shall implement monitoring and surveillance, pretreatment, source control, and pollution prevention for cyanide in accordance with the following tasks and time schedule.

**Table 9. Cyanide Action Plan**

Task	Compliance Date
<p><b>1. Review Potential Cyanide Contributors</b></p> <p>The Discharger shall submit an inventory of potential contributors of cyanide to the treatment plant (e.g., metal plating operations, hazardous waste recycling, etc.). If no contributors of cyanide are identified, Tasks 2 and 3 are not required, unless the Discharger receives a request to discharge detectable levels of cyanide to the sanitary sewer. If so, the Discharger shall notify the Executive Officer and implement Tasks 2 and 3.</p>	By February 28, 2009.
<p><b>2. Implement Cyanide Control Program</b></p> <p>The Discharger shall submit a plan for and begin implementation of a program to minimize cyanide discharges to the sanitary sewer system consisting, at a minimum, of the following elements:</p> <ol style="list-style-type: none"> <li>Inspect each potential contributor to assess the need to include that contributing source in the control program.</li> <li>Inspect contributing sources included in the control program annually. Inspection elements may be based on U.S. EPA guidance, such as Industrial User Inspection and Sampling Manual for POTWs (EPA 831-B-94-01).</li> <li>Develop and distribute educational materials to contributing sources and potential contributing sources regarding the need to prevent cyanide discharges.</li> <li>Prepare an emergency monitoring and response plan to be implemented if a significant cyanide discharge occurs.</li> <li>If ambient monitoring shows cyanide concentrations of 1.0 µg/L or higher in the main body of San Francisco Bay, undertake actions to identify and abate cyanide sources responsible for the elevated ambient concentrations.</li> </ol>	February 28, 2010, with 2009 annual pollution prevention report.
<p><b>3. Report Status of Cyanide Control Program</b></p> <p>Submit a report to the Regional Water Board documenting implementation of the cyanide control program.</p>	Annually with annual pollution prevention reports due February 28.

## 8. Action Plan for Copper

The Discharger shall implement pretreatment, source control, and pollution prevention for copper in accordance with the following tasks and time schedule.

**Table 10. Copper Action Plan**

Task	Compliance Date
<p><b>1. Review Potential Copper Sources</b></p> <p>The Discharger shall submit an inventory of potential copper sources to the treatment plant.</p>	By February 28, 2009.

Task	Compliance Date
<p><b>2. Implement Copper Control Program</b> The Discharger shall submit a plan for and begin implementation of a program to reduce copper discharges identified in Task 1 consisting, at a minimum, of the following elements:</p> <ul style="list-style-type: none"> <li>a. Provide education and outreach to the public (e.g., focus on proper pool and spa maintenance and plumbers' roles in reducing corrosion).</li> <li>b. If corrosion is determined to be a significant copper source, work cooperatively with local water purveyors to reduce and control water corrosivity, as appropriate, and ensure that local plumbing contractors implement best management practices to reduce corrosion in pipes.</li> <li>c. Educate plumbers, designers, and maintenance contractors for pools and spas to encourage best management practices that minimize copper discharges.</li> </ul>	February 28, 2010, with 2009 annual pollution prevention report.
<p><b>3. Implement Additional Measures</b> If the three-year rolling mean copper concentration of the receiving water exceeds 3.0 µg/L, evaluate the effluent copper concentration trend, and if it is increasing, develop and implement additional measures to control copper discharges.</p>	Within 90 days of exceedance
<p><b>4. Report Status of Copper Control Program</b> Submit a report to the Regional Water Board documenting implementation of the copper control program.</p>	Annually with annual pollution prevention reports due February 28.

## VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in Section IV of this Order will be determined as specified below:

### A. General.

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in Attachment A to the MRP (Attachment E) and Fact Sheet Section VI. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

### B. Multiple Sample Data.

When determining compliance with an AMEL or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of DNQ or ND. In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.

2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

## ATTACHMENT A – DEFINITIONS

**Arithmetic Mean ( $\mu$ )**, also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n$$

where:  $\Sigma x$  is the sum of the measured ambient water concentrations, and  $n$  is the number of samples.

**Average Monthly Effluent Limitation (AMEL)**: the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

**Average Weekly Effluent Limitation (AWEL)**: the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

**Bioaccumulative** pollutants are those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

**Carcinogenic** pollutants are substances that are known to cause cancer in living organisms.

**Coefficient of Variation (CV)** is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

**Daily Discharge**: Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in this Order), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

**Detected, but Not Quantified (DNQ)** are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

**Dilution Credit** is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

**Effluent Concentration Allowance (ECA)** is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

**Enclosed Bays** means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of San Francisco Bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

**Estimated Chemical Concentration** is the estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

**Estuaries** means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters include, but are not limited to, the Sacramento-San Joaquin Delta, as defined in California Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

**Inland Surface Waters** are all surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

**Instantaneous Maximum Effluent Limitation:** the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

**Instantaneous Minimum Effluent Limitation:** the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

**Maximum Daily Effluent Limitation (MDEL)** means the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

**Median** is the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements ( $n$ ) is odd, then the median =  $X_{(n+1)/2}$ . If  $n$  is even, then the median =  $(X_{n/2} + X_{(n/2)+1})/2$  (i.e., the midpoint between the  $n/2$  and  $n/2+1$ ).

**Method Detection Limit (MDL)** is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

**Minimum Level (ML)** is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

**Mixing Zone** is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

**Not Detected (ND)** are those sample results less than the laboratory's MDL.

**Ocean Waters** are the territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

**Persistent** pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

**Pollutant Minimization Program (PMP)** means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to California Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

**Pollution Prevention** means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in California Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Regional Water Board.

**Reporting Level (RL)** is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences.

Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

**Satellite Collection System** is the portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

**Source of Drinking Water** is any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

**Standard Deviation ( $\sigma$ )** is a measure of variability that is calculated as follows:

$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:

- x is the observed value;
- $\mu$  is the arithmetic mean of the observed values; and
- n is the number of samples.

**Toxicity Reduction Evaluation (TRE)** is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)


### ATTACHMENT B – FACILITY MAP





### ATTACHMENT C – PROCESS FLOW DIAGRAM

Treatment Plant Processes



ATTACHMENT 2

**ATTACHMENT D –STANDARD PROVISIONS****I. STANDARD PROVISIONS – PERMIT COMPLIANCE****A. Duty to Comply**

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 C.F.R. § 122.41(a).)
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 C.F.R. § 122.41(a)(1).)

**B. Need to Halt or Reduce Activity Not a Defense**

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 C.F.R. § 122.41(c).)

**C. Duty to Mitigate**

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 C.F.R. § 122.41(d).)

**D. Proper Operation and Maintenance**

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order (40 C.F.R. § 122.41(e)).

**E. Property Rights**

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 C.F.R. § 122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 C.F.R. § 122.5(c).)

## F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 C.F.R. § 122.41(i); Wat. Code, § 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 C.F.R. § 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 C.F.R. § 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 C.F.R. § 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (40 C.F.R. § 122.41(i)(4).)

## G. Bypass

1. Definitions
  - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 C.F.R. § 122.41(m)(1)(i).)
  - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 C.F.R. § 122.41(m)(1)(ii).)
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 C.F.R. § 122.41(m)(2).)
3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 C.F.R. § 122.41(m)(4)(i)):
  - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 C.F.R. § 122.41(m)(4)(i)(A));
  - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment

- should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 C.F.R. § 122.41(m)(4)(i)(B)); and
- c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 C.F.R. § 122.41(m)(4)(i)(C).)
  4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 C.F.R. § 122.41(m)(4)(ii).)
  5. Notice
    - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 C.F.R. § 122.41(m)(3)(i).)
    - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 C.F.R. § 122.41(m)(3)(ii).)

## H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 C.F.R. § 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 C.F.R. § 122.41(n)(2).)
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 C.F.R. § 122.41(n)(3)):
  - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 C.F.R. § 122.41(n)(3)(i));
  - b. The permitted facility was, at the time, being properly operated (40 C.F.R. § 122.41(n)(3)(ii));
  - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 C.F.R. § 122.41(n)(3)(iii)); and

- d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 C.F.R. § 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 C.F.R. § 122.41(n)(4).)

## **II. STANDARD PROVISIONS – PERMIT ACTION**

### **A. General**

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 C.F.R. § 122.41(f).)

### **B. Duty to Reapply**

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 C.F.R. § 122.41(b).)

### **C. Transfers**

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of this Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code. (40 C.F.R. § 122.41(l)(3); § 122.61.)

## **III. STANDARD PROVISIONS – MONITORING**

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 C.F.R. § 122.41(j)(1).)
- B. Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order. (40 C.F.R. § 122.41(j)(4); § 122.44(i)(1)(iv).)

## **IV. STANDARD PROVISIONS – RECORDS**

- A. Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 C.F.R. § 122.41(j)(2).)
- B. Records of monitoring information shall include:
  1. The date, exact place, and time of sampling or measurements (40 C.F.R. § 122.41(j)(3)(i));

2. The individual(s) who performed the sampling or measurements (40 C.F.R. § 122.41(j)(3)(ii));
  3. The date(s) analyses were performed (40 C.F.R. § 122.41(j)(3)(iii));
  4. The individual(s) who performed the analyses (40 C.F.R. § 122.41(j)(3)(iv));
  5. The analytical techniques or methods used (40 C.F.R. § 122.41(j)(3)(v)); and
  6. The results of such analyses. (40 C.F.R. § 122.41(j)(3)(vi).)
- C. Claims of confidentiality for the following information will be denied (40 C.F.R. § 122.7(b)):
1. The name and address of any permit applicant or Discharger (40 C.F.R. § 122.7(b)(1)); and
  2. Permit applications and attachments, permits and effluent data. (40 C.F.R. § 122.7(b)(2).)

## **V. STANDARD PROVISIONS – REPORTING**

### **A. Duty to Provide Information**

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 C.F.R. § 122.41(h); Wat. Code, § 13267.)

### **B. Signatory and Certification Requirements**

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 C.F.R. § 122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 C.F.R. § 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
  - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 C.F.R. § 122.22(b)(1));
  - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant

- manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 C.F.R. § 122.22(b)(2)); and
- c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 C.F.R. § 122.22(b)(3).)
  4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 C.F.R. § 122.22(c).)
  5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:  
  
“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 C.F.R. § 122.22(d).)

### **C. Monitoring Reports**

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 C.F.R. § 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 C.F.R. § 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board. (40 C.F.R. § 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 C.F.R. § 122.41(l)(4)(iii).)

## **D. Compliance Schedules**

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 C.F.R. § 122.41(l)(5).)

## **E. Twenty-Four Hour Reporting**

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 C.F.R. § 122.41(l)(6)(i).)
2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 C.F.R. § 122.41(l)(6)(ii)):
  - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(A).)
  - b. Any upset that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 C.F.R. § 122.41(l)(6)(iii).)

## **F. Planned Changes**

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 C.F.R. § 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 C.F.R. § 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 C.F.R. § 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application



process or not reported pursuant to an approved land application plan. (40 C.F.R. § 122.41(l)(1)(iii).)

#### **G. Anticipated Noncompliance**

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements. (40 C.F.R. § 122.41(l)(2).)

#### **H. Other Noncompliance**

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 C.F.R. § 122.41(l)(7).)

#### **I. Other Information**

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 C.F.R. § 122.41(l)(8).)

### **VI. STANDARD PROVISIONS – ENFORCEMENT**

- A. The Regional Water Board is authorized to enforce the terms of this Order under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.

### **VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS**

#### **A. Publicly-Owned Treatment Works (POTWs)**

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 C.F.R. § 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 C.F.R. § 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of this Order. (40 C.F.R. § 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 C.F.R. § 122.42(b)(3).)

**ATTACHMENT E – MONITORING AND REPORTING PROGRAM**

**Table of Contents**

I. General Monitoring Provisions ..... E-2

II. Monitoring Locations ..... E-3

III. Influent Monitoring Requirements ..... E-3

IV. Effluent Monitoring Requirements ..... E-4

V. Whole Effluent Toxicity Testing Requirements ..... E-5

VI. Land Discharge Monitoring Requirements ..... E-8

VII. Reclamation Monitoring Requirements ..... E-8

VIII. Receiving water Monitoring Requirements ..... E-8

IX. Legend for MRP Tables ..... E-8

X. Other Monitoring Requirements ..... E-9

XI. Reporting Requirements ..... E-10

    A. General Monitoring and Reporting Requirements ..... E-10

    B. Modifications to Part A of Self-Monitoring Program (Attachment G) ..... E-10

    C. Self Monitoring Reports ..... E-13

    D. Discharge Monitoring Reports ..... E-15

    E. Other Reports ..... E-16

**Tables**

Table E-1. Test Methods and Minimum Levels for Pollutants with Reasonable Potential ..... E-3

Table E-2. Monitoring Station Locations ..... E-3

Table E-3. Influent Monitoring ..... E-3

Table E-4. Effluent Monitoring ..... E-4

Table E-5. Pretreatment Monitoring Requirements ..... E-9

Table E-6. Monitoring Periods and Reporting Schedule ..... E-14

## ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

National Pollutant Discharge Elimination System (NPDES) regulations at 40 CFR 122.48 require that all NPDES permits specify monitoring and reporting requirements. California Water Code (CWC) sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements, which implement the federal and State regulations.

### I. GENERAL MONITORING PROVISIONS

- A. The Discharger shall comply with the MRP for this Order as adopted by the Regional Water Board, and with all of the Self-Monitoring Program (SMP), Part A, adopted August 1993. The MRP and SMP may be amended by the Executive Officer pursuant to United States Environmental Protection Agency (USEPA) regulations 40 CFR 122.62, 122.63, and 124.5. If any discrepancies exist between the MRP and SMP, the MRP prevails.
- B. Sampling is required during the entire year when discharging. All analyses shall be conducted using current USEPA methods, or methods that have been approved by the USEPA Regional Administrator pursuant to 40 CFR 136.4 and 40 CFR 136.5, or equivalent methods that are commercially and reasonably available and that provide quantification of sampling parameters and constituents sufficient to evaluate compliance with applicable effluent limits and to perform reasonable potential analysis. Equivalent methods must be more sensitive than those specified in 40 CFR 136, must be specified in the permit, and must be approved for use by the Executive Officer, following consultation with the State Water Quality Control Board (State Water Board) Quality Assurance Program.
- C. Sampling and analysis of additional constituents is required pursuant to Table 1 of the Regional Water Board's August 6, 2001, Letter entitled *Requirement for Monitoring of Pollutants in Effluent and Receiving Water to Implement New Statewide Regulations and Policy* (Attachment G).
- D. *Minimum Levels.* For compliance and reasonable potential monitoring, analyses shall be conducted using the commercially available and reasonably achievable detection levels that are lower than the effluent limitations. The objective is to provide quantification of constituents sufficient to allow evaluation of observed concentrations with respect to the Minimum Levels (MLs) given below.

MLs are the concentrations at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed. All MLs are expressed as micrograms per liter ( $\mu\text{g/L}$ ).

Table E-1 lists the test methods the Discharger may use for compliance and reasonable potential monitoring for the pollutants with effluent limits.

**Table E-1. Test Methods and Minimum Levels for Pollutants with Reasonable Potential**

CTR #	Constituent	Types of Analytical Methods <sup>[a]</sup>											
		Minimum Levels (µg/L)											
		GC	GCMS	LC	Color	FAA	GFAA	ICP	ICPMS	SPGFAA	HYDRIDE	CVAF	DCP
6	Copper					25	5	10	0.5	2			
14	Cyanide				5								
16-TEQ	Dioxin-TEQ <sup>[b]</sup>												

- <sup>[a]</sup> Analytical Methods / Laboratory techniques are defined as follows:  
 Color = Colorimetric;  
 CVAF = Cold Vapor Atomic Fluorescence.  
 DCP = Direct Current Plasma  
 FAA = Furnace Atomic Absorption;  
 GC = Gas Chromatography  
 GCMS = Gas Chromatography Mass Spectroscopy  
 GFAA = Graphite Furnace Atomic Absorption;  
 ICP = Inductively Coupled Plasma  
 ICPMS = Inductively Coupled Plasma/Mass Spectrometry;  
 LC = Liquid Chromatography  
 SPGFAA = Stabilized Platform Graphite Furnace Atomic Absorption (i.e. USEPA 200.9)

<sup>[b]</sup> Use USEPA Method 1613

**II. MONITORING LOCATIONS**

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order.

**Table E-2. Monitoring Station Locations**

Type of Sampling Location	Monitoring Location Name	Monitoring Location Description
Influent	A-001	At any point in the Millbrae WPCP upstream of the primary sedimentation basins at which all waste tributary to the treatment system is present, and preceding any phase of treatment.
Effluent	E-001	At any point after full treatment and before discharge into the North Bayside System Unit (NBSU) joint force main.
Effluent	E-002	The combined NBSU discharge, after dechlorination and preceding discharge into Lower San Francisco Bay via the NBSU joint force main.

**III. INFLUENT MONITORING REQUIREMENTS**

A. The Discharger shall monitor influent to the Millbrae WPCP at A-001 as follows.

**Table E-3. Influent Monitoring**

Parameter	Units	Minimum Sampling Frequency	Required Analytical Test Method
		C-24 <sup>(1)</sup>	
Carbonaceous Biological Oxygen Demand (CBOD)	milligrams per liter (mg/L)	3/W	(2)
Total Suspended Solids (TSS)	mg/L	3/W	(2)

- (1) Composite samples of influent shall be collected on varying days selected at random and shall not include any plant recirculation or other side stream waste. Deviation from this requirement must be approved by the Executive Officer.
- (2) Pollutants shall be analyzed using the analytical methods described in 40 CFR 136.

**IV. EFFLUENT MONITORING REQUIREMENTS**

A. The Discharger shall monitor treated effluent from the Millbrae WPCP at E-001 as follows (or at E-002 as noted):

**Table E-4. Effluent Monitoring**

Parameter	Units	Minimum Sampling Frequency			Required Analytical Test Method
		Continuous	C-24	G	
Flow Rate <sup>(2)</sup>	MGD	Cont/D			(1)
Oil and Grease <sup>(3)</sup>	mg/L			M	(1)
pH <sup>(4)</sup>	s.u.			3/W	(1)
CBOD <sub>5</sub> <sup>(5)</sup>	mg/L		3/W		(1)
TSS <sup>(5)</sup>	mg/L		3/W		(1)
Acute Toxicity <sup>(6)</sup>	% survival		M		(1)
Chlorine, Total Residual <sup>(7)</sup>	mg/L	Cont or 1/2h			(1)
Chronic Toxicity <sup>(8)</sup>	TUc		1/Y		(1)
Dissolved Oxygen	mg/L			3/W	(1)
Fecal Coliform Bacteria	MPN/100mL			2/W	(1)
Enterococcus Bacteria <sup>(12)</sup>	MPN/100mL			M	(1)
Temperature	°C			3/W	(1)
Ammonia (total as N)	mg/L			M	(1)
Copper	µg/L		M		(1)
Cyanide	µg/L			M	(1)(11)
Dioxin-TEQ	µg/L			2/Y	(1)
Remaining Priority Pollutants	µg/L		2/Y <sup>(9)(10)</sup>		(1)

Units:

- MG = million gallons
- MGD = million gallons per day
- s.u. = standard units
- TUc = Chronic Toxicity Units
- MPN/100mL = Most Probable Number per 100 milliliters
- °C = degrees Celsius
- µg/L = micrograms per liter
- mg/L = milligrams per liter
- kg/d = kilograms per day

(1) Pollutants and pollutant parameters shall be analyzed using the analytical methods described in 40 CFR 136. For priority pollutants, the methods must meet the lowest MLs specified in Attachment 4 of the SIP. Where no methods are specified for a given pollutant, the methods must be approved by this Regional Water Board or the State Board.

(2) Flow Monitoring:

For effluent flows, the following information shall also be reported monthly:

- Daily: Total Daily Flow Volume (MG)
- Monthly: Monthly Average Flow (MGD)
- Monthly: Maximum Daily Flow (MGD)
- Monthly: Minimum Daily Flow (MGD)
- Monthly: Total Flow Volume (MG)

- (3) Each oil and grease sampling event shall consist of three grab samples taken at equal intervals during the sampling date, with each grab sample being collected in a glass container. The grab samples shall be analyzed separately with the result of each analysis weighted by instantaneous flow rates to calculate a composite sample result. Each glass container used for sample collection or mixing shall be thoroughly rinsed with solvent rinsings as soon as possible after use, and the solvent rinsings shall be added to the respective grab sample for extraction and analysis.
- (4) If pH is monitored continuously; the minimum and maximum pH values for each day shall be reported in monthly Self-Monitoring Reports (SMRs).
- (5) The percent removal for CBOD and TSS shall be reported for each calendar month. Samples for CBOD and TSS shall be collected simultaneously with influent samples.
- (6) Acute bioassay tests shall be performed in accordance with Section V.A of this MRP.
- (7) During all times when chlorination is used for effluent disinfection, effluent chlorine residual concentrations shall be monitored continuously, or by grab samples taken once every 2 hours. Chlorine residual concentrations shall be monitored and reported for sampling points both prior to and following dechlorination. Total chlorine dosage (kg/d) shall be recorded on a daily basis. Chlorine residual compliance may be demonstrated by monitoring at the NBSU common outfall (E-002).
- (8) Critical Life Stage Toxicity Test shall be performed and reported in accordance with the Chronic Toxicity Requirements specified in Section V.B of this MRP.
- (9) Sampling for all priority pollutants in the State Implementation Plan (SIP) is addressed in a Regional Water Board letter dated August 6, 2001, entitled *Requirements for Monitoring of Pollutants in Effluent and Receiving Water to Implement New Statewide Regulations and Policy* (not attached but available for review or download on the Regional Water Board's website at <http://www.waterboards.ca.gov/sanfranciscobay/>).
- (10) For the same pollutants the sampling frequencies shall be the higher ones under this table or under the pretreatment program sampling required in Section X.A of this MRP. Pretreatment program monitoring can be used to satisfy part of these sampling requirements.
- (11) The Discharger may move the cyanide monitoring and compliance point to E-002 (post-dechlorination) if the Discharger notifies the Regional Water Board of its intent by letter to the Executive Officer prior to the monitoring change.
- (12) The Discharger shall monitor for Enterococci using EPA-approved methods, including the IDEXX Enterolert method.

## V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

The Discharger shall monitor acute and chronic toxicity at E-001 as follows.

### A. Whole Effluent Acute Toxicity

1. Compliance with the acute toxicity effluent limitations of this Order shall be evaluated by measuring survival of test organisms exposed to 96-hour continuous flow-through bioassays.
2. Test organisms shall be fathead minnow unless specified otherwise in writing by the Executive Officer.
3. All bioassays shall be performed according to the most up-to-date protocols in 40 CFR 136, currently in *Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms*, 5<sup>th</sup> Edition.
4. If specific identifiable substances in the discharge can be demonstrated by the Discharger as being rapidly rendered harmless upon discharge to the receiving water, compliance with the acute toxicity limit may be determined after the test samples are adjusted to remove the influence of those substances. Written approval from the Executive Officer must be obtained to authorize such an adjustment.
5. Effluent used for fish bioassays must be dechlorinated prior to testing. Monitoring of the bioassay water shall include, on a daily basis, the following parameters: pH, dissolved oxygen, ammonia (if toxicity is observed), temperature, hardness, and alkalinity. These results shall be recorded and maintained with all other analytical documents. If a violation of

acute toxicity requirements occurs or if the control fish survival rate is less than 90 percent, the bioassay test shall be restarted with new batches of fish. Bioassay tests shall continue back to back until compliance is demonstrated.

## B. Whole Effluent Chronic Toxicity

### 1. Chronic Toxicity Monitoring Requirements

- a. *Sampling*. The Discharger shall collect 24-hour composite samples of the effluent at the compliance point specified in Table E-4 above for critical life stage toxicity testing. For toxicity tests requiring renewals, 24-hour composite samples collected on consecutive days are required.
- b. *Test Species*. The test species shall be *Mysidopsis bahia*. The Executive Officer may change to another test species if data suggest that another test species is more sensitive to the discharge.
- c. *Methodology*. Sample collection, handling and preservation shall be in accordance with USEPA protocols. In addition, bioassays shall be conducted in compliance with the most recently promulgated test methods, as shown in **Appendix E-1**. These are *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, currently third edition (EPA-821-R-02-014), and *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, currently fourth Edition (EPA-821-R-02-013), with exceptions granted the Discharger by the Executive Officer and the Environmental Laboratory Accreditation Program (ELAP).
- d. *Dilution Series*. The Discharger shall conduct tests at 2%, 5%, 10%, 20%, and 40%. The "%" represents percent effluent as discharged. The Discharger may use a buffer only after obtaining written approval from the Executive Officer.

### 2. Chronic Toxicity Reporting Requirements

- a. *Routine Reporting*. Toxicity test results for the current reporting period shall include, at a minimum, for each test:
  - (1) Sample date(s)
  - (2) Test initiation date
  - (3) Test species
  - (4) End point values for each dilution (e.g., number of young, growth rate, percent survival)
  - (5) No Observed Effect Concentration (NOEC) value(s) in percent effluent
  - (6) Inhibition Concentration (IC) values at IC<sub>15</sub>, IC<sub>25</sub>, IC<sub>40</sub>, and IC<sub>50</sub> (or Effective Concentration (EC) values at EC<sub>15</sub>, EC<sub>25</sub> ... etc.) as percent effluent

- (7) Chronic Toxicity Units (TUC) values (100/NOEC, 100/IC<sub>25</sub>, or 100/EC<sub>25</sub>)
  - (8) Mean percent mortality ( $\pm$ s.d.) after 96 hours in 100% effluent (if applicable)
  - (9) NOEC and Lowest Observed Effect Concentration (LOEC) values for reference toxicant test(s)
  - (10) IC<sub>50</sub> or EC<sub>50</sub> value(s) for reference toxicant test(s)
  - (11) Available water quality measurements for each test (pH, dissolved oxygen [DO], temperature, conductivity, hardness, salinity, ammonia)
- b. *Compliance Summary.* The results of the chronic toxicity testing shall be provided in the Self-Monitoring Report (SMR) and shall include a summary table of chronic toxicity data from at least eleven of the most recent samples. The information in the table shall include items listed above under 2.a, specifically item numbers (1), (3), (5), (6) (IC<sub>25</sub> or EC<sub>25</sub>), (7), and (8).
3. Chronic Toxicity Reduction Evaluation (TRE)
- a. *Prepare Generic TRE Work Plan.* To be ready to respond to toxicity events, the Discharger shall prepare a generic TRE work plan within 90 days of the effective date of this Order. The Discharger shall review and update the work plan as necessary to remain current and applicable to the discharge and discharge facilities.
  - b. *Submit Specific TRE Work Plan.* Within 30 days of exceeding the trigger for accelerated monitoring, the Discharger shall submit to the Regional Water Board a TRE work plan, which should be the generic work plan revised as appropriate for this toxicity event after consideration of available discharge data.
  - c. *Initiate TRE.* Within 30 days of the date of completion of the accelerated monitoring tests observed to exceed either trigger, the Discharger shall initiate a TRE in accordance with a TRE work plan that incorporates any and all comments from the Executive Officer.
  - d. The TRE shall be specific to the discharge and be prepared in accordance with current technical guidance and reference materials, including USEPA guidance materials. The TRE shall be conducted as a tiered evaluation process, such as summarized below:
    - i. Tier 1 consists of basic data collection (routine and accelerated monitoring).
    - ii. Tier 2 consists of evaluation of optimization of the treatment process, including operation practices and in-plant process chemicals.
    - iii. Tier 3 consists of a toxicity identification evaluation (TIE).
    - iv. Tier 4 consists of evaluation of options for additional effluent treatment processes.
    - v. Tier 5 consists of evaluation of options for modifications of in-plant treatment processes.



- vi. Tier 6 consists of implementation of selected toxicity control measures, and follow-up monitoring and confirmation of implementation success.
- e. The TRE may be ended at any stage if monitoring finds there is no longer consistent toxicity (complying with requirements of Section IV.A.4 of this Order).
- f. The objective of the TIE shall be to identify the substance or combination of substances causing the observed toxicity. All reasonable efforts using currently available TIE methodologies shall be employed.
- g. As toxic substances are identified or characterized, the Discharger shall continue the TRE by determining the source(s) and evaluating alternative strategies for reducing or eliminating the substances from the discharge. All reasonable steps shall be taken to reduce toxicity to levels consistent with chronic toxicity evaluation parameters.
- h. Many recommended TRE elements parallel required or recommended efforts of source control, pollution prevention and storm water control programs. TRE efforts should be coordinated with such efforts. To prevent duplication of efforts, evidence of complying with requirements or recommended efforts of such programs may be acceptable to comply with TRE requirements.
- i. The Regional Water Board recognizes that chronic toxicity may be episodic and identification of causes of and reduction of sources of chronic toxicity may not be successful in all cases. Consideration of enforcement action by the Regional Water Board will be based in part on the Discharger's actions and efforts to identify and control or reduce sources of consistent toxicity.

## **VI. LAND DISCHARGE MONITORING REQUIREMENTS**

Not applicable.

## **VII. RECLAMATION MONITORING REQUIREMENTS**

Not Applicable.

## **VIII. RECEIVING WATER MONITORING REQUIREMENTS**

The Discharger shall continue to participate in the Regional Monitoring Program (RMP), which involves collection of data on pollutants and toxicity in water, sediment and biota of the Estuary. The Discharger's participation and support of the RMP is used in consideration of the level of receiving water monitoring required by this Order.

## **IX. LEGEND FOR MRP TABLES**

### Types of Samples

- C-24 = composite sample, 24 hours (includes continuous sampling, such as for flows)
- C-X = composite sample, X hours
- G = grab sample

Frequency of Sampling

Cont.	=	Continuous
Cont/D	=	Continuous monitoring & daily reporting
H	=	Once each hour (at about hourly intervals)
2H	=	once every 2 hours
W	=	Once each week
2/W	=	Twice each week
4/W	=	Four times each week
M	=	Once each month
Q	=	Once each calendar quarter (at about three month intervals)
1/Y	=	Once each calendar year
2/Y	=	Twice each calendar year (at about 6 months intervals, once during dry season, once during wet season)

Parameter and Unit Abbreviations

BNA	=	Base, Neutral, Acid-extractable compounds
CBOD	=	Carbonaceous Biochemical Oxygen Demand
TUc	=	Chronic Toxicity Units
°C	=	Degrees Celsius
DO	=	Dissolved Oxygen
kg/d	=	Kilograms per day
kg/mo	=	Kilograms per month
µg/L	=	Micrograms per liter
mg/L	=	Milligrams per liter
MG	=	Million Gallons
MGD	=	Million Gallons per Day
MPN/100 mL	=	Most Probable Number per 100 milliliters
Metals	=	Multiple metals; See SMP Section VI.G.
% survival	=	Percent survival
s.u.	=	Standard units
TSS	=	Total Suspended Solids
VOC	=	Volatile Organic Compounds

**X. OTHER MONITORING REQUIREMENTS****A. Pretreatment Requirements**

The Discharger shall comply with the pretreatment requirements specified in Table E-5 for influent (A-001), effluent (E-001), and biosolids.

**Table E-5. Pretreatment Monitoring Requirements** <sup>(1)</sup>

Constituents/EPA Method	Influent (A-001)	Effluent (E-001)	Biosolids
VOCs / 624 <sup>(2)</sup>	2/Y	2/Y	
BNA / 625 <sup>(3)</sup>	2/Y	2/Y	
Metals <sup>(4)</sup>	M	M	
Organophosphorus Pesticides	2/Y	2/Y	
Carbamate and Urea Pesticides	2/Y	2/Y	

Biosolids <sup>(5)</sup>			2/Y
--------------------------	--	--	-----

- (1) Influent and effluent monitoring conducted in accordance with Tables E-3 and E-4 can be used to satisfy these pretreatment monitoring requirements.
- (2) Volatile organic compounds.
- (3) Base neutral, acid extractable compounds.
- (4) Same USEPA method used to determine compliance with the respective NPDES permit. Analyses for metals shall include arsenic, cadmium, chromium, copper, lead, nickel, silver, zinc, selenium and cyanide.
- (5) USEPA approved methods.

## B. Biosolids Monitoring

The Discharger shall adhere to sludge monitoring requirements required by 40 CFR 503.

## XI. REPORTING REQUIREMENTS

### A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.

### B. Modifications to Part A of Self-Monitoring Program (Attachment G)

1. If any discrepancies exist between SMP Part A, August 1993 (Attachment G) and this MRP, this MRP prevails.
2. Sections C.3 and C.5 are satisfied by participation in the Regional Monitoring Program.
3. Amend Section E as Follows:

#### ***Records to be Maintained***

*Written reports, electronic records, strip charts, equipment calibration and maintenance records, and other records pertinent to demonstrating compliance with waste discharge requirements, including monitoring and reporting requirements, shall be maintained by the Discharger in a manner and at a location (e.g., wastewater treatment plant or Discharger offices) such that the records are accessible to Regional Water Board staff. These records shall be retained by the Discharger for a minimum of 3 years. This minimum period of retention shall be extended during the course of any unresolved litigation regarding the subject discharge, or when requested by the Regional Water Board or Regional Administrator of the U.S. EPA, Region IX.*

*Records to be maintained shall include the following:*

#### ***1. Parameter Sampling and Analyses, and Observations***

*For each sample, analysis, or observation conducted, records shall include the following:*

*a. Parameter.*

*b. Identity of sampling and observation stations, consistent with the station descriptions given in the MPR (Attachment E).*

- c. Date and time of sampling and/or observations.*
  - d. Method of sampling (e.g., grab, composite, or other method).*
  - e. Date and time analyses are started and completed, and name of personnel or contract laboratory performing the analyses.*
  - f. Reference or description of procedure(s) and analytical method(s) used.*
  - g. Analytical method detection limits and related quantification parameters.*
  - h. Results of the analyses and/or observations.*
- 2. Flow Monitoring Data**  
*For all required flow monitoring (e.g., influent and effluent flows), records shall include the following:*
- a. Total flow or volume, for each day.*
  - b. Maximum, minimum, and average daily flows for each calendar month.*
- 3. Wastewater Treatment Process Solids**
- a. For each treatment unit process that involves solids removal from the wastewater stream, records shall include the following:*
    - 1) Total volume and/or mass quantification of solids removed from each unit (e.g., grit, skimmings, undigested biosolids) for each calendar month.*
    - 2) Final disposition of such solids (e.g., landfill, other subsequent treatment unit).*
  - b. For final dewatered biosolids from the treatment plant as a whole, records shall include the following:*
    - 1) Total volume and/or mass quantification of dewatered biosolids for each calendar month.*
    - 2) Solids content of the dewatered biosolids.*
    - 3) Final disposition of dewatered biosolids (point of disposal location and disposal method).*
- 4. Disinfection Process**  
*For the disinfection process, records shall be maintained documenting process operation and performance, including the following:*

*For bacteriological analyses:*

- 1) *Date and time of each sample collected.*
- 2) *Wastewater flow rate at the time of sample collection.*
- 3) *Results of sample analyses (e.g., bacterial count).*
- 4) *Required statistical parameters for cumulative bacterial values (e.g., moving median or geometric mean for the number of samples or sampling period identified in waste discharge requirements).*

**5. Treatment Process Bypasses**

*A chronological log of all treatment process bypasses, including wet weather blending, shall include the following:*

- a. *Identification of the treatment process bypassed.*
- b. *Date(s) and times of bypass beginning and end.*
- c. *Total bypass duration.*
- d. *Estimated total volume.*
- e. *Description of, or reference to other report(s) describing, the bypass event, the cause, corrective actions taken, and any additional monitoring conducted.*

**6. Modify Section F.4 as follows:**

***Self-Monitoring Reports***

*For each calendar month, a self-monitoring report (SMR) shall be submitted to the Regional Water Board in accordance with the requirements listed in Self-Monitoring Program, Part A. The purpose of the report is to document treatment performance, effluent quality and compliance with waste discharge requirements prescribed by this Order, as demonstrated by the monitoring program data and the Discharger's operation practices.*

[And add at the end of Section F.4 the following:]

- g. *If the Discharger wishes to invalidate any measurement, the letter of transmittal will include identification of the measurement suspected to be invalid and notification of intent to submit, within 60 days, a formal request to invalidate the measurement, the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports the invalidation (e.g., laboratory sheet, log entry, test results, etc.), and discussion of the corrective actions taken or planned (with a time schedule for completion), to prevent recurrence of the sampling or measurement problem.*

#### *h. Reporting Data in Electronic Format*

*The Discharger has the option to submit all monitoring results in an electronic reporting format approved by the Executive Officer. If the Discharger chooses to submit SMRs electronically, the following shall apply:*

- 1) Reporting Method: The Discharger shall submit SMRs electronically via the process approved by the Executive Officer in a letter dated December 17, 1999, Official Implementation of Electronic Reporting System (ERS) and in the Progress Report letter dated December 17, 2000, or in a subsequently approved format that the Permit has been modified to include.*
- 2) Monthly or Quarterly Reporting Requirements: For each reporting period (monthly or quarterly as specified in SMP Part B), an electronic SMR shall be submitted to the Regional Water Board in accordance with Section F.4.a-g. above. However, until U.S. EPA approves the electronic signature or other signature technologies, Dischargers that are using the ERS must submit a hard copy of the original transmittal letter, an ERS printout of the data sheet, a violation report, and a receipt of the electronic transmittal.*
- 3) Annual Reporting Requirements: Dischargers who have submitted data using the ERS for at least one calendar year are exempt from submitting an annual report electronically, but a hard copy of the annual report per Sections F.5.b, F.5.c, and F.5.d below shall be submitted.*

#### 7. Add at the end of Section F.5, Annual Reporting, the following:

*d. A plan view drawing or map showing the Discharger's facility, flow routing and sampling and observation station locations.*

### **C. Self Monitoring Reports**

1. At any time during the term of this Order, the State or Regional Water Board may notify the Discharger to electronically submit SMRs using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). Until such notification is given, the Discharger shall submit hard copy SMRs. The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.
2. The Discharger shall submit monthly and annual SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order for each calendar month. If the Discharger monitors any pollutant more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR. Monthly SMRs shall be due on the 30th day following the end of each calendar month, covering samples collected during that calendar month; Annual Reports shall be due on February 1 following each calendar year.

3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

**Table E-6. Monitoring Periods and Reporting Schedule**

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period
Continuous	Day after permit effective date	All
Hourly	Day after permit effective date	Hourly
Daily	Day after permit effective date	Midnight through 11:59 PM or any 24-hour period that reasonably represents a calendar day for purposes of sampling.
Weekly	Sunday following permit effective date or on permit effective date if on a Sunday	Sunday through Saturday
Monthly	First day of calendar month following permit effective date or on permit effective date if that date is first day of the month	1 <sup>st</sup> day of calendar month through last day of calendar month
Quarterly	Closest of January 1, April 1, July 1, or October 1 following (or on) permit effective date	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31
Semiannually	Closest of January 1 or July 1 following (or on) permit effective date	January 1 through June 30 July 1 through December 31
Annually	January 1 following (or on) permit effective date	January 1 through December 31
Per Discharge Event	Anytime during the discharge event or as soon as possible after aware of the event	At a time when sampling can characterize the discharge event

4. Reporting Protocols. The Discharger shall report with each sample result the applicable Reporting Level (RL) and the current Method Detection Limit (MDL), as determined by the procedure in 40 CFR 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc."). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy ( $\pm$  a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
  - d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from *extrapolation* beyond the lowest point of the calibration curve.
5. The Discharger shall submit SMRs in accordance with the following requirements:
- a. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the Millbrae WPCP is operating in compliance with interim and/or final effluent limitations. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Discharger shall electronically submit the data in a tabular format as an attachment.
  - b. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify violations of the WDRs; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation.
  - c. SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D), to the address listed below:

Executive Officer  
California Regional Water Quality Control Board  
San Francisco Bay Region  
1515 Clay Street, Suite 1400  
Oakland, CA 94612  
ATTN: NPDES Permit

#### **D. Discharge Monitoring Reports**

1. As described in Section X.B.1 above, at any time during the term of this Order, the State or Regional Water Board may notify the Discharger to electronically submit SMRs that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.
2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharge shall submit the original DMR and one copy of the DMR to one of the addresses listed below:



<b>Standard Mail</b>	<b>FedEx/UPS/Other Private Carriers</b>
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 <sup>th</sup> Floor Sacramento, CA 95814

- All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated will not be accepted unless they follow the exact same format of EPA Form 3320-1.

**E. Other Reports**

The Discharger shall report the results of any special studies, monitoring, and reporting required by Section VI.C.2 (Special Studies, Technical Reports, and Additional Monitoring Requirements) of this Order with the first monthly SMR following the respective due date. The Discharger shall include a report of progress towards meeting compliance schedules established by section VI.C.2 of this Order in the annual SMR.

**APPENDIX E-1**  
**CHRONIC TOXICITY**  
**DEFINITION OF TERMS AND SCREENING PHASE REQUIREMENTS**

**I. Definition of Terms**

- A. No observed effect level (NOEL) for compliance determination is equal to IC<sub>25</sub> or EC<sub>25</sub>. If the IC<sub>25</sub> or EC<sub>25</sub> cannot be statistically determined, the NOEL shall be equal to the NOEC derived using hypothesis testing.
- B. Effective concentration (EC) is a point estimate of the toxicant concentration that would cause an adverse effect on a quantal, "all or nothing," response (such as death, immobilization, or serious incapacitation) in a given percent of the test organisms. If the effect is death or immobility, the term lethal concentration (LC) may be used. EC values may be calculated using point estimation techniques such as probit, logit, and Spearman-Kärber. EC<sub>25</sub> is the concentration of toxicant (in percent effluent) that causes a response in 25 percent of the test organisms.
- C. Inhibition concentration (IC) is a point estimate of the toxicant concentration that would cause a given percent reduction in a nonlethal, nonquantal biological measurement, such as growth. For example, an IC<sub>25</sub> is the estimated concentration of toxicant that would cause a 25 percent reduction in average young per female or growth. IC values may be calculated using a linear interpolation method such as USEPA's Bootstrap Procedure.
- D. No observed effect concentration (NOEC) is the highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specific time of observation. It is determined using hypothesis testing.

**II. Chronic Toxicity Screening Phase Requirements**

- A. The Discharger shall perform screening phase monitoring:
  - 1. Subsequent to any significant change in the nature of the effluent discharged through changes in sources or treatment, except those changes resulting from reductions in pollutant concentrations attributable to source control efforts, or
  - 2. Prior to permit reissuance. Screening phase monitoring data shall be included in the NPDES permit application for reissuance. The information shall be as recent as possible, but may be based on screening phase monitoring conducted within 5 years before the permit expiration date.
- B. Design of the screening phase shall, at a minimum, consist of the following elements:
  - 1. Use of test species specified in **Appendix E-2**, attached, and use of the protocols referenced in those tables.
  - 2. Two stages:

- a. Stage 1 shall consist of a minimum of one battery of tests conducted concurrently. Selection of the type of test species and minimum number of tests shall be based on **Appendix E-2** (attached).
  - b. Stage 2 shall consist of a minimum of two test batteries conducted at a monthly frequency using the three most sensitive species based on the Stage 1 test results.
3. Appropriate controls.
  4. Concurrent reference toxicant tests.
  5. Dilution series of 2%, 5%, 10%, 20%, and 40%, where “%” is percent effluent as discharged.
- C. The Discharger shall submit a screening phase proposal acceptable to the Executive Officer. The proposal shall address each of the elements listed above. If within 30 days, the Executive Officer does not comment, the Discharge shall commence with screening phase monitoring.

## APPENDIX E-2 SUMMARY OF TOXICITY TEST SPECIES REQUIREMENTS

### Critical Life Stage Toxicity Tests for Estuarine Waters

Species	(Scientific Name)	Effect	Test Duration	Reference
Alga	<i>(Skeletonema costatum)</i> <i>(Thalassiosira pseudonana)</i>	Growth rate	4 days	1
Red alga	<i>(Champia parvula)</i>	Number of cystocarps	7–9 days	3
Giant kelp	<i>(Macrocystis pyrifera)</i>	Percent germination; germ tube length	48 hours	2
Abalone	<i>(Haliotis rufescens)</i>	Abnormal shell development	48 hours	2
Oyster Mussel	<i>(Crassostrea gigas)</i> <i>(Mytilus edulis)</i>	Abnormal shell development; percent survival	48 hours	2
Echinoderms - Urchins Sand dollar	<i>(Strongylocentrotus purpuratus,</i> <i>S. franciscanus)</i> <i>(Dendraster excentricus)</i>	Percent fertilization	1 hour	2
Shrimp	<i>(Mysidopsis bahia)</i>	Percent survival; growth	7 days	3
Shrimp	<i>(Holmesimysis costata)</i>	Percent survival; growth	7 days	2
Topsmelt	<i>(Atherinops affinis)</i>	Percent survival; growth	7 days	2
Silversides	<i>(Menidia beryllina)</i>	Larval growth rate; percent survival	7 days	3

#### Toxicity Test References:

1. American Society for Testing Materials (ASTM). 1990. Standard Guide for Conducting Static 96-Hour Toxicity Tests with Microalgae. Procedure E 1218-90. ASTM, Philadelphia, PA.
2. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to West Coast Marine and Estuarine Organisms. EPA/600/R-95/136. August 1995.
3. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to Marine and Estuarine Organisms. EPA/600/4-90/003. July 1994.

### Critical Life Stage Toxicity Tests for Fresh Waters

Species	(Scientific Name)	Effect	Test Duration	Reference
Fathead minnow	<i>(Pimephales promelas)</i>	Survival; growth rate	7 days	4
Water flea	<i>(Ceriodaphnia dubia)</i>	Survival; number of young	7 days	4
Alga	<i>(Selenastrum capricornutum)</i>	Cell division rate	4 days	4

#### Toxicity Test Reference:

4. Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, third edition. EPA/600/4-91/002. July 1994.

**Toxicity Test Requirements for Stage One Screening Phase**

Requirements	Receiving Water Characteristics		
	Discharges to Coast	Discharges to San Francisco Bay <sup>[2]</sup>	
	Ocean	Marine/Estuarine	Freshwater
Taxonomic diversity	1 plant 1 invertebrate 1 fish	1 plant 1 invertebrate 1 fish	1 plant 1 invertebrate 1 fish
Number of tests of each salinity type: Freshwater <sup>[1]</sup> Marine/Estuarine	0	1 or 2	3
	4	3 or 4	0
Total number of tests	4	5	3

[1] The freshwater species may be substituted with marine species if:

- (a) The salinity of the effluent is above 1 part per thousand (ppt) greater than 95 percent of the time, or
- (b) The ionic strength (TDS or conductivity) of the effluent at the test concentration used to determine compliance is documented to be toxic to the test species.

[2] (a) Marine/Estuarine refers to receiving water salinities greater than 1 ppt at least 95 percent of the time during a normal water year.  
 (b) Fresh refers to receiving water with salinities less than 1 ppt at least 95 percent of the time during a normal water year.

**ATTACHMENT F: FACT SHEET****Table of Contents**

I.	Permit Information .....	F-3
II.	Facility Description .....	F-4
	A. Description of Wastewater Treatment.....	F-4
	B. Discharge Points and Receiving Waters .....	F-5
	C. Summary of Existing Requirements and Self-Monitoring Report Data .....	F-5
	D. Compliance Summary .....	F-6
	E. Planned Changes .....	F-7
III.	Applicable Plans, Policies, and Regulations .....	F-7
	A. Legal Authorities.....	F-7
	B. California Environmental Quality Act (CEQA).....	F-7
	C. State and Federal Regulations, Policies, and Plans .....	F-7
	D. Impaired Water Bodies on CWA 303(d) List .....	F-10
IV.	Rationale For Effluent Limitations and Discharge Specifications.....	F-11
	A. Discharge Prohibitions .....	F-11
	B. Technology-Based Effluent Limitations .....	F-12
	1. Scope and Authority.....	F-12
	2. Applicable Technology-Based Effluent Limitations.....	F-12
	3. Bacteria.....	F-13
	C. Water Quality-Based Effluent Limitations.....	F-14
	1. Scope and Authority.....	F-14
	2. Applicable Beneficial Uses and Water Quality Criteria and Objectives.....	F-14
	3. Determining the Need for WQBELs .....	F-16
	4. WQBEL Calculations.....	F-22
	5. Whole Effluent Acute Toxicity .....	F-31
	D. Interim Effluent Limitations.....	F-33
	E. Land Discharge Specifications.....	F-34
	F. Reclamation Specifications .....	F-34
V.	Rationale for Receiving Water Limitations.....	F-35
VI.	Rationale for Monitoring and Reporting Requirements .....	F-35
	A. Influent Monitoring .....	F-35
	B. Effluent Monitoring.....	F-35
	C. Bypasses or Sewer Overflow Monitoring .....	F-36
	D. Whole Effluent Toxicity Testing Requirements .....	F-36
	E. Receiving Water Monitoring.....	F-36
	F. Other Monitoring Requirements .....	F-36
VII.	Rationale for Provisions .....	F-36
	A. Standard Provisions (Provision VI.A).....	F-36
	B. Monitoring and Reporting Requirements (Provision VI.B).....	F-36
	C. Special Provisions (Provision VI.C) .....	F-37
	1. Reopener Provisions.....	F-37
	2. Special Studies and Additional Monitoring Requirements .....	F-37
	3. Best Management Practices and Pollution Minimization Program.....	F-37
	4. Construction, Operation, and Maintenance Specifications .....	F-37
	5. Special Provisions for Municipal Facilities (POTWs Only).....	F-38

6. Compliance Schedule.....	F-38
VIII. Public Participation.....	F-38
A. Notification of Interested Parties.....	F-38
B. Written Comments .....	F-38
C. Public Hearing.....	F-39
D. Waste Discharge Requirements Petitions.....	F-39
E. Information and Copying .....	F-39
F. Register of Interested Persons .....	F-39
G. Additional Information.....	F-39

### List of Tables

Table F-1. Facility Information.....	F-3
Table F-2. Outfall Location .....	F-5
Table F-3. Effluent Limitations (Order No. 01-143) and Monitoring Data for Conventional and Non-Conventional Pollutants .....	F-5
Table F-4. Effluent Limitations (Order No. 01-143) and Monitoring Data for Toxic Pollutants.....	F-6
Table F-5. Numeric Effluent Exceedances .....	F-6
Table F-6. Basin Plan Beneficial Uses .....	F-8
Table F-7. Secondary Treatment Requirements .....	F-12
Table F-8. Summary of Technology-Based Effluent Limitations .....	F-12
Table F-9. Translators for Copper and Nickel for Deepwater Discharges of North of Dumbarton Bridge .....	F-16
Table F-10. Summary of RPA Results .....	F-18
Table F-11. Effluent Limitations for Copper.....	F-25
Table F-12. Effluent Limit Calculations.....	F-30

**ATTACHMENT F – FACT SHEET**

As described in Section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

**I. PERMIT INFORMATION**

The following table summarizes administrative information related to the Millbrae Water Pollution Control Plant (WPCP).

**Table F-1. Facility Information**

<b>WDID</b>	2 417019001
<b>Dischargers</b>	City of Millbrae and the North Bayside System Unit (NBSU)
<b>Name of Facility</b>	City of Millbrae Water Pollution Control Plant
<b>Facility Address</b>	400 East Millbrae Avenue
	Millbrae, CA 94030
	San Mateo County
<b>Facility Contact, Title, Phone</b>	Joseph Magner, Superintendent, (650) 259-2388
<b>Authorized Person to Sign and Submit Reports</b>	Joseph Magner, Superintendent, (650) 259-2388
<b>Mailing Address</b>	621 Magnolia Avenue Millbrae, CA 94030
<b>Billing Address</b>	Same as Mailing Address
<b>Type of Facility</b>	Publicly Owned Treatment Works (POTW)
<b>Major or Minor Facility</b>	Major
<b>Threat to Water Quality</b>	2
<b>Complexity</b>	A
<b>Pretreatment Program</b>	Yes
<b>Reclamation Requirements</b>	1
<b>Facility Permitted Flow</b>	3.0 million gallons per day (MGD) average dry weather flow
<b>Facility Design Flow</b>	3.0 MGD (average daily, dry weather design flow)
	9.0 MGD (peak daily, wet weather design flow)
<b>Watershed</b>	San Francisco Bay
<b>Receiving Water</b>	Lower San Francisco Bay
<b>Receiving Water Type</b>	Marine

- A. The City of Millbrae is the owner and operator of the City of Millbrae Water Pollution Control Plant (WPCP), which discharges to Lower San Francisco Bay through the North Bayside System Unit (NBSU) force main.



For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B.** The Millbrae WPCP discharges treated wastewater through the NBSU force main into the deep-water channel of Lower San Francisco Bay, a water of the United States, and is currently regulated by Order No. 01-143 (NPDES Permit No. CA0037532), which was adopted on November 28, 2001.

The terms and conditions of Order No. 01-143 have been automatically continued past the Order’s original expiration date of November 28, 2006, and remain in effect until new Waste Discharge Requirements (WDRs) and a new NPDES permit are adopted pursuant to this Order.

- C.** The Discharger filed a Report of Waste Discharge and submitted an application for renewal of its WDRs and NPDES permit on March 24, 2006. The application was deemed complete on April 3, 2006.

## **II. FACILITY DESCRIPTION**

### **A. Description of Wastewater Treatment**

The Discharger owns and operates the Millbrae WPCP, which provides primary and secondary treatment of domestic and commercial wastewater collected from the City of Millbrae (population 20,500). The Millbrae WPCP has an average daily dry weather design treatment capacity of 3.0 MGD and can treat up to 9.0 MGD during wet weather.

Wastewater treatment processes at the Millbrae WPCP include grinding, primary sedimentation in rectangular clarifiers, biological activated sludge treatment, secondary clarification, disinfection with sodium hypochlorite, and final effluent skimming. Electricity is generated using the digester methane gas to fuel a co-generator. Standby generators supply power to Millbrae WPCP systems during power outages. Recycled water is produced for restricted use applications. A treatment process schematic diagram is included as Attachment C.

Chlorinated secondary effluent is discharged through Outfall E-001 to the North Bayside System Unit (NBSU) force main. The effluent is dechlorinated at the City of South San Francisco Water Quality Control Plant prior to discharge into Lower San Francisco Bay through the NBSU outfall (Outfall E-002). Outfall E-002 is a submerged diffuser located northeast of Point San Bruno about 5,300 feet offshore at a depth of 20 feet below mean lower low water (37 degrees, 39 minutes, 55 seconds N latitude and 122 degrees, 21 minutes, 41 seconds W longitude). The NBSU is a joint powers authority and includes the Cities of Burlingame, Millbrae, South San Francisco, and San Bruno, and San Francisco International Airport (both industrial and domestic waste treatment plants).

The Millbrae WPCP previously blended primary effluent with secondary effluent prior to disinfection when necessary as part of its wet weather operating strategy. It reported one blending event during the term of the previous permit, in February 2004. However, the Millbrae WPCP no longer blends; therefore, this Order does not include a provision for blending.

All storm water captured within the wastewater treatment plant is directed to the headworks of the treatment plant. Therefore, discharges of storm water originating on the grounds of the Millbrae WPCP are regulated by this order and coverage under Statewide Industrial Storm Water Permit (NPDES General Permit No. CAS000001) is not required.

## B. Discharge Points and Receiving Waters

The receiving water and the location of the NBSU discharge point are shown in Table F-2 below and Attachment B.

**Table F-2. Outfall Location**

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
E-002	POTW Effluent	37°, 39', 55" N	122°, 21', 41" W	Lower San Francisco Bay, via Discharge through the North Bayside System Unit

Lower San Francisco Bay is located in the South Bay Basin watershed management area, between the Dumbarton Bridge and the San Francisco-Oakland Bay Bridge.

## C. Summary of Existing Requirements and Self-Monitoring Report Data

Effluent limitations contained in the previous Order (Order No. 01-143) for discharges to Lower San Francisco Bay and representative monitoring data from the term of Order No. 01-143 are as follows:

**Table F-3. Effluent Limitations (Order No. 01-143) and Monitoring Data for Conventional and Non-Conventional Pollutants**

Parameter	(units)	Effluent Limitations			Monitoring Data (From 01/02 to 02/07)		
		Monthly Average	Weekly Average	Daily Maximum	Highest Monthly Average	Highest Weekly Average	Highest Daily Discharge
Oil and Grease	mg/L	10	---	20	5.5	NA	5.5
pH	standard units	6.0 – 9.0			7.4	NA	8.0
Total Suspended Solids (TSS)	mg/L	30	45	60	20	33	66
Acute Toxicity	% survival	(1)	(1)	(1)	NA	NA	NA
Carbonaceous Biological Oxygen Demand (CBOD)	mg/L	25	40	50	20	38	59
Fecal Coliform	MPN/100 mL	(2)	(2)	(2)	137	NA	16,000
Chlorine, Total Residual (TRC)	mg/L	---	---	0.0 <sup>(3)</sup>	(4)	(4)	(4)
Settleable Matter	mL/L-hr.	0.1	---	0.2	0.5	NA	0.5

mg/L = milligrams per liter

mL/L-hr = milliliters per liter per hour

Most Probable Number per 100 milliliters = MPN/100 mL

ND = Non-Detect

NA = Not Applicable

% survival = percent survival

- (1) An 11-sample median value of not less than 90 percent survival and an 11-sample 90th percentile value of not less than 70 percent survival.
- (2) The geometric mean for each calendar month shall not exceed 200 MPN/100 mL and no more than 10 percent of the samples in each calendar month shall exceed 400 MPN/100 mL.
- (3) For TRC, 0.0 mg/L was established as an instantaneous maximum effluent limitation.
- (4) Compliance is measured at the NBSU outfall for all NBSU dischargers. Individual data for the Millbrae WCPC is not available. TRC was not detected at the NBSU outfall over the time period covered in this table.

**Table F-4. Effluent Limitations (Order No. 01-143) and Monitoring Data for Toxic Pollutants**

Parameter	Units	Final Limits		Interim Limits		Monitoring Data (From 02/04 to 01/07)
		Daily Maximum	Monthly Average	Daily Maximum	Monthly Average	Highest Daily Concentration
Copper	µg/L	-----	-----	-----	17	13
Lead	µg/L	89	31	-----	-----	0.58
Mercury	µg/L	-----	-----	-----	0.087	0.028
Nickel	µg/L	63	33	-----	-----	6.5
Zinc	µg/L	887	440	-----	-----	27
Cyanide	µg/L	-----	-----	-----	10	17
TCDD Equivalents	µg/L	-----	-----	-----	$1.4 \times 10^{-7}$	$8.3 \times 10^{-8}$
Tetrachloroethylene	µg/L	-----	-----	-----	25	1.2
Bis(2-Ethylhexyl)Phthalate	µg/L	-----	-----	-----	170	3.1
4,4-DDE	µg/L	0.00118	0.00059	-----	-----	(0.002) <sup>(1)</sup>
Dieldrin	µg/L	0.000264	0.00014	-----	-----	(0.0019) <sup>(1)</sup>

Units: µg/L = micrograms per liter

<sup>(1)</sup> Analyte not detected in effluent. Number in parenthesis is the method detection limit (MDL) as reported by the analytical laboratory.**D. Compliance Summary**

1. **Compliance with Numeric Effluent Limits.** Exceedances of numeric effluent limits were observed during the permit term for total suspended solids, total settleable solids, fecal coliform, and CBOD. The exceedances are outlined below:

**Table F-5. Numeric Effluent Exceedances**

Date of Violation	Exceeded Parameter	Units	Effluent Limitation	Reported Concentration
October 31, 2002	Cyanide – Effluent Monthly Average	µg/L	10	18
December 19, 2002	TSS – Effluent Daily Maximum	Mg/L	60	66
October 31, 2003	Fecal Coliform – Monthly Percentage of Samples Greater Than 400 MPN/100 mL	%	10	25
November 30, 2003	Fecal Coliform – Monthly Percentage of Samples Greater Than 400 MPN/100 mL	%	10	18
December 29, 2003	Total Settleable Solids - Effluent Daily Maximum	mL/L-hr	0.2	0.5
December 31, 2003	Total Settleable Solids - Effluent Monthly Average	mL/L-hr	0.1	0.5
December 31, 2003	Fecal Coliform – Monthly Percentage of Samples Greater Than 400 MPN/100 mL	%	10	20
September 30, 2004	Fecal Coliform – Monthly Percentage of Samples	%	10	12.5

Date of Violation	Exceeded Parameter	Units	Effluent Limitation	Reported Concentration
	Greater Than 400 MPN/100 mL			
January 23, 2005	CBOD – Daily Maximum	mg/L	50	59
July 31, 2006	Cyanide - Effluent Monthly Average	µg/L	10	11.2
August 7, 2006	Acute Toxicity – Less Than 70% Survival If One or More of Past 10 or Less also Less Than 70%	%	70	45
September 30, 2006	Fecal Coliform – Monthly Percentage of Samples Greater Than 400 MPN/100 mL	-----	10	16.67

The Regional Water Board is evaluating appropriate enforcement for the exceedances listed above. Three of the above violations (cyanide effluent daily maximum, October 2002; Total Settleable Solids effluent daily maximum and effluent monthly average, December 2003) are considered “serious” and one additional violation (Fecal Coliform – Monthly Percentage of Samples Greater Than 400 MPN/100 mL in December 2003) is considered “chronic” under California Water Code (CWC) section 13385.

### E. Planned Changes

The Millbrae WPCP is in the planning stages of a series of capital projects that will include improvements to the collection system, addition of treatment plant flow equalization, process facilities renovation, a new aeration system, and a new operations center. The projects do not include an increase in the treatment capacity. The improvement projects are estimated to be completed by May, 2010.

## III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in the proposed Order are based on the requirements and authorities described in this section.

### A. Legal Authorities

This Order is issued pursuant to CWA section 402 and implementing regulations adopted by the USEPA and Chapter 5.5, Division 7 of the CWC (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from the Millbrae WPCP to surface waters. This Order also serves as WDRs pursuant to CWC Article 4, Chapter 4, Division 7 (commencing with section 13260).

### B. California Environmental Quality Act (CEQA)

Under CWC section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA.

### C. State and Federal Regulations, Policies, and Plans

1. Water Quality Control Plans. The Water Quality Control Plan for the San Francisco Bay Basin (the Basin Plan) is the Regional Water Board’s master water quality control planning document. It designates beneficial uses and water quality objectives for waters of the State, including surface waters and groundwater. It also includes programs of implementation to achieve water quality objectives. The Basin Plan was adopted by the Regional Water Board

and approved by the State Water Resources Control Board, USEPA, and the Office of Administrative Law, as required. Requirements of this Order implement the Basin Plan.

The Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which establishes state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply (MUN). Because of the marine influence on receiving waters of San Francisco Bay, total dissolved solids levels in San Francisco Bay commonly (and often significantly) exceed 3,000 mg/L and thereby meet an exception to State Water Board Resolution No. 88-63. Therefore, the designation MUN is not applicable to Lower San Francisco Bay. Beneficial uses applicable to Lower San Francisco Bay are as follows:

**Table F-6. Basin Plan Beneficial Uses**

Discharge Point	Receiving Water Name	Beneficial Use(s)
E-002	Lower San Francisco Bay	Industrial Service Supply (IND) Navigation (NAV) Water Contact Recreation (REC1) Non-Contact Water Recreation (REC2) Ocean, Commercial and Sport Fishing (COMM) Wildlife Habitat (WILD) Preservation of Rare and Endangered Species (RARE) Fish Migration (MIGR) Shellfish Harvesting (SHELL) Estuarine Habitat (EST)

2. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and amended it on May 4, 1995, and November 9, 1999. About 40 criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority toxic pollutants, which are applicable to Lower San Francisco Bay.
3. **State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
4. **Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA

purposes [40 CFR 131.21, 65 Fed. Reg. 24641 (April 27, 2000)]. Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.

5. **Antidegradation Policy.** 40 CFR 131.12 requires that State water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution 68-16. Resolution 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies.

The permitted discharge is consistent with the antidegradation provision of 40 CFR 131.12 and State Water Board Resolution 68-16. This Order continues the status quo with respect to the level of discharge authorized in the previous permit and thus there will be no change in water quality beyond the level that was authorized in the last permit. The final limits in this Order comply with antidegradation requirements and meet the requirements of the SIP. These limits hold the Discharger to performance levels that will neither cause nor contribute to water quality impairment, nor further water quality degradation. This Order does not provide for an increase in the permitted design flow, allow for a reduction in the level of treatment, or increase effluent limitations (with the exception of copper and cyanide).

In the cases of copper and cyanide:

- Both the final effluent limits for copper that will take effect with this Order and the alternate effluent limits for copper based on site-specific objectives (SSOs) that will take effect if the SSOs become effective during the term of this Order are higher than the current interim limits.
- The final effluent limits for cyanide are higher than the previous interim effluent limit in Order No. 01-143.

The standards-setting processes for the copper and cyanide SSOs addressed antidegradation, concluding that water quality would not be degraded (*Copper Site-Specific Objectives in San Francisco Bay: Proposed Basin Plan Amendment and Draft Staff Report*, June 6, 2007; *Staff Report on Proposed Site-Specific Water Quality Objectives for Cyanide for San Francisco Bay*, December 4, 2006). These conclusions were based on assumed implementation of copper and cyanide action plans. Such plans are included in the provisions of this Order (Sections VI.C.7 and 8).

As antidegradation has been addressed, there will be no lowering of water quality beyond the current level authorized in the previous permit, which is the baseline by which to measure whether degradation will occur, and further analysis in this permit is unnecessary. Findings authorizing degradation are thus unnecessary.

6. **Anti-Backsliding Requirements.** CWA Sections 402(o)(2) and 303(d)(4) and NPDES regulations at 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-

backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed. See Fact Sheet Section VI.D.1, Anti-Backsliding/Antidegradation.

#### **D. Impaired Water Bodies on CWA 303(d) List**

In November 2006, the USEPA approved a revised list of impaired water bodies prepared by the State [hereinafter referred to as the 303(d) list], prepared pursuant to provisions of CWA section 303(d), which requires identification of specific water bodies where it is expected that water quality standards will not be met after implementation of technology-based effluent limitations on point sources. Lower San Francisco Bay is listed as an impaired waterbody for chlordane, DDT, dieldrin, dioxin compounds, exotic species, furan compounds, mercury, PCBs, and dioxin-like PCBs. The SIP requires final effluent limitations for all 303(d)-listed pollutants to be consistent with total maximum daily loads and associated waste load allocations.

##### **1. Total Maximum Daily Loads**

The Regional Water Board plans to adopt Total Maximum Daily Loads (TMDLs) for pollutants on the 303(d) list in Lower San Francisco Bay within the next ten years. Future review of the 303(d)-list for Lower San Francisco Bay may provide schedules or result in revision of the schedules for adoption of TMDLs.

##### **2. Waste Load Allocations**

The TMDLs will establish waste load allocations (WLAs) for point sources and load allocations (LAs) for non-point sources, and will result in achieving the water quality standards for the waterbodies. Final water quality-based effluent limitations (WQBELs) for 303(d)-listed pollutants in this discharge will be based on WLAs contained in the respective TMDLs.

##### **3. Implementation Strategy**

The Regional Water Board's strategy to collect water quality data and to develop TMDLs is summarized below:

- a. Data Collection.** The Regional Water Board has given dischargers to San Francisco Bay the option to collectively assist in developing and implementing analytical techniques capable of detecting 303(d)-listed pollutants to at least their respective levels of concern or WQOs/Water Quality Criteria (WQC). This collective effort may include development of sample concentration techniques for approval by the USEPA. The Regional Water Board will require dischargers to characterize the pollutant loads from their facilities into the water-quality limited waterbodies. The results will be used in the development of TMDLs, and may be used to update or revise the 303(d) list or change the WQOs/WQC for the impaired waterbodies including Lower San Francisco Bay.
- b. Funding Mechanism.** The Regional Water Board has received, and anticipates continuing to receive, resources from Federal and State agencies for TMDL development. To ensure timely development of TMDLs, the Regional Water Board intends to

supplement these resources by allocating development costs among dischargers through the Regional Monitoring Program (RMP) or other appropriate funding mechanisms.

#### IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the NPDES regulations: 40 CFR 122.44(a) requires that permits include applicable technology-based limitations and standards; and 40 CFR 122.44(d) requires that permits include WQBELs to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water. Where Reasonable Potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs may be established (1) using USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) using an indicator parameter for the pollutant of concern; or (3) using a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR 122.44(d)(1)(vi).

Several specific factors affecting the development of limitations and requirements in this Order are discussed as follows.

##### A. Discharge Prohibitions

1. **Discharge Prohibition III.A (No discharge other than that described in this Order):** This prohibition is the same as in the previous permit and is based on CWC section 13260, which requires filing a Report of Waste Discharge (ROWD) before discharges can occur. Discharges not described in the ROWD, and subsequently in this Order, are prohibited.
2. **Discharge Prohibition III.B (Average dry weather flow not to exceed dry weather design capacity):** This prohibition is based on the design treatment capacity of the Millbrae WPCP. Exceedance of the Millbrae WPCP's average dry weather flow design capacity of 3.0 MGD may result in lowering the reliability of achieving compliance with water quality requirements.
3. **Discharge Prohibition III.C (No discharge receiving less than 10:1 dilution):** This prohibition is the same as in the previous permit and is based on Discharge Prohibition No. 1 from Table 4-1 of the Basin Plan, which prohibits discharges that do not receive a minimum 10:1 initial dilution. Further, this Order allows a 10:1 dilution credit in the calculation of some water quality based effluent limitations, and these limits would not be protective of water quality if the discharge did not actually achieve a 10:1 minimum initial dilution.
4. **Discharge Prohibition III.D (No bypass or overflow of untreated or partially treated wastewaters):** This prohibition is based on the NPDES regulations expressed at 40 CFR 122.41(m)(4)(i)(A)-(C). This prohibition is changed from Order 01-143 in that blending, which was permitted by Order 01-143 during wet weather subject to the requirements of 40 CFR 122.41(m)(4)(i)(A)-(C), is also prohibited.



5. **Discharge Prohibition III.E (No sanitary sewer overflows to waters of the United States).** Sanitary sewer overflows that result in the discharge of raw or partially treated sewage not meeting secondary treatment requirements to surface waters of the United States are prohibited under the Clean Water Act and the Basin Plan. Discharge Prohibition No. 15 from Table 4-1 of the Basin Plan and the Clean Water Act prohibit the discharge of wastewater to surface waters except as authorized under an NPDES permit. POTWs must achieve secondary treatment, at a minimum, and any more stringent limitations necessary to achieve water quality standards (33U.S.C. §1311(b)(1)(B) and (C)).

## B. Technology-Based Effluent Limitations

### 1. Scope and Authority

CWA section 301(b)(1)(B) requires USEPA to develop secondary treatment standards (the level of effluent quality attainable through application of secondary or equivalent treatment) for POTWs. USEPA promulgated such technology-based effluent guidelines for POTWs at 40 CFR 133. These Secondary Treatment Regulations include the following minimum requirements for POTWs, which are applicable to discharges from the Millbrae WPCP.

**Table F-7. Secondary Treatment Requirements**

	30-Day Average	7-Day Average
BOD <sup>(1)</sup>	30 mg/L	45 mg/L
CBOD <sup>(1)(2)</sup>	25 mg/L	40 mg/L
TSS <sup>(1)</sup>	30 mg/L	45 mg/L
pH	6.0 – 9.0	

<sup>(1)</sup> The 30 day average percent removal shall not be less than 85 percent.

<sup>(2)</sup> At the option of the permitting authority, these effluent limitations for CBOD may be substituted for limitations for BOD.

### 2. Applicable Technology-Based Effluent Limitations

This Order retains the following technology-based effluent limitations, applicable to Discharge Point E-001, from Order No. 01-143.

**Table F-8. Summary of Technology-Based Effluent Limitations**

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
CBOD <sub>5</sub>	mg/L	25	40		---	---
TSS	mg/L	30	45		---	---
Oil and Grease	mg/L	10	---	20	---	---
pH	s.u.	---	---	---	6.0	9.0
Total Residual Chlorine	mg/L	---	---	---	---	0.0 <sup>(1)</sup>

<sup>(1)</sup> Chlorine residual compliance may be demonstrated by monitoring at the NBSU common outfall (E-002).

The limitations established for Oil and Grease are levels attainable by secondary treatment and are required by the Basin Plan (Table 4-2) for all discharges to inland surface waters and enclosed bays and estuaries of the San Francisco Bay Region.

The pH limitation is retained from Order No. 01-143 and is required by USEPA's Secondary Treatment Regulation at 40 CFR 133 and by the Basin Plan (Table 4-2) for deep water discharges.

The technology-based effluent limitations for settleable matter are not retained from Order No. 01-143, as the Regional Water Board has determined that compliance with the Secondary Treatment Regulation at 40 CFR 133 and with the Basin Plan (Table 4-2) requirements for all discharges to inland surface waters and enclosed bays and estuaries of the San Francisco Bay Region will ensure removal of settleable solids to acceptably low levels below 0.1 mL/L-hr (30 day average) and 0.2 mL/L-hr (daily maximum).

Effluent limitations for CBOD and TSS, including the 85% removal requirement, are retained from Order No. 01-143. 40 CFR 122.45(d)(2) specifies that discharge limitations for POTWs shall be stated as average weekly limitations and average monthly limitations, unless impracticable.

### 3. Bacteria

- a. **Fecal Coliform:** Effluent limitations for fecal coliform bacteria are retained from Order No. 01-143. These limitations reflect applicable water quality objectives for water contact recreation, established by Table 3-1 of the Basin Plan and applied as end-of-pipe effluent limitations.
- b. **Enterococci:** This Order establishes a technology-based effluent limitation for enterococci bacteria. This limitation is based on the enterococci concentration currently economically and technologically achievable by six other POTWs in the San Francisco Bay Region. This limitation is also consistent with the requirements of the Basin Plan at Table 4-2, footnote d, and with the BEACH Act of 2004 [40CFR 133.41(e)(1)]. This effluent limitation will ensure that there are no "unacceptable adverse impacts on the beneficial uses" of lower San Francisco Bay.

Enterococci are more closely associated with gastrointestinal disease contracted by water contact than are fecal coliform bacteria. USEPA established bacteriological criteria for water contact recreation in coastal waters, including coastal estuaries such as San Francisco Bay, pursuant to the BEACH Act on November 16, 2004 (Federal Register, Volume 69, No. 220). This Order's effluent limitation on enterococci, a geometric mean of 35 MPN/100 mL, is equivalent to the BEACH Act's saltwater bacteriological criterion for water contact recreation.

Bacteria concentrations in sewage treatment plant effluent are primarily a function of disinfectant application, so the Discharger can meet this limitation with its existing technology. Because this technology-based limitation does not account for dilution in the receiving waters, it is likely to be conservative in terms of protecting beneficial uses, and therefore consistent with Basin Plan Table 4-2, footnote d.

Although USEPA also established single sample maximum criteria for enterococci bacteria, this Order implements only the geometric mean criterion of 35 MPN/100 mL. When these criteria were promulgated, USEPA expected that the single sample maximum values would be used for making beach notification and beach closure decisions. "Other

than in the beach notification and closure decision context, the geometric mean is the more relevant value for assuring that appropriate actions are taken to protect and improve water quality because it is a more reliable measure, being less subject to random variation...” [Federal Register, Volume 69, No 220].

## C. Water Quality-Based Effluent Limitations

### 1. Scope and Authority

- a. NPDES regulations at 40 CFR 122.44(d)(1)(i) require permits to include WQBELs for pollutants (including toxicity) that are or may be discharged at levels that cause, have reasonable potential to cause, or contribute to an excursion above any state water quality standard (Reasonable Potential). The process for determining Reasonable Potential and, when necessary, calculating WQBELs is intended to (1) protect the designated beneficial uses of the receiving water specified in the Basin Plan, and (2) achieve applicable WQOs and WQC that are contained in the California Toxics Rule (CTR), National Toxics Rule (NTR), Basin Plan, and other State plans and policies.
- b. NPDES regulations and the SIP provide the basis to establish Maximum Daily Effluent Limitations (MDELs).
  - (1) **NPDES Regulations.** NPDES regulations at 40 CFR 122.45(d) state: “For continuous discharges all permit effluent limitations, standards, and prohibitions, including those necessary to achieve water quality standards, shall *unless impracticable* be stated as maximum daily and average monthly discharge limitations for all discharges other than publicly owned treatment works.”
  - (2) **SIP.** The SIP (page 8, Section 1.4) requires WQBELs be expressed as MDELs and average monthly effluent limitations (AMELs).
- c. MDELs are used in this Order to protect against acute water quality effects. The MDELs are necessary for preventing fish kills or mortality to aquatic organisms.

### 2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

The WQC and WQOs applicable to the receiving waters for this discharge are from the Basin Plan; the CTR, established by USEPA at 40 CFR 131.38; and the NTR, established by USEPA at 40 CFR 131.36. Some pollutants have WQC/WQOs established by more than one of these three sources.

- a. **Basin Plan.** The Basin Plan specifies numeric WQOs for 10 priority toxic pollutants, as well as narrative WQOs for toxicity and bioaccumulation in order to protect beneficial uses. The pollutants for which the Basin Plan specifies numeric objectives are arsenic, cadmium, chromium (VI), copper in freshwater, lead, mercury, nickel, silver, zinc, and cyanide. The narrative toxicity objective states in part that “[a]ll waters shall be maintained free of toxic substances in concentrations that are lethal to or that produce other detrimental responses in aquatic organisms.” The bioaccumulation objective states in part that “[c]ontrollable water quality factors shall not cause a detrimental increase in concentrations of toxic substances found in bottom sediments or aquatic life. Effects on

aquatic organisms, wildlife, and human health will be considered.” Effluent limitations and provisions contained in this Order are designed based on available information to implement these objectives.

- b. **CTR.** The CTR specifies numeric aquatic life criteria for 23 priority toxic pollutants and numeric human health criteria for 57 priority toxic pollutants. These criteria apply to all inland surface waters and enclosed bays and estuaries of San Francisco Bay Region, although Tables 3-3 and 3-4 of the Basin Plan include numeric objectives that supersede criteria of the CTR for certain of these priority toxic pollutants.
- c. **NTR.** The NTR establishes numeric aquatic life criteria for selenium, numeric aquatic life and human health criteria for cyanide, and numeric human health criteria for 34 toxic organic pollutants for waters of San Francisco Bay upstream to and including Suisun Bay and the Sacramento River Delta. These criteria of the NTR are applicable to Lower San Francisco Bay, the receiving water for this Discharger.
- d. **Technical Support Document for Water Quality-Based Toxics Controls.** Where numeric objectives have not been established or updated in the Basin Plan, NPDES regulations at 40 CFR 122.44 (d) require that WQBELs be established based on USEPA criteria, supplemented where necessary by other relevant information, to attain and maintain narrative WQOs to fully protect designated beneficial uses.

To determine the need for WQBELs and establish them when necessary, the Regional Water Board has followed the requirements of applicable NPDES regulations, including 40 CFR 122 and 131; guidance and requirements established by the Basin Plan; USEPA’s *Technical Support Document for Water Quality-Based Toxics Control* (the TSD, EPA/505/2-90-001, 1991); and the SIP.

- e. **Basin Plan Receiving Water Salinity Policy.** The Basin Plan (like the CTR and the NTR) states that the salinity characteristics (i.e., freshwater vs. saltwater) of the receiving water shall be considered in determining the applicable WQC. Freshwater criteria shall apply to discharges to waters with salinities equal to or less than one part per thousand (ppt) at least 95 percent of the time. Saltwater criteria shall apply to discharges to waters with salinities equal to or greater than 10 ppt at least 95 percent of the time in a normal water year. For discharges to water with salinities in between these two categories, or tidally influenced freshwaters that support estuarine beneficial uses, the criteria shall be the lower of the salt or freshwater criteria (the latter calculated based on ambient hardness) for each substance.

The receiving water for this discharger, Lower San Francisco Bay, is a salt water environment based on salinity data generated through the San Francisco Estuary Institute’s RMP at the Alameda (BB70), Oyster Point (BB30), and San Bruno Shoal (BB15) sampling stations between 1993 and 2001. In that period, the average salinity at the three sampling stations was 24 ppt; the minimum observed salinity levels at the San Bruno Shoal, Alameda, and Oyster Point sampling stations were 12, 11, and 0.5 ppt, respectively. As salinity was greater than 10 ppt in at least 95 percent of receiving water samples, the saltwater criteria from the Basin Plan, NTR, and CTR apply to this discharge.

- f. Shallow/Deep Water Discharge.** Discharge from the Millbrae WPCP to Lower San Francisco Bay is viewed as a deep water discharge, which is defined by the Basin Plan as a discharge through a diffuser that receives a minimum initial dilution of 10 to 1. Pursuant to the Basin Plan, WQBELs established by this Order (except those for bioaccumulative pollutants and the non-persistent pollutant ammonia) are therefore based on an initial dilution of 10 to 1.
- g. Site-Specific Metals Translators.** Because NPDES regulations at 40 CFR 122.45(c) require that effluent limitations for metals be expressed as total recoverable metal, and applicable WQC for metals are typically expressed as dissolved metal, factors or translators must be used to convert metals concentrations from dissolved to total recoverable and vice versa. In the CTR, USEPA establishes default translators that are used in NPDES permitting activities; however, site-specific conditions such as water temperature, pH, suspended solids, and organic carbon greatly impact the form of metal (dissolved, filterable, or otherwise) that is present in the water and therefore available to cause toxicity. In general, the dissolved form of the metals is more available and more toxic to aquatic life than filterable forms. Site-specific translators can be developed to account for site-specific conditions, thereby preventing exceedingly stringent or underprotective WQOs.

For deep water discharges to South San Francisco Bay, the Regional Water Board used the following translators for copper and nickel, based on recommendations of the Clean Estuary Partnership’s *North of Dumbarton Bridge Copper and Nickel Development and Selection of Final Translators* (2005). In determining the need for and calculating WQBELs for all other metals, the Regional Water Board staff used default translators established by the USEPA in the CTR at 40 CFR 131.38(b)(2), Table 2.

**Table F-9. Translators for Copper and Nickel for Deepwater Discharges of North of Dumbarton Bridge**

CU and Ni Translators for Deepwater Discharges to Lower San Francisco Bay	Copper		Nickel	
	AMEL Translator	MDEL Translator	AMEL Translator	MDEL Translator
	0.74	0.88	0.65	0.85

**3. Determining the Need for WQBELs**

NPDES regulations at 40 CFR 122.44 (d)(1)(i) require permits to include WQBELs for all pollutants (non-priority and priority) “which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any narrative or numeric criteria within a State water quality standard.” Thus, assessing whether a pollutant has “Reasonable Potential” is the fundamental step in determining whether or not a WQBEL is required. For non-priority pollutants, Regional Water Board staff used available monitoring data, the receiving water’s designated beneficial uses, and/or previous permit pollutant limitations to determine Reasonable Potential. For priority pollutants, Regional Water Board staff used the methods prescribed in Section 1.3 of the SIP to determine if the discharge from the Millbrae WPCP demonstrates Reasonable Potential as described below in sections 3.a – 3.e.

**a. Reasonable Potential Analysis**

Using the methods prescribed in Section 1.3 of the SIP, Regional Water Board staff analyzed the effluent data to determine if the discharge from the Millbrae WPCP demonstrates Reasonable Potential. The RPA compares the effluent data with numeric and narrative WQOs in the Basin Plan and numeric WQC established by the USEPA in the NTR and CTR.

**b. Reasonable Potential Methodology**

Using the methods and procedures prescribed in Section 1.3 of the SIP, Regional Water Board staff analyzed the effluent and background data and the nature of Millbrae WPCP operations to determine if the discharge has Reasonable Potential to cause or contribute to exceedances of applicable Site-Specific Objectives or WQC.

The RPA projects a maximum effluent concentration (MEC) for each pollutant based on existing data, while accounting for a limited data set and effluent variability. There are three triggers in determining Reasonable Potential.

- (1) The first trigger is activated if the MEC is greater than or equal to the lowest applicable WQO ( $MEC \geq WQO$ ), which has been adjusted, if appropriate, for pH, hardness, and translator data. If the MEC is greater than or equal to the adjusted WQO, then that pollutant has Reasonable Potential, and a WQBEL is required.
- (2) The second trigger is activated if the observed maximum ambient background concentration (B) is greater than the adjusted WQO ( $B > WQO$ ), and the pollutant is detected in any of the effluent samples ( $MEC > ND$ ).
- (3) The third trigger is activated if a review of other information determines that a WQBEL is required to protect beneficial uses, even though both MEC and B are less than the WQO/WQC. A limitation may be required under certain circumstances to protect beneficial uses.

**c. Effluent Data**

The Regional Water Board's August 6, 2001, letter titled *Requirement for Monitoring of Pollutants in Effluent and Receiving Water to Implement New Statewide Regulations and Policy* (August 6, 2001 Letter – available online; see Standard Language and Other References Available Online, below) to all permittees, formally required the Discharger (pursuant to Section 13267 of the CWC) to initiate or continue monitoring for the priority pollutants using analytical methods that provide the best detection limits reasonably feasible. Regional Water Board staff analyzed this effluent data and the nature of the Millbrae WPCP to determine if the discharge has Reasonable Potential. The RPA was based on the effluent monitoring data collected by the Discharger from February 2004 through January 2007 for most inorganic pollutants, and from June 2002 through November 2006 for most organic pollutants.

**d. Ambient Background Data**

Ambient background values are used in the RPA and in the calculation of effluent limitations. For the RPA, ambient background concentrations are the observed maximum detected water column concentrations. The SIP states that for calculating WQBELs, ambient background concentrations are either the observed maximum ambient water column concentrations or, for criteria/objectives intended to protect human health from carcinogenic effects, the arithmetic mean of observed ambient water concentrations. The RMP station at Yerba Buena Island, located in the Central Bay, has been monitored for most of the inorganic (CTR constituent numbers 1–15) and some of the organic (CTR constituent numbers 16–126) toxic pollutants, and these RMP data were used as background data in performing the RPA for this Discharger.

Not all the constituents listed in the CTR have been analyzed by the RMP. These data gaps are addressed by the August 6, 2001, Letter. The August 6, 2001, Letter formally requires Dischargers (pursuant to CWC Section 13267) to conduct ambient background monitoring and effluent monitoring for those constituents not currently monitored by the RMP, and to provide this technical information to the Regional Water Board.

On May 15, 2003, a group of several San Francisco Bay Region dischargers (known as the Bay Area Clean Water Agencies, or BACWA) submitted a collaborative receiving water study, entitled the *San Francisco Bay Ambient Water Monitoring Interim Report* (2003). This study includes monitoring results from sampling events in 2002 and 2003 for the remaining priority pollutants not monitored by the RMP. The RPA was conducted and the WQBELs were calculated using RMP data from 1993 through 2003 for inorganics and organics at the Yerba Buena Island RMP station, and additional data from BACWA's *Ambient Water Monitoring: Final CTR Sampling Update* (2004) for the Yerba Buena Island RMP station. The Dischargers may use this study to fulfill all requirements of the August 6, 2001 Letter for receiving water monitoring.

**e. RPA Determination**

The MECs, most stringent applicable WQOs/WQC, and background concentrations used in the RPA are presented in the following table, along with the RPA results (yes or no) for each pollutant analyzed. Reasonable Potential was not determined for all pollutants, as there are not applicable WQOs/WQC for all pollutants, and monitoring data are not available for others. RPA results are shown below. Based on a review of the effluent data collected during the previous permit term, the pollutants that exhibit Reasonable Potential are copper, mercury, cyanide, dioxin-TEQ, and ammonia.

**Table F-10. Summary of RPA Results**

CTR #	Priority Pollutants	MEC or Minimum DL <sup>[a][b]</sup> (µg/L)	Governing WQO/WQC (µg/L)	Maximum Background or Minimum DL <sup>[a][b]</sup> (µg/L)	RPA Results <sup>[c]</sup>
1	Antimony	0.5	4300	1.8	No
2	Arsenic	1.8	36	2.46	No
3	Beryllium	0.1	No Criteria	0.215	Ud
4	Cadmium	0.13	9.4	0.13	No
5a	Chromium (III)	1	No Criteria	Not Available	No
5b	Chromium (VI)	1.4	50	4.4	Ud

CTR #	Priority Pollutants	MEC or Minimum DL <sup>[a][b]</sup> (µg/L)	Governing WQO/WQC (µg/L)	Maximum Background or Minimum DL <sup>[a][b]</sup> (µg/L)	RPA Results <sup>[c]</sup>
6	<b>Copper</b>	<b>13</b>	<b>4.2</b>	<b>2.55</b>	<b>Yes</b>
7	Lead	0.58	8.5	0.80	No
8	<b>Mercury (303d listed) <sup>[d]</sup></b>	<b>0.028</b>	<b>0.025</b>	<b>0.0086</b>	<b>Yes</b>
9	Nickel	6.5	13	3.7	No
10	Selenium	3	5.0	0.39	No
11	Silver	1	2.2	0.052	No
12	Thallium	0.1	6.3	0.21	No
13	Zinc	27	86	5.1	No
14	<b>Cyanide</b>	<b>17</b>	<b>2.9</b>	<b>&lt; 0.4</b>	<b>Yes</b>
15	Asbestos	Not Available	No Criteria	Not Available	Ud
16	2,3,7,8-TCDD (303d listed)	< 3.1E-07	1.4E-08	Not Available	No
	<b>Dioxin TEQ (303d listed)</b>	<b>8.3E-07</b>	<b>1.4E-08</b>	<b>7.10E-08</b>	<b>Yes</b>
17	Acrolein	< 0.5	780	< 0.5	No
18	Acrylonitrile	< 0.33	0.66	0.03	No
19	Benzene	< 0.03	71	< 0.05	No
20	Bromoform	< 0.03	360	< 0.5	No
21	Carbon Tetrachloride	< 0.04	4.4	0.06	No
22	Chlorobenzene	< 0.03	21000	< 0.5	No
23	Chlorodibromomethane	0.2	34	< 0.05	No
24	Chloroethane	< 0.03	No Criteria	< 0.5	Ud
25	2-Chloroethylvinyl ether	< 0.1	No Criteria	< 0.5	Ud
26	Chloroform	4.8	No Criteria	< 0.5	Ud
27	Dichlorobromomethane	0.6	46	< 0.05	No
28	1,1-Dichloroethane	< 0.04	No Criteria	< 0.05	Ud
29	1,2-Dichloroethane	< 0.04	99	0.04	No
30	1,1-Dichloroethylene	< 0.06	3.2	< 0.5	No
31	1,2-Dichloropropane	< 0.03	39	< 0.05	No
32	1,3-Dichloropropylene	< 0.03	1700	Not Available	No
33	Ethylbenzene	< 0.04	29000	< 0.5	No
34	Methyl Bromide	< 0.05	4000	< 0.5	No
35	Methyl Chloride	< 0.04	No Criteria	< 0.5	Ud
36	Methylene Chloride	1	1600	0.5	No
37	1,1,2,2-Tetrachloroethane	< 0.04	11	< 0.05	No
38	Tetrachloroethylene	1.2	8.85	< 0.05	No
39	Toluene	1	200000	< 0.3	No
40	1,2-Trans-Dichloroethylene	< 0.05	140000	< 0.5	No
41	1,1,1-Trichloroethane	< 0.03	No Criteria	< 0.5	Ud
42	1,1,2-Trichloroethane	< 0.05	42	< 0.05	No
43	Trichloroethylene	< 0.05	81	< 0.5	No
44	Vinyl Chloride	< 0.05	525	< 0.5	No
45	2-Chlorophenol	< 0.6	400	< 1.2	No
46	2,4-Dichlorophenol	< 0.7	790	< 1.3	No
47	2,4-Dimethylphenol	< 0.9	2300	< 1.3	No
48	2-Methyl- 4,6-Dinitrophenol	< 0.9	765	< 1.2	No
49	2,4-Dinitrophenol	< 0.6	14000	< 0.7	No
50	2-Nitrophenol	< 0.7	No Criteria	< 1.3	Ud
51	4-Nitrophenol	< 0.6	No Criteria	< 1.6	Ud
52	3-Methyl 4-Chlorophenol	< 0.5	No Criteria	< 1.1	Ud
53	Pentachlorophenol	< 0.9	7.9	< 1.0	No
54	Phenol	< 0.4	4600000	< 1.3	No
55	2,4,6-Trichlorophenol	< 0.6	6.5	< 1.3	No
56	Acenaphthene	< 0.029	2700	0.0015	No
57	Acenaphthylene	< 0.019	No Criteria	0.00053	Ud



CTR #	Priority Pollutants	MEC or Minimum DL <sup>[a][b]</sup> (µg/L)	Governing WQO/WQC (µg/L)	Maximum Background or Minimum DL <sup>[a][b]</sup> (µg/L)	RPA Results <sup>[c]</sup>
58	Anthracene	< 0.029	110000	0.0005	No
59	Benzidine	< 0.97	0.00054	< 0.0015	No
60	Benzo(a)Anthracene	< 0.019	0.049	0.0053	No
61	Benzo(a)Pyrene	< 0.019	0.049	0.00029	No
62	Benzo(b)Fluoranthene	< 0.02	0.049	0.0046	No
63	Benzo(ghi)Perylene	< 0.02	No Criteria	0.0027	Ud
64	Benzo(k)Fluoranthene	< 0.02	0.049	0.0015	No
65	Bis(2-Chloroethoxy)Methane	< 0.7	No Criteria	< 0.3	Ud
66	Bis(2-Chloroethyl)Ether	< 0.68	1.4	< 0.3	No
67	Bis(2-Chloroisopropyl)Ether	< 0.6	170000	Not Available	No
68	Bis(2-Ethylhexyl)Phthalate	3.1	5.9	< 0.5	No
69	4-Bromophenyl Phenyl Ether	< 0.4	No Criteria	< 0.23	Ud
70	Butylbenzyl Phthalate	< 0.8	5200	< 0.52	No
71	2-Chloronaphthalene	< 0.5	4300	< 0.3	No
72	4-Chlorophenyl Phenyl Ether	< 0.5	No Criteria	< 0.3	Ud
73	Chrysene	< 0.02	0.049	0.0024	No
74	Dibenzo(a,h)Anthracene	< 0.029	0.049	0.00064	No
75	1,2-Dichlorobenzene	< 0.05	17000	< 0.8	No
76	1,3-Dichlorobenzene	< 0.07	2600	< 0.8	No
77	1,4-Dichlorobenzene	1.4	2600	< 0.8	No
78	3,3 Dichlorobenzidine	< 0.3	0.077	< 0.001	No
79	Diethyl Phthalate	< 0.7	120000	< 0.24	No
80	Dimethyl Phthalate	< 0.58	2900000	< 0.24	No
81	Di-n-Butyl Phthalate	< 0.58	12000	< 0.5	No
82	2,4-Dinitrotoluene	< 0.6	9.1	< 0.27	No
83	2,6-Dinitrotoluene	< 0.49	No Criteria	< 0.29	No
84	Di-n-Octyl Phthalate	< 0.68	No Criteria	< 0.38	No
85	1,2-Diphenylhydrazine	< 0.6	0.54	0.0037	No
86	Fluoranthene	< 0.029	370	0.011	No
87	Fluorene	< 0.02	14000	0.00208	No
88	Hexachlorobenzene	< 0.4	0.00077	0.0000202	No
89	Hexachlorobutadiene	< 0.7	50	< 0.3	No
90	Hexachlorocyclopentadiene	< 0.4	17000	< 0.31	No
91	Hexachloroethane	< 0.6	8.9	< 0.2	No
92	Indeno(1,2,3-cd)Pyrene	< 0.02	0.049	0.004	No
93	Isophorone	< 0.49	600	< 0.3	No
94	Naphthalene	< 0.019	No Criteria	0.0023	Ud
95	Nitrobenzene	< 0.68	1900	< 0.25	No
96	N-Nitrosodimethylamine	< 0.58	8.1	< 0.3	No
97	N-Nitrosodi-n-Propylamine	< 0.78	1.4	< 0.001	No
98	N-Nitrosodiphenylamine	< 0.58	16	< 0.001	No
99	Phenanthrene	< 0.02	No Criteria	0.0061	Ud
100	Pyrene	< 0.02	11000	0.0051	No
101	1,2,4-Trichlorobenzene	< 0.6	No Criteria	< 0.3	Ud
102	Aldrin	< 0.002	0.00014	Not Available	No
103	Alpha-BHC	< 0.0029	0.013	0.000496	No
104	beta-BHC	< 0.0029	0.046	0.000413	No
105	gamma-BHC	< 0.0029	0.063	0.0007034	No
106	delta-BHC	< 0.002	No Criteria	0.000042	Ud
107	Chlordane (303d listed)	< 0.005	0.00059	0.00018	No
108	4,4'-DDT (303d listed)	< 0.0029	0.00059	0.000066	No
109	4,4'-DDE (linked to DDT)	< 0.002	0.00059	0.000693	No
110	4,4'-DDD	< 0.0019	0.00084	0.000313	No

CTR #	Priority Pollutants	MEC or Minimum DL <sup>[a][b]</sup> (µg/L)	Governing WQO/WQC (µg/L)	Maximum Background or Minimum DL <sup>[a][b]</sup> (µg/L)	RPA Results <sup>[c]</sup>
111	Dieldrin (303d listed)	< 0.0019	0.00014	0.000264	No
112	Alpha-Endosulfan	< 0.0019	0.0087	0.000031	No
113	beta-Endosulfan	< 0.0019	0.0087	0.000069	No
114	Endosulfan Sulfate	< 0.002	240	0.0000819	No
115	Endrin	< 0.0019	0.0023	0.000036	No
116	Endrin Aldehyde	< 0.002	0.81	Not Available	No
117	Heptachlor	< 0.0029	0.00021	0.000019	No
118	Heptachlor Epoxide	< 0.0019	0.00011	0.00002458	No
119-125	PCBs sum (303d listed)	< 0.029	0.00017	Not Available	No
126	Toxaphene	< 0.14	0.0002	Not Available	No
	Tributyltin	< 0.0016	0.0074	< 0.001	No
	Total PAHs	Not Available	15	0.26	Ud
	<b>Ammonia <sup>[e]</sup></b>	<b>59,000</b>	<b>1505</b>	<b>100</b>	<b>Yes</b>

[a] The Maximum Effluent Concentration (MEC) and maximum background concentration are the actual detected concentrations unless preceded by a “<” sign, in which case the value shown is the minimum detection level (DL).

[b] The MEC or maximum background concentration is “Not Available” when there are no monitoring data for the constituent.

[c] RPA Results = Yes, if MEC > WQO/WQC, B > WQO/WQC and MEC is detected, or Trigger 3;

= No, if MEC and B are < WQO/WQC or all effluent data are undetected;

= Undetermined (Ud), if no criteria have been promulgated or there are insufficient data.

[d] Effluent limitations for Mercury are established by Regional Water Board Order R2-2007-0077 (*Waste Discharge Requirements For Municipal And Industrial Wastewater, Discharges of Mercury To San Francisco Bay NPDES No. CA0038849*).

[e] See section IV.C.4.d.5 of this Order for an explanation of the WQOs for ammonia.

**(1) Constituents with limited data.** The Discharger has performed sampling and analysis for the constituents listed in the CTR. This data set was used to perform the RPA. In some cases, Reasonable Potential cannot be determined because effluent data are limited, or ambient background concentrations are not available. The Discharger will continue to monitor for these constituents in the effluent using analytical methods that provide the best feasible detection limits. When additional data become available, further RPA will be conducted to determine whether to add numeric effluent limitations to this Order or to continue monitoring.

**(2) Pollutants with no Reasonable Potential.** WQBELs are not included in this Order for constituents that do not demonstrate Reasonable Potential; however, monitoring for those pollutants is still required. If concentrations of these constituents are found to have increased significantly, the Discharger is required to investigate the source(s) of the increase(s) (see provision VI.C.2.a of this Order). Remedial measures are required if the increases pose a threat to water quality in the receiving water.

Order No. 01-143 included final WQBELs for lead, nickel, zinc, 4,4-DDE, and dieldrin; however, because the current RPA showed that discharges from the Millbrae WPCP no longer demonstrate Reasonable Potential for lead, nickel, zinc, 4,4-DDE, and dieldrin, the effluent limitations for these pollutants from Order No. 01-143 are not retained. This is consistent with State Water Board Order WQ 2001-16.

#### 4. WQBEL Calculations.

##### a. Pollutants with Reasonable Potential

WQBELs were developed for the toxic and priority pollutants that were determined to have reasonable potential to cause or contribute to exceedances of the WQOs or WQC. The WQBELs were calculated based on appropriate WQOs/WQC and the appropriate procedures specified in Section 1.4 of the SIP. The WQOs or WQC used for each pollutant with Reasonable Potential are discussed below.

##### b. Dilution Credit

The SIP provides the basis for a dilution credit. The NBSU outfall is designed to achieve a minimum initial dilution of 10:1. Based on review of RMP monitoring data for San Francisco Bay, there is variability in the receiving water, and the hydrology of the receiving water is complex. Therefore, there is uncertainty regarding the representative nature of ambient background data, which is used for determination of effluent limitations. Pursuant to section 1.4.2.1 of the SIP, “dilution credit may be limited or denied on a pollutant-by-pollutant basis...” The Regional Water Board has determined that a conservative 10:1 dilution credit for non-bioaccumulative priority pollutants and a zero dilution credit for bioaccumulative pollutants are necessary for protection of beneficial uses. The detailed basis for each are explained below.

- (1) For certain bioaccumulative pollutants, dilution credit is not included in calculating the final WQBELs. This determination is based on available data on concentrations of these pollutants in aquatic organisms, sediment, and the water column. The Clean Water Act 303(d) list was updated and approved by the Regional Water Board on October 25, 2006. For Lower San Francisco Bay, the Regional Water Board placed mercury and polychlorinated biphenyls (PCBs) on the 303(d) list. The USEPA added dioxin and furan compounds, chlordane, dieldrin, and 4,4'-DDT to the 303(d) list. The reasoning for these decisions is based on the following factors that suggest there is no more assimilative capacity in San Francisco Bay for these pollutants.

Samples of tissue taken from fish in San Francisco Bay show the presence of these pollutants at concentrations greater than screening levels (*Contaminant Concentrations in Fish from San Francisco Bay*, May 1997). The Office of Environmental Health and Hazard Assessment (OEHHA) also completed a preliminary review of data in the 1994 San Francisco Bay pilot study, *Contaminated Levels in Fish Tissue from San Francisco Bay*. The results of the study also showed elevated levels of chemical contaminants in fish tissues. In December 1994, OEHHA subsequently issued an interim consumption advisory covering certain fish species in San Francisco Bay. This advisory is still in effect for exposure to sport fish that are found to be contaminated with mercury, dioxins, and pesticides (e.g., DDT).

- (2) For non-bioaccumulative constituents (except ammonia), a conservative allowance of 10:1 dilution for discharges to San Francisco Bay has been assigned for protection of beneficial uses. The 10:1 dilution allowance was granted in Order No. 01-143 and is also based on the Basin Plan's Prohibition Number 1, which prohibits discharges with

less than 10:1 dilution. Limiting the dilution credit is based on SIP provisions in Section 1.4.2, which considers the following:

- (a) A far-field background station is appropriate because the receiving water body (San Francisco Bay) is a very complex estuarine system with highly variable and seasonal upstream freshwater inflows and diurnal tidal saltwater inputs. The SIP allows background conditions to be determined on a discharge-by-discharge or water body-by-water body basis (SIP section 1.4.3). Consistent with the SIP, Regional Water Board staff chose to use a water body-by-water body basis due to inherent uncertainties in characterizing ambient background conditions in a complex estuarine system on a discharge-by-discharge basis.

The Yerba Buena Island RMP monitoring station, relative to other RMP stations, fits the guidance criteria of the SIP for establishing background conditions. The SIP requires that background water quality data be representative of the ambient receiving water that will mix with the discharge. Regional Water Board staff believes that water quality data from the Yerba Buena Island monitoring station are representative of the water that will mix with discharges from the Millbrae WPCP.

- (b) Because of the complex hydrology of San Francisco Bay, a mixing zone has not been established. There are uncertainties in accurately determining the mixing zones for each discharge. The models that have been used to predict dilution have not considered the three dimensional nature of the currents in the Estuary resulting from the interaction of tidal flushes and seasonal fresh water outflows. Being heavier and colder than fresh water, ocean salt water enters San Francisco Bay on diurnal tidal cycles, generally beneath the warmer fresh water which flows seaward during wet seasons. When these waters mix and interact, complex circulation patterns occur due to varying densities of the fresh and ocean waters. The complex patterns occur throughout the Estuary but are most prevalent in the San Pablo, Carquinez Straight, and Suisun Bay areas. The locations of this mixing and interaction change, depending on the strength of each tide and rate of delta outflow. Additionally, sediment loads to San Francisco Bay from the Central Valley change on a longer term basis, affecting the depth of different parts of San Francisco Bay and resulting in alteration of flow patterns and mixing and dilution that is achieved at an outfall.
- (c) The SIP allows limiting a mixing zone and dilution credit for persistent pollutants. Discharges to San Francisco Bay are defined by the SIP as incompletely mixed discharges; therefore, dilution credit should be determined using site specific information. Section 1.4.2.2 of the SIP specifies that the Regional Water Board shall “significantly limit a mixing zone and dilution credit as necessary to protect beneficial uses ... For example, in determining the extent of a mixing zone or dilution credit, the RWQCB shall consider the presence of pollutants in the discharge that are ... persistent.” The SIP defines persistent pollutants as “substances for which degradation or decomposition in the environment is nonexistent or very slow.” The pollutants at issue here are persistent pollutants (e.g., copper). Dilution studies that estimate actual dilution do not address the

effects of these persistent pollutants in San Francisco Bay environment, including long term effects on sediment concentrations.

- (3) For ammonia, a non-persistent pollutant, estimated actual initial dilution levels have been used to calculate the effluent limits. This is justified because ammonia is dispersed and degraded to a non-toxic state very rapidly. An engineering study on the actual dilution was performed by the Airfield Development Engineering Consultant on behalf of the NBSU and submitted on December 12, 2000. This was part of a larger study to estimate hydrodynamic impacts on San Francisco Bay by the once-proposed runway extension.

The discharge is pumped through a 60 inch pipe to a 654-foot diffuser section located approximately 5,200 feet offshore, at a depth 20 feet below mean lower low water, from Point San Bruno. The diffuser consists of 66 three-inch openings spaced 7 feet apart. At a point in the immediate vicinity of the diffuser, a 74:1 instantaneous dilution was calculated using the CORMIX model to estimate mixing of the effluent under tidal conditions. Dilution rates at other points were estimated. At a point approximately 1.5 km from the diffuser into the Bay (to the east), a dilution of 270:1 was estimated. In calculating the WQBELs (maximum daily and average monthly) the lowest dilution rate, i.e. 74:1 (or  $D = 73$ ), was used.

### c. Calculation of Pollutant-Specific WQBELs

#### (1) Copper

- (a) *Copper WQC*. The chronic and acute marine WQC for copper from the Basin Plan and the CTR are 3.1 and 4.8 micrograms per liter ( $\mu\text{g/L}$ ), respectively, expressed as dissolved metal. Regional Water Board staff converted these WQC to total recoverable metal using the site-specific translators of 0.74 (chronic) and 0.88 (acute), as recommended by the Clean Estuary Partnership's (CEP's) *North of Dumbarton Bridge Copper and Nickel Development and Selection of Final Translators* (2005). The resulting chronic water quality criterion of 4.2  $\mu\text{g/L}$  and acute water quality criterion of 5.5  $\mu\text{g/L}$  were used to perform the RPA.
- (b) *RPA Results*. This Order establishes effluent limitations for copper because the MEC of 13  $\mu\text{g/L}$  exceeds the WQC for copper, demonstrating Reasonable Potential by Trigger 1.
- (c) *Copper WQBELs*. This Order includes two sets of WQBELs for copper. They are calculated based on the CTR's WQC, and the site-specific WQOs established in the Basin Plan Amendment, Regional Water Board Resolution R2-2007-0042, based on the *Copper Site-Specific Objectives in San Francisco Bay: Proposed Basin Plan Amendment and Draft Staff Report* (dated June 6, 2007). Both sets of criteria are expressed as total recoverable metal using the site-specific translators and water effects ratio (WER) of 2.4 recommended by the CEP. The following table compares effluent limitations for copper calculated according to SIP procedures (and a coefficient of variation of 0.27) using the two sets of criteria. The limitations take into account the deep water nature of the discharge and are therefore based on an initial dilution of 10 to 1.

**Table F-11. Effluent Limitations for Copper**

Effluent Limitations for Copper		
	AMEL	MDEL
Based on CTR Criteria	71 µg/L	100 µg/L
Based on SSOs (Alternate Limits)	53 µg/L	77 µg/L

- (d) *Immediate Compliance Feasible.* Statistical analysis of effluent data for copper, collected over the period of February 2004 through January 2007, shows that the 95<sup>th</sup> percentile (11 µg/L) is less than the AMEL based on CTR criteria (71 µg/L); the 99<sup>th</sup> percentile (12 µg/L) is less than the MDEL (100 µg/L); and the mean (7.4 µg/L) is less than the long term average of the projected normal distribution of the effluent data set after accounting for effluent variability (57 µg/L). The Regional Water Board therefore concludes that immediate compliance with these effluent limitations for copper is feasible. Although the alternate limits are lower than the final limits in this Order, compliance with the alternate limits would be feasible because the 95<sup>th</sup> percentile and 99<sup>th</sup> percentile of the effluent data set, respectively, are also lower than the alternate AMEL (53 µg/L) and MDEL (77 µg/L) based on the SSOs.
- (e) *Alternate Limitations for Copper.* As described in the Basin Plan Amendment, Regional Water Board Resolution R2-2007-0042, and the *Copper Site-Specific Objectives in San Francisco Bay: Proposed Basin Plan Amendment and Draft Staff Report*, the Regional Water Board proposes to develop site-specific criteria for copper in non-ocean, marine waters of the San Francisco Bay Region. Proposed SSOs for copper are 2.5 and 3.9 µg/L as four-day and one-hour average (i.e., chronic and acute) criteria, respectively. If these SSOs for copper become effective, the final effluent limitations, calculated according to Section 1.4 of the SIP and using a WER of 2.4, would be an AMEL of 53 µg/L and an MDEL of 77 µg/L.
- (f) *Antibacksliding.* Antibacksliding requirements are satisfied as Order No. 01-143 did not include final effluent limitations for copper. The alternate limits comply with anti-backsliding requirements because Lower San Francisco Bay is not impaired by copper and water quality would not be degraded (see Fact Sheet sections III.C.6 [Antidegradation Policy] and III.C.7 [Anti-Backsliding Requirements]).
- (2) Cyanide
- (a) *Cyanide WQC.* The most stringent applicable WQC criteria for cyanide are established by the Basin Plan for protection of aquatic life in San Francisco Bay. The Basin Plan establishes site-specific objectives of 9.4 µg/L (acute) and 2.9 µg/L (chronic).
- (b) *RPA Results.* This Order establishes effluent limitations for cyanide because the MEC of 17 µg/L exceeds the governing WQC of 2.9 µg/L, demonstrating Reasonable Potential by Trigger 1.

- (c) *Cyanide WQBELs*. WQBELs for cyanide, calculated according to SIP procedures using a CV of 0.73 based on the mean and standard deviation of the effluent data set, and using the site specific objectives of 9.4 µg/L (acute) and 2.9 µg/L (chronic), are an MDEL of 44 µg/L and an AMEL of 20 µg/L.
- (d) *Immediate Compliance Feasible*. Statistical analysis of effluent cyanide data collected from February 2004 through January 2007 shows that the 95th percentile (11 µg/L) is less than the AMEL (20 µg/L); the 99th percentile (16 µg/L) is less than the MDEL (44 µg/L); and the mean (4.5 µg/L) is less than the long term average of the projected lognormal distribution of the effluent data set after accounting for effluent variability (12 µg/L). Based on this analysis, the Regional Water Board concludes that immediate compliance is feasible.
- (e) *Antibacksliding*. Antibacksliding requirements are satisfied, as Order No. 01-143 did not include final effluent limitations for cyanide.
- (3) Dioxin-TEQ

- (a) *WQC*. 40 CFR 122.44(d) provides that, where Reasonable Potential exists for a pollutant that does not have a numeric water quality criterion or objective, such as for a narrative water quality objective, WQBELs may be established by using a calculated numeric water quality criterion supplemented with other relevant information. The dioxin-TEQ WQBELs in this Order are translated from the Basin Plan's narrative WQO for bioaccumulative substances using the CTR's numeric WQO for 2,3,7,8-tetrachlorinated dibenzo-p-dioxin (2,3,7,8-TCDD) and other relevant scientific information, including USEPA guidance, as described below.

The Basin Plan narrative WQO for bioaccumulative substances states:

*Many pollutants can accumulate on particulates, in sediments, or bioaccumulate in fish and other aquatic organisms. Controllable water quality factors shall not cause a detrimental increase in concentrations of toxic substances found in bottom sediments or aquatic life. Effects on aquatic organisms, wildlife, and human health will be considered.*

Because it is the consensus of the scientific community that dioxins and furans associate with particulates, accumulate in sediments, and bioaccumulate in the fatty tissue of fish and other organisms, the Basin Plan's narrative bioaccumulation WQO is applicable to these pollutants. Elevated levels of dioxins and furans in fish tissue in San Francisco Bay demonstrate that the narrative bioaccumulation WQO is not being met. USEPA has therefore included Lower San Francisco Bay in the current 303(d) listing as impaired by dioxin and furan compounds.

The CTR establishes a numeric WQO for 2,3,7,8-TCDD of  $1.4 \times 10^{-8}$  µg/L for the protection of human health, when aquatic organisms are consumed. When the CTR was promulgated, USEPA stated its support of the regulation of other dioxin

and dioxin-like compounds through the use of toxicity equivalencies (TEQs) in NPDES permits. For California waters, USEPA stated specifically, “if the discharge of dioxin or dioxin-like compounds has reasonable potential to cause or contribute to a violation of a narrative criterion, numeric WQBELs for dioxin or dioxin-like compounds should be included in NPDES permits and should be expressed using a TEQ scheme.” [65 Fed. Reg. 31682, 31695 (2000)] This procedure, developed by the World Health Organization (WHO) in 1998, uses a set of toxicity equivalency factors (TEFs) to convert the concentration of any congener of dioxin or furan into an equivalent concentration of 2,3,7,8-TCDD. USEPA also stated that the Agency would continue to assess the risks posed by dioxin to public health and the WQC for dioxin that it had promulgated.

To determine if the discharge of dioxin or dioxin-like compounds from the Millbrae WPCP has reasonable potential to cause or contribute to a violation of the Basin Plan’s narrative bioaccumulation WQO, Regional Water Board staff used TEFs to express the measured concentrations of 16 dioxin congeners in effluent and background samples as 2,3,7,8-TCDD. These “equivalent” concentrations were then compared to the CTR numeric criterion for 2,3,7,8-TCDD ( $1.4 \times 10^{-8}$  µg/L). Although the 1998 WHO scheme includes TEFs for dioxin-like PCBs, they are not included in this Order’s version of the TEF procedure. The CTR has established a specific water quality standard for dioxin-like PCBs, and they are included in the analysis of total PCBs.

- (b) *RPA Results.* This Order establishes effluent limitations for dioxin-TEQ because the MEC ( $8.3 \times 10^{-8}$  µg/L) exceeds the CTR numeric water quality criterion for 2,3,7,8-TCDD ( $1.4 \times 10^{-8}$  µg/L). The maximum observed ambient background dioxin-TEQ concentration in San Francisco Bay ( $7.1 \times 10^{-8}$  µg/L) also exceeds the CTR numeric water quality criterion for 2,3,7,8-TCDD.
- (c) *WQBELs.* WQBELs for dioxin-TEQ, calculated using SIP procedures as guidance using a CV of 0.60, are an AMEL of  $1.4 \times 10^{-8}$  µg/L and an MDEL of  $2.8 \times 10^{-8}$  µg/L. Because dioxin-TEQ is a bioaccumulative pollutant, these limitations are calculated without dilution credit.
- (d) *Immediate Compliance Infeasible.* The Discharger’s Infeasibility Study asserts that the Millbrae WPCP cannot immediately comply with the WQBELs for dioxin-TEQ. Regional Water Board staff concurs because the MEC ( $8.3 \times 10^{-8}$  µg/L) is above the AMEL ( $1.4 \times 10^{-8}$  µg/L) and the MDEL ( $2.8 \times 10^{-8}$  µg/L).
- (e) *Interim Effluent Limitation.* Because Order 01-043 did not include a final effluent limitation for dioxin-TEQ and there is insufficient data to statistically determine a performance based interim limitation, no interim limit is proposed. Further, because the dioxin-TEQ limit implements the Basin Plan’s narrative bioaccumulation WQO, it is not subject to the SIP’s requirement for an interim limit. Instead, this Order requires further monitoring for dioxin-TEQ in effluent to support the development of a meaningful interim limitation in the future. This monitoring requirement will remain in effect for ten years following the effective



date of this Order or until the Regional Water Board adopts a limitation based on additional data.

- (f) *Antibacksliding*. Antibacksliding requirements are satisfied, as Order No. 01-143 did not include a final effluent limitation for dioxin-TEQ.

(4) Ammonia

- (a) *Ammonia WQC*. The Basin Plan contains WQOs for un-ionized ammonia of 0.025 milligrams per liter (mg/L) as an annual median, 0.16 mg/L as a maximum north of the Golden Gate Channel, and 0.4 mg/L as a maximum south of the Golden Gate Channel. Regional Water Board staff translated these WQOs from un-ionized ammonia concentrations to equivalent total ammonia concentrations (as nitrogen) since (1) sampling and laboratory methods are not available to analyze for un-ionized ammonia, and (2) the fraction of total ammonia that exists in the toxic un-ionized form depends on the pH, salinity and temperature of the receiving water. To translate the Basin Plan unionized ammonia objective, Regional Water Board staff used pH, salinity and temperature data from March 1993 to July 2001 from the Oyster Point RMP station (BB30), the nearest RMP station to the outfall. Regional Water Board staff used the following equations to determine the fraction of total ammonia in a discharge that would be converted to the toxic un-ionized form in estuarine and marine receiving waters (USEPA, 1989, Ambient Water Quality Criteria for Ammonia (Saltwater)–1989, EPA Publication No. 440/5-88-004):

$$\text{For salinity} > 10 \text{ ppt: fraction of NH}_3 = \frac{1}{1 + 10^{(pK - pH)}}$$

Where:

$$pK = 9.245 + 0.116(I) + 0.0324(298 - T) + \frac{0.0415(P)}{(T + 273)}$$

$$I = \text{the molal ionic strength of saltwater} = \frac{19.9273(S)}{(1,000 - 1.005109[S])}$$

S = Salinity (parts per thousand)

T = temperature in degrees Celsius

P = Pressure (one atmosphere)

Regional Water Board staff then used the 90<sup>th</sup> percentile and median un-ionized ammonia fractions to express the acute and chronic un-ionized ammonia WQOs, respectively, as total ammonia concentrations. Using the 90<sup>th</sup> percentile and median to express the acute and chronic un-ionized ammonia WQOs as equivalent total ammonia concentrations is consistent with USEPA guidance on translating dissolved metal WQOs to total recoverable metal WQOs (USEPA, 1996, *The Metals Translator: Guidance for Calculating a Total Recoverable Limit from a Dissolved Criterion*, EPA Publication Number 823-B-96-007). The equivalent total ammonia acute and chronic WQOs are 14.3 mg/L and 1.51 mg/L, respectively.

- (b) *RPA Results*. The SIP methodology was used to perform the RPA and to calculate effluent limitations. To set limitations for toxic pollutants, the Basin Plan (Section 4.5.5.2) indicates that WQBELs shall be calculated according to the SIP. Section 3.3.20 of the Basin Plan refers to ammonia as a toxic pollutant. Therefore, it is consistent with the Basin Plan to determine and establish effluent limitations for ammonia using SIP methodology. This Order establishes effluent limitations for total ammonia because the MEC of 59 mg/L exceeds the applicable WQO for this pollutant, demonstrating Reasonable Potential by Trigger 1.
- (c) *WQBELs*. The total ammonia WQBELs calculated according to SIP procedures are an MDEL of 160 mg/L and an AMEL of 110 mg/L. Regional Water Board staff made statistical adjustments because the Basin Plan's chronic WQO for un-ionized ammonia is based on an annual median, while chronic criteria are usually based on a 4-day average; also, the SIP assumes a monthly sampling frequency of 4 days per month to calculate effluent limitations based on chronic criteria. A 365-day average and a monitoring frequency of 30 days per month were used to calculate the total ammonia WQBELs. These statistical adjustments are supported by USEPA's *Water Quality Criteria; Notice of Availability; 1999 Update of Ambient Water Quality Criteria for Ammonia*, published on December 22, 1999, in the Federal Register.

Following SIP methodology as guidance, Regional Water Board staff used the maximum ambient background total ammonia concentration to calculate effluent limitations based on the acute criterion, and the median background total ammonia concentration to calculate effluent limitations based on the chronic criterion. Because the Basin Plan's chronic un-ionized ammonia objective is an annual median, the median background concentration is more representative of ambient conditions than a daily maximum.

- (d) *Immediate Compliance Feasible*. Statistical analysis of effluent data for total ammonia collected over the period of January 2002 through December 2006 shows that the 95<sup>th</sup> percentile (48 mg/L) is less than the AMEL (110 mg/L); the 99<sup>th</sup> percentile (54 mg/L) is less than the MDEL (160 mg/L); and the mean (38 mg/L) is less than the long-term average of the projected normal distribution of the effluent data set after accounting for effluent variability (69 mg/L). Therefore, the Regional Water Board concludes that immediate compliance with final effluent limitations for total ammonia is feasible.
- (e) *Antibacksliding*. Antibacksliding requirements are satisfied as the previous order did not include final effluent limitations for ammonia.

#### **e. Effluent Limit Calculations**

The following table shows the WQBEL calculations for copper, cyanide, dioxin-TEQ, and ammonia.

**Table F-12. Effluent Limit Calculations**

PRIORITY POLLUTANTS	Copper		Mercury	Cyanide <sup>[1]</sup>	Dioxin TEQ	Total Ammonia
Units	ug/L		ug/L		ug/L	ug/L
	BP & CTR SW Aq Life	Alternate limits using SSOs (December 2004)	BP SW Aq Life	SSOs	Basin Plan HH	Basin Plan Aq. Life
Basis and Criteria type						
CTR Criteria -Acute	5.5	-----	2.1	-----	-----	--
CTR Criteria -Chronic	4.2	-----	0.025	-----	-----	--
SSO Criteria -Acute (December 2004) (Diss.)		3.9		9.4		
SSO Criteria -Chronic (December 2004) (Diss.)		2.5		2.9		
Water Effects ratio (WER)	2.4	2.4	1	1	1	1
Lowest WQO	4.2		0.025	2.9	1.4E-08	1505
Site Specific Translator - MDEL	0.88	0.88				
Site Specific Translator - AMEL	0.74	0.74				
Dilution Factor (D) (if applicable)	9	9	0	9	0	73
No. of samples per month	4	4	4	4	4	30
Aquatic life criteria analysis required? (Y/N)	Y	Y	Y	Y	N	Y
HH criteria analysis required? (Y/N)	N	N	Y	Y	Y	N
Applicable Acute WQO	13.09	10.64	2.1	9.4		14,296
Applicable Chronic WQO	10.05	8.11	0.025	2.9		1,505
HH criteria	-----	-----	0.05	220,000	1.40E-08	0
Background (Maximum Conc for Aquatic Life calc) <sup>[2]</sup>	2.55	2.55	0.0086	0.4	7.10E-08	100
Background (Average Conc for Human Health calc)	-----	-----	0.0022	0.4	5.00E-08	--
Is the pollutant Bioaccumulative(Y/N)? (e.g., Hg)	N	N	Y	N	Y	N
ECA acute	108.0	83.4	2.1	90.4		1,050,604
ECA chronic	77.6	58.1	0.025	25.4		104,070
ECA HH			0.051	2199996.4	1.40E-08	
No. of data points <10 or at least 80% of data reported non detect? (Y/N)	N	N	N	N	Y	N
Avg of effluent data points	7.4	7.4	0.0087	4.5		38
Std Dev of effluent data points	2.0	2.0	0.0052	3.2		7.4
CV calculated	0.27	0.27	0.60	0.73	N/A	0.20
CV (Selected) - Final	0.27	0.27	0.60	0.73	0.60	0.20
ECA acute mult99	0.55	0.55	0.320	0.27		0.65
ECA chronic mult99	0.73	0.73	0.526	0.47		0.98
LTA acute	59.82	46.22	0.672	24.56		681,047
LTA chronic	57.00	42.71	0.013	11.91		101,617
minimum of LTAs	57.00	42.71	0.013	11.91		101,617
AMEL mult95	1.24	1.24	1.55	1.68	1.55	1.06
MDEL mult99	1.80	1.80	3.12	3.68	3.11	1.54
AMEL (aq life)	70.70	52.97	0.02	19.98		107,719
MDEL(aq life)	102.88	77.08	0.04	43.83		156,758
MDEL/AMEL Multiplier	1.46	1.46	2.01	2.19	2.01	1.46
AMEL (human hlth)			0.051	2199996	1.4E-08	
MDEL (human hlth)			0.102	4826245	2.8E-08	
minimum of AMEL for Aq. life vs HH	71	53	0.020	20	1.4E-08	1.1E+05
minimum of MDEL for Aq. Life vs HH	103	77	0.041	44	2.8E-08	1.6E+05
Current limit in permit (30-day average)	17 (Interim)	17 (Interim)	0.087 (Interim)	10 (Interim)	1.4E-07 (Interim)	-----
Current limit in permit (daily)	-----	-----	-----	-----	-----	-----
Final limit - AMEL	71	53	0.020	20	1.4E-08	1.1E+05
Final limit - MDEL	100	77	0.041	44	2.8E-08	1.6E+05
Max Effl Conc (MEC)	13	13	0.028	17	8.3E-08	5.9E+04

[1] WQBELs calculated based on SIP methodology do not exceed alternate limits to comply with antibacksliding policies.

[2] Median concentration used for ammonia.

## 5. Whole Effluent Acute Toxicity

The Basin Plan requires dischargers to either conduct flow-through effluent toxicity tests or perform static renewal bioassays (Chapter 4, Acute Toxicity) to measure the toxicity of wastewaters and to assess negative impacts upon water quality and beneficial uses caused by the aggregate toxic effect of the discharge of pollutants. This Order includes effluent limitations for whole effluent acute toxicity. Compliance evaluation for this Order is based on flow-through whole effluent toxicity tests, performed according to the USEPA-approved method in 40 CFR Part 136 (currently “Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms, 5<sup>th</sup> Edition.”)

If acute toxicity is observed in the future and the Discharger believes that it is due to ammonia toxicity, the Discharger must show this through a Toxicity Identification Evaluation (TIE) acceptable to the Executive Officer. If the Discharger demonstrates that toxicity exceeding the permit limit is caused by ammonia, and that the discharge is in compliance with the effluent limits, then such toxicity does not constitute a violation of the acute toxicity effluent limitation. If ammonia toxicity is verified in the TIE, the Discharger may utilize an adjustment protocol approved by the Executive Officer for the routine bioassay testing.

## 6. Whole Effluent Chronic Toxicity

This permit includes requirements for chronic toxicity monitoring based on the Basin Plan narrative toxicity objective and USEPA and State Water Board Task Force guidance. This permit includes the Basin Plan narrative toxicity objective as the applicable effluent limit, implemented via monitoring with numeric values as “triggers” to initiate accelerated monitoring and to initiate a chronic toxicity reduction evaluation (TRE) as necessary. The permit requirements for chronic toxicity are also consistent with the CTR and SIP requirements. Accelerated monitoring is required after exceeding a single-sample maximum of 10 TU<sub>c</sub>, consistent with Table 4-5 of the Basin Plan for dischargers monitoring chronic toxicity annually.

## 7. Chlorine

This Order retains the instantaneous maximum limitation for chlorine of 0.0 mg/L. This limitation is required by the Basin Plan (Table 4-2).

### **Anti-Backsliding/Antidegradation.**

- a. Effluent Limitations Retained from Order No. 01-143.** Limitations for the following parameters are retained and are unchanged from Order No. 01-143.
- Oil and grease
  - pH
  - CBOD<sub>5</sub> and TSS
  - Total residual chlorine
  - 85% removal requirement for CBOD and TSS
  - Fecal coliform bacteria

- Acute toxicity

Retaining effluent limitations for these parameters in this Order ensures that these limitations are at least as stringent as those in Order No. 01-143, meeting applicable anti-backsliding requirements of the CWA. Retaining effluent limitations for these parameters also ensures that the existing receiving water quality will not be degraded (in terms of these parameters) as a result of this Order.

- b. New Effluent Limitations.** Final, concentration-based limitations for the following parameters were not contained in Order No. 01-143 and are established by this Order.

- Enterococcus bacteria
- Copper
- Cyanide
- Dioxin-TEQ
- Ammonia

The establishment of effluent limitations for dioxin-TEQ, ammonia, and enterococcus bacteria effectively creates limitations that are more stringent than in Order No. 01-143, therefore meeting applicable anti-backsliding requirements and ensuring that the existing quality of the receiving water will not be degraded (in terms of these parameters) as a result of this Order. The copper and cyanide effluent limits in this order are new final limits. Although these new limits are higher than the interim limits in Order No. 01-143, interim limits and final limits are not comparable for purposes of complying with antibacksliding requirements. These final limits also comply with antidegradation requirements.

- c. More Stringent Effluent Limitations.** No limitations established by Order No. 01-143 are made more stringent by this Order.

- d. Effluent Limitations Not Retained from Order No. 01-143.** Final limitations for the following parameters are not retained by this Order.

- Settleable matter
- Lead
- Nickel
- Zinc
- Tetrachloroethylene
- Bis(2-ethylhexyl)phthalate
- 4,4-DDE
- Dieldrin

This Order does not retain effluent limitations for settleable matter. For the Millbrae WPCP, like other facilities achieving secondary or more advanced levels of treatment, compliance with the requirements of 40 CFR 133 and of Table 4-2 of the Basin Plan will also assure removal of settleable solids to acceptably low levels - below 0.1 mL/L-hr (30-day average) and 0.2 mL/L-hr (daily maximum).

Order No. 01-143 included final effluent limitations for lead, nickel, zinc, tetrachloroethylene, bis(2-ethylhexyl)phthalate, 4,4-DDE and dieldrin; however, because the RPA showed that discharges from the Millbrae WPCP no longer demonstrate a reasonable potential to cause or contribute to exceedances of applicable water quality criteria for these pollutants, this Order does not retain these limitations from Order No. 01-143. Elimination of WQBELs for lead, nickel, zinc, tetrachloroethylene, bis(2-ethylhexyl)phthalate, 4,4-DDE and dieldrin is consistent with State Water Board Order WQ 2001-16.

#### **D. Interim Effluent Limitations**

The Discharger has shown the infeasibility of immediately complying with final limitations for dioxin-TEQ and has demonstrated that a compliance schedule for this constituent is justified based on the Discharger's source control and pollution minimization efforts in the past and continued efforts in the present and future.

1. **Feasibility Evaluation.** The Discharger submitted an infeasibility to comply report for Discharge Point E-001, dated May 23, 2008, for dioxin-TEQ (Infeasibility Report). The Infeasibility Report asserts that the Discharger cannot immediately comply with final WQBELs for dioxin-TEQ. Regional Water Board staff used the Discharger's self-monitoring data from June 2002 to November 2006 for dioxin-TEQ to confirm the Discharger's assertion of infeasibility.

With insufficient effluent data to determine the distribution of the effluent data set or to calculate a mean and standard deviation, and significant variability in the data, feasibility to comply with final effluent limitations is determined by comparing the MEC ( $8.3 \times 10^{-8}$   $\mu\text{g/L}$ ) to the AMEL ( $1.4 \times 10^{-8}$   $\mu\text{g/L}$ ) and the MDEL ( $2.8 \times 10^{-8}$   $\mu\text{g/L}$ ). Based on this comparison, the Regional Water Board concurs with the Discharger's assertion of infeasibility to comply with final WQBELs for dioxin-TEQ

2. **Determination of Interim Effluent Limitations.** Because Order 01-043 did not include a final effluent limitation for dioxin-TEQ and there is insufficient data to statistically determine a performance based interim limitation, no interim limit is proposed. Further, because the dioxin-TEQ limit implements the Basin Plan's narrative bioaccumulation WQO, it is not subject to the SIP's requirement for an interim limit. Instead, this Order requires further monitoring for dioxin-TEQ in effluent to support the development of a meaningful interim limitation. This monitoring requirement will remain in effect for ten years following the effective date of this Order or until the Regional Water Board adopts a limitation based on additional data.
3. **Compliance Schedule**
  - a. The SIP and the Basin Plan authorize compliance schedules in a permit if an existing Discharger cannot immediately comply with a new and more stringent water quality objective. Compliance schedules for limitations derived from CTR WQC are based on Section 2.2 of the SIP, and compliance schedules for limitations derived from Basin Plan narrative water quality objectives are based on the Basin Plan. Both the SIP and the

Basin Plan require the Discharger to demonstrate the infeasibility of achieving immediate compliance with the new limitation to qualify for a compliance schedule.

The SIP and Basin Plan require the following documentation to be submitted to the Regional Water Board to support a finding of infeasibility:

- Descriptions of diligent efforts the Discharger have made to quantify pollutant levels in the discharge, sources of the pollutant in the waste stream, and the results of those efforts.
- Descriptions of source control and/or pollutant minimization efforts currently under way or completed.
- A proposed schedule for additional or future source control measures, pollutant minimization, or waste treatment.
- A demonstration that the proposed schedule is as short as practicable.

The Basin Plan provides for a 10-year compliance schedule to implement measures to comply with new standards as of the effective date of those standards. Additionally, the provision authorizes compliance schedules for new interpretations of other existing standards if the new interpretation results in more stringent limitations.

- c. As previously described, the Discharger submitted an Infeasibility Report, and the Regional Water Board staff confirmed its assertions.
- d. A maximum compliance schedule is reasonable for dioxin-TEQ, because of the considerable uncertainty in determining effective measures (e.g., pollution prevention, treatment upgrades) that should be implemented to ensure compliance with final limitations. In the Regional Water Board’s view, it is appropriate to allow the Discharger sufficient time to explore source control measures before requiring it to propose further actions, such as treatment plant upgrades, that are likely to be much more costly. This approach is supported by the Basin Plan (section 4.13), which states, “In general, it is often more economical to reduce overall pollutant loading into treatment systems than to install complex and expensive technology at the plant.”

During the compliance schedule periods, the Regional Water Board may take appropriate enforcement actions if interim limitations and requirements are not met.

#### **E. Land Discharge Specifications**

Not Applicable.

#### **F. Reclamation Specifications**

Not applicable

## V. RATIONALE FOR RECEIVING WATER LIMITATIONS

Receiving water limitations are retained from Order No. 01-143 and reflect applicable water quality standards from the Basin Plan.

## VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

The principal purposes of a monitoring program by a discharger are to:

- Document compliance with waste discharge requirements and prohibitions established by the Regional Water Board,
- Facilitate self-policing by the discharger in the prevention and abatement of pollution arising from waste discharge,
- Develop or assist in the development of limitations, discharge prohibitions, national standards of performance, pretreatment and toxicity standards, and other standards, and to
- Prepare water and wastewater quality inventories.

The MRP is a standard requirement in almost all NPDES permits issued by the Regional Water Board, including this Order. It contains definitions of terms, specifies general sampling and analytical protocols, and sets out requirements for reporting of spills, violations, and routine monitoring data in accordance with NPDES regulations, the CWC, and Regional Water Board's policies. The MRP also defines the sampling stations and frequency, the pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all parameters for which effluent limitations are specified. Monitoring for additional constituents, for which no effluent limitations are established, is also required to provide data for future completion of RPAs for them.

### A. Influent Monitoring

Influent monitoring requirements for CBOD<sub>5</sub> and TSS allows determination of compliance with this Order's 85 percent removal requirement.

### B. Effluent Monitoring

The MRP retains most effluent monitoring requirements from the previous permit. Changes in effluent monitoring are summarized as follows.

- Monitoring for settleable matter is no longer required, as the effluent limitation for this parameter has not been retained by this Order.
- Routine effluent monitoring for copper, cyanide, and dioxin-TEQ (priority toxic pollutants with effluent limitations established by this Order) is required. Monitoring for all other priority toxic pollutants must be conducted in accordance with frequency and methods described in the August 6, 2001 Letter. Routine effluent monitoring for ammonia and enterococcus bacteria is also required.



- Monitoring for and compliance with final effluent chlorine residual requirements at E-002 is the City of South San Francisco's responsibility as part of their NBSU Outfall duties and authorities.

### **C. Bypasses or Sewer Overflow Monitoring**

Monitoring to record observations related to bypasses or sewer overflows is required by the Self-Monitoring Plan Part A (Attachment G).

### **D. Whole Effluent Toxicity Testing Requirements**

1. **Acute Toxicity.** Monthly 96-hour bioassay testing is required to demonstrate compliance with the effluent limitation for acute toxicity.
2. **Chronic Toxicity.** Chronic whole effluent toxicity testing is required annually in order to demonstrate compliance with the Basin Plan's narrative toxicity objective.

### **E. Receiving Water Monitoring**

On April 15, 1992, the Regional Water Board adopted Resolution No. 92-043 directing the Executive Officer to implement the RMP for San Francisco Bay. Subsequent to a public hearing and various meetings, Regional Water Board staff requested under authority of section 13267 of CWC that major permit holders in the San Francisco Bay region report on the water quality of the San Francisco Estuary. These permit holders responded to this request by participating in a collaborative effort through the San Francisco Estuary Institute known as the San Francisco Bay Regional Monitoring Program for Trace Substances, or RMP. This Order specifies that the Discharger shall continue to participate in the RMP, which involves collection of data on pollutants and toxicity in water, sediment, and biota of the estuary.

### **F. Other Monitoring Requirements**

Not applicable

## **VII. RATIONALE FOR PROVISIONS**

### **A. Standard Provisions (Provision VI.A)**

Standard Provisions, which in accordance with 40 CFR 122.41 and 122.42 apply to all NPDES discharges and must be included in every NPDES permit, are provided in Attachments D and G through H of this Order.

### **B. Monitoring and Reporting Requirements (Provision VI.B)**

The Discharger is required to monitor the permitted discharges in order to evaluate compliance with permit conditions. Monitoring requirements are contained in the MRP (Attachment E), Standard Provisions and SMP, Part A (Attachment G), of this Order. This provision requires compliance with these documents and is based on 40 CFR 122.63. The Standard Provisions and SMP, Part A, are standard requirements in almost all NPDES permits issued by the Regional Water Board, including this Order. They contain definitions of terms, specify general sampling and analytical protocols, and set out requirements for reporting of spills, violations, and routine monitoring data in

accordance with NPDES regulations, the CWC, and Regional Water Board's policies. The MRP contains a sampling program specific for the Millbrae WPCP. It defines the sampling stations and frequency, the pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all parameters for which effluent limitations are specified. Monitoring for additional constituents, for which no effluent limitations are established, is also required to provide data for future completion of RPAs for them.

## **C. Special Provisions (Provision VI.C)**

### **1. Reopener Provisions**

These provisions are based on 40 CFR 123 and allow modification of this Order and its effluent limitations as necessary in response to updated WQOs that may be established in the future.

### **2. Special Studies and Additional Monitoring Requirements**

- a. Effluent Characterization Study. This Order does not include effluent limitations for the selected constituents addressed in the August 6, 2001 Letter that do not demonstrate Reasonable Potential, but this provision requires the Discharger to continue monitoring for these pollutants as described in the August 6, 2001 Letter and as specified in the MRP of this Order. If concentrations of these constituents increase significantly, the Discharger will be required to investigate the source of the increases and establish remedial measures if the increases result in reasonable potential to cause or contribute to an excursion above the applicable WQO/WQC. This provision is based on the Basin Plan and the SIP.
- b. Ambient Background Receiving Water Study. This provision is based on the Basin Plan, the SIP, and the August 6, 2001 Letter for priority pollutant monitoring. As indicated in this Order, this requirement may be met by participating in a collaborative BACWA study.
- c. Optional Mass Offset Plan: This option is provided to encourage the Discharger to further implement aggressive reduction of mass loads to Lower San Francisco Bay. If the Discharger wishes to pursue a mass offset program, a mass offset plan for reducing 303(d) listed pollutants to the same receiving water body needs to be submitted for Regional Water Board approval. The Regional Water Board will consider any proposed mass offset plan and amend this Order accordingly.

### **3. Best Management Practices and Pollution Minimization Program**

This provision is based on Chapter 4 of the Basin Plan and Section 2.4.5 of the SIP.

### **4. Construction, Operation, and Maintenance Specifications**

- a. Wastewater Facilities, Review and Evaluation, Status Reports: This provision is based on Order No. 01-143 and the Basin Plan. See Section VI.C.10 of this Order for specific requirements.

- b. Operations and Maintenance Manual, Review and Status Reports: This provision is based on the Basin Plan, the requirements of 40 CFR 122, and Order No. 01-143. See Section VI.C.10 of this Order for specific requirements.
- c. Contingency Plan, Review and Status Reports: This provision is based on the Basin Plan, the requirements of 40 CFR 122, and Order No. 01-143. See Section VI.C.10 of this Order for specific requirements.

## 5. Special Provisions for Municipal Facilities (POTWs Only)

- a. Sanitary Sewer Overflows and Sewer System Management Plan: This provision is to explain this Order's requirements as they relate to the Discharger's conveyance system, and to promote consistency with the State Water Board-adopted Statewide General Waste Discharge Requirements for Sanitary Sewer Overflow (SSO WDRs) and a related Monitoring and Reporting Program (Order No. 2006-0003-DWQ). The bases for these requirements are described elsewhere in this Fact Sheet. See Section VI.C.11 of this Order for specific requirements.

## 6. Compliance Schedule

The compliance schedule and the requirement to submit reports on further measures to reduce concentrations of dioxin-TEQ to ensure compliance with final limits are based on the Basin Plan Section 4.7.6. Because of the ubiquitous nature of the sources of dioxin-TEQ, this provision allows the Dischargers to address compliance with calculated WQBELs through other strategies such as mass offsets.

## VIII. PUBLIC PARTICIPATION

The San Francisco Bay Regional Water Board is considering the issuance of WDRs that will serve as an NPDES permit for City of Millbrae WPCP. As a step in the WDR adoption process, the Regional Water Board has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

### A. Notification of Interested Parties

The Regional Water Board has notified the Dischargers and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Notification was provided through the **San Mateo County Times**.

### B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments must be submitted either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order, Attention: John Madigan.

To be fully responded to by staff and considered by the Regional Water Board, written comments should be received at the Regional Water Board offices by 5:00 p.m. on **July 18, 2008**.

### **C. Public Hearing**

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: **August 13, 2008**  
Time: 9:00 am  
Location: Elihu Harris State Office Building  
1515 Clay Street, 1<sup>st</sup> Floor Auditorium  
Oakland, CA 94612

Contact: John Madigan, (510) 622-2405, email [jmadigan@waterboards.ca.gov](mailto:jmadigan@waterboards.ca.gov)

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is <http://www.waterboards.ca.gov/sanfranciscobay> where you can access the current agenda for changes in dates and locations.

### **D. Waste Discharge Requirements Petitions**

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board  
Office of Chief Counsel  
P.O. Box 100, 1001 I Street  
Sacramento, CA 95812-0100

### **E. Information and Copying**

The (ROWD), related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., except from noon to 1:00 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling 510-622-2300.

### **F. Register of Interested Persons**

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference the Millbrae WPCP, and provide a name, address, and phone number.

### **G. Additional Information**

Requests for additional information or questions regarding this order should be directed to John Madigan at 510-622-2405 (e-mail at [JMadigan@waterboards.ca.gov](mailto:JMadigan@waterboards.ca.gov)).

## ATTACHMENT H - PRETREATMENT REQUIREMENTS

### Pretreatment Program Provisions

1. The Discharger shall implement all pretreatment requirements contained in 40 CFR 403, as amended. The Discharger shall be subject to enforcement actions, penalties, and fines as provided in the Clean Water Act (33 USC 1351 et seq.), as amended. The Discharger shall implement and enforce its Approved Pretreatment Program or modified Pretreatment Program as directed by the Board's Executive Officer or the EPA. The EPA and/or the State may initiate enforcement action against an industrial user for noncompliance with applicable standards and requirements as provided in the Clean Water Act.
2. The Discharger shall enforce the requirements promulgated under Sections 307(b), 307(c), 307(d) and 402(b) of the Clean Water Act. The Discharger shall cause industrial users subject to Federal Categorical Standards to achieve compliance no later than the date specified in those requirements or, in the case of a new industrial user, upon commencement of the discharge.
3. The Discharger shall perform the pretreatment functions as required in 40 CFR Part 403 and amendments or modifications thereto including, but not limited to:
  - i) Implement the necessary legal authorities to fully implement the pretreatment regulations as provided in 40 CFR 403.8(f)(1);
  - ii) Implement the programmatic functions as provided in 40 CFR 403.8(f)(2);
  - iii) Publish an annual list of industrial users in significant noncompliance as provided per 40 CFR 403.8(f)(2)(vii);
  - iv) Provide for the requisite funding and personnel to implement the pretreatment program as provided in 40 CFR 403.8(f)(3); and
  - v) Enforce the national pretreatment standards for prohibited discharges and categorical standards as provided in 40 CFR 403.5 and 403.6, respectively.
4. The Discharger shall submit annually a report to the EPA Region 9, the State Board and the Regional Water Board describing its pretreatment program activities over the previous twelve months. In the event that the Discharger is not in compliance with any conditions or requirements of the Pretreatment Program, the Discharger shall also include the reasons for noncompliance and a plan and schedule for achieving compliance. The report shall contain, but is not limited to, the information specified in Appendix A entitled, "Requirements for Pretreatment Annual Reports," which is made a part of this Order. The annual report is due on the last day of February each year.
5. The Discharger shall submit semiannual pretreatment reports to the EPA Region 9, the State Board and the Board describing the status of its significant industrial users (SIUs). The report shall contain, but not is limited to, the information specified in Appendix B entitled, "Requirements for Semiannual

Pretreatment Reports,” which is made part of this Order. The semiannual reports are due July 31<sup>st</sup> (for the period January through June) and January 31<sup>st</sup> (for the period July through December) of each year. The Executive Officer may exempt a Discharger from the semiannual reporting requirements on a case by case basis subject to State Board and EPA’s comment and approval.

6. The Discharger may combine the annual pretreatment report with the semiannual pretreatment report (for the July through December reporting period). The combined report shall contain all of the information requested in Appendices A and B and will be due on January 31<sup>st</sup> of each year.
7. The Discharger shall conduct the monitoring of its treatment plant’s influent, effluent, and sludge as described in Appendix C entitled, “Requirements for Influent, Effluent and Sludge Monitoring,” which is made part of this Order. The results of the sampling and analysis, along with a discussion of any trends, shall be submitted in the semiannual reports. A tabulation of the data shall be included in the annual pretreatment report. The Executive Officer may require more or less frequent monitoring on a case by case basis.

**APPENDIX A****REQUIREMENTS FOR PRETREATMENT ANNUAL REPORTS**

The Pretreatment Annual Report is due each year on the last day of February. [If the annual report is combined with the semiannual report (for the July through December period) the submittal deadline is January 31<sup>st</sup> of each year.] The purpose of the Annual Report is 1) to describe the status of the Publicly Owned Treatment Works (POTW) pretreatment program and 2) to report on the effectiveness of the program, as determined by comparing the results of the preceding year's program implementation. The report shall contain at a minimum, but is not limited to, the following information:

**1) Cover Sheet**

The cover sheet must contain the name(s) and National Pollutant Discharge Elimination System (NPDES) permit number(s) of those POTWs that are part of the Pretreatment Program. Additionally, the cover sheet must include: the name, address and telephone number of a pretreatment contact person; the period covered in the report; a statement of truthfulness; and the dated signature of a principal executive officer, ranking elected official, or other duly authorized employee who is responsible for overall operation of the POTW (40 CFR 403.12(j)).

**2) Introduction**

The Introduction shall include any pertinent background information related to the Discharger, the POTW and/or the industrial user base of the area. Also, this section shall include an update on the status of any Pretreatment Compliance Inspection (PCI) tasks, Pretreatment Performance Evaluation tasks, Pretreatment Compliance Audit (PCA) tasks, Cleanup and Abatement Order (CAO) tasks, or other pretreatment-related enforcement actions required by the Regional Water Board or the EPA. A more specific discussion shall be included in the section entitled, "Program Changes."

**3) Definitions**

This section shall contain a list of key terms and their definitions that the Discharger uses to describe or characterize elements of its pretreatment program.

**4) Discussion of Upset, Interference and Pass Through**

This section shall include a discussion of Upset, Interference or Pass Through incidents, if any, at the POTW(s) that the Discharger knows of or suspects were caused by industrial discharges. Each incident shall be described, at a minimum, consisting of the following information:

- a) a description of what occurred;
- b) a description of what was done to identify the source;
- c) the name and address of the IU responsible
- d) the reason(s) why the incident occurred;
- e) a description of the corrective actions taken; and
- f) an examination of the local and federal discharge limits and requirements for the purposes of determining whether any additional limits or changes to existing requirements may be necessary to prevent other Upset, Interference or Pass Through incidents.

5) **Influent, Effluent and Sludge Monitoring Results**

This section shall provide a summary of the analytical results from the “Influent, Effluent and Sludge Monitoring” as specified in Appendix C. The results should be reported in a summary matrix that lists monthly influent and effluent metal results for the reporting year.

A graphical representation of the influent and effluent metal monitoring data for the past five years shall also be provided with a discussion of any trends.

6) **Inspection and Sampling Program**

This section shall contain at a minimum, but is not limited to, the following information:

- a) Inspections: the number of inspections performed for each type of IU; the criteria for determining the frequency of inspections; the inspection format procedures;
- b) Sampling Events: the number of sampling events performed for each type of IU; the criteria for determining the frequency of sampling; the chain of custody procedures.

7) **Enforcement Procedures**

This section shall provide information as to when the approved Enforcement Response Plan (ERP) had been formally adopted or last revised. In addition, the date the finalized ERP was submitted to the Regional Water Board shall also be given.

8) **Federal Categories**

This section shall contain a list of all of the federal categories that apply to the Discharger. The specific category shall be listed including the subpart and 40 CFR section that applies. The maximum and average limits for the each category shall be provided. This list shall indicate the number of Categorical Industrial Users (CIUs) per category and the CIUs that are being regulated pursuant to the category. The information and data used to determine the limits for those CIUs for which a combined waste stream formula is applied shall also be provided.



9) **Local Standards**

This section shall include a table presenting the local limits.

10) **Updated List of Regulated SIUs**

This section shall contain a complete and updated list of the Discharger's Significant Industrial Users (SIUs), including their names, addresses, and a brief description of the individual SIU's type of business. The list shall include all deletions and additions keyed to the list as submitted in the previous annual report. All deletions shall be briefly explained.

11) **Compliance Activities**

- a) **Inspection and Sampling Summary:** This section shall contain a summary of all the inspections and sampling activities conducted by the Discharger over the past year to gather information and data regarding the SIUs. The summary shall include:
- (1) the number of inspections and sampling events conducted for each SIU;
  - (2) the quarters in which these activities were conducted; and
  - (3) the compliance status of each SIU, delineated by quarter, and characterized using all applicable descriptions as given below:
    - (a) in consistent compliance;
    - (b) in inconsistent compliance;
    - (c) in significant noncompliance;
    - (d) on a compliance schedule to achieve compliance, (include the date final compliance is required);
    - (e) not in compliance and not on a compliance schedule;
    - (f) compliance status unknown, and why not.
- b) **Enforcement Summary:** This section shall contain a summary of the compliance and enforcement activities during the past year. The summary shall include the names of all the SIUs affected by the following actions:

- (1) Warning letters or notices of violations regarding SIUs' apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements. For each notice, indicate whether it was for an infraction of a federal or local standard/limit or requirement.
- (2) Administrative Orders regarding the SIUs' apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements. For each notice, indicate whether it was for an infraction of a federal or local standard/limit or requirement.
- (3) Civil actions regarding the SIUs' apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements. For each notice, indicate whether it was for an infraction of a federal or local standard/limit or requirement.
- (4) Criminal actions regarding the SIUs' apparent noncompliance with or violation of any federal pretreatment categorical standards and/or requirements, or local limits and/or requirements. For each notice, indicate whether it was for an infraction of a federal or local standard/limit or requirement.
- (5) Assessment of monetary penalties. Identify the amount of penalty in each case and reason for assessing the penalty.
- (6) Order to restrict/suspend discharge to the POTW.
- (7) Order to disconnect the discharge from entering the POTW.

## 12) **Baseline Monitoring Report Update**

This section shall provide a list of CIUs that have been added to the pretreatment program since the last annual report. This list of new CIUs shall summarize the status of the respective Baseline Monitoring Reports (BMR). The BMR must contain all of the information specified in 40 CFR 403.12(b). For each of the new CIUs, the summary shall indicate when the BMR was due; when the CIU was notified by the POTW of this requirement; when the CIU submitted the report; and/or when the report is due.

## 13) **Pretreatment Program Changes**

This section shall contain a description of any significant changes in the Pretreatment Program during the past year including, but not limited to: legal authority, local limits, monitoring/ inspection program and frequency, enforcement protocol, program's administrative structure, staffing level, resource requirements and funding mechanism. If the manager of the pretreatment program changes, a revised organizational chart shall be included. If any element(s) of the program is in the process of being modified, this intention shall also be indicated.

**14) Pretreatment Program Budget**

This section shall present the budget spent on the Pretreatment Program. The budget, either by the calendar or fiscal year, shall show the amounts spent on personnel, equipment, chemical analyses and any other appropriate categories. A brief discussion of the source(s) of funding shall be provided.

**15) Public Participation Summary**

This section shall include a copy of the public notice as required in 40 CFR 403.8(f)(2)(vii). If a notice was not published, the reason shall be stated.

**16) Sludge Storage and Disposal Practice**

This section shall have a description of how the treated sludge is stored and ultimately disposed. The sludge storage area, if one is used, shall be described in detail. Its location, a description of the containment features and the sludge handling procedures shall be included.

**17) PCS Data Entry Form**

The annual report shall include the PCS Data Entry Form. This form shall summarize the enforcement actions taken against SIUs in the past year. This form shall include the following information: the POTW name, NPDES Permit number, period covered by the report, the number of SIUs in significant noncompliance (SNC) that are on a pretreatment compliance schedule, the number of notices of violation and administrative orders issued against SIUs, the number of civil and criminal judicial actions against SIUs, the number of SIUs that have been published as a result of being in SNC, and the number of SIUs from which penalties have been collected.

**18) Other Subjects**

Other information related to the Pretreatment Program that does not fit into one of the above categories should be included in this section.

Signed copies of the reports shall be submitted to the Regional Administrator at USEPA, the State Water Resources Control Board and the Regional Water Board at the following addresses:

Regional Administrator  
United States Environmental Protection Agency  
Region 9, Mail Code: WTR-7

Clean Water Act Compliance Office

Water Division

75 Hawthorne Street

San Francisco, CA 94105

Pretreatment Program Manager

Regulatory Unit

State Water Resources Control Board

Division of Water Quality

1001 I Street

Sacramento, CA 95814

Pretreatment Coordinator

NPDES Permits Division

SF Bay Regional Water Quality Control Board

1515 Clay Street, Suite 1400

Oakland, CA 94612

**APPENDIX B:****REQUIREMENTS FOR SEMIANNUAL PRETREATMENT REPORTS**

The semiannual pretreatment reports are due on July 31<sup>st</sup> (for pretreatment program activities conducted from January through June) and January 31<sup>st</sup> (for pretreatment activities conducted from July through December) of each year, unless an exception has been granted by the Board's Executive Officer. The semiannual reports shall contain, at a minimum, but is not limited to, the following information:

**1) Influent, Effluent and Sludge Monitoring**

The influent, effluent and sludge monitoring results shall be included in the report. The analytical laboratory report shall also be included, with the QA/QC data validation provided upon request. A description of the sampling procedures and a discussion of the results shall be given. (Please see Appendix C for specific detailed requirements.) The contributing source(s) of the parameters that exceed NPDES limits shall be investigated and discussed. In addition, a brief discussion of the contributing source(s) of all organic compounds identified shall be provided.

The Discharger has the option to submit all monitoring results via an electronic reporting format approved by the Executive Officer. The procedures for submitting the data will be similar to the electronic submittal of the NPDES self-monitoring reports as outlined in the December 17, 1999 Regional Water Board letter, Official Implementation of Electronic Reporting System (ERS). The Discharger shall contact the Regional Water Board's ERS Project Manager for specific details in submitting the monitoring data.

If the monitoring results are submitted electronically, the analytical laboratory reports (along with the QA/QC data validation) should be kept at the Discharger's facility.

**2) Industrial User Compliance Status**

This section shall contain a list of all Significant Industrial Users (SIUs) that were not in consistent compliance with all pretreatment standards/limits or requirements for the reporting period. The compliance status for the previous reporting period shall also be included. Once the SIU has determined to be out of compliance, the SIU shall be included in the report until consistent compliance has been achieved. A brief description detailing the actions that the SIU undertook to come back into compliance shall be provided.

For each SIU on the list, the following information shall be provided:

- a. Indicate if the SIU is subject to Federal categorical standards; if so, specify the category including the subpart that applies.

- b. For SIUs subject to Federal Categorical Standards, indicate if the violation is of a categorical or local standard.
- c. Indicate the compliance status of the SIU for the two quarters of the reporting period.
- d. For violations/noncompliance occurring in the reporting period, provide (1) the date(s) of violation(s); (2) the parameters and corresponding concentrations exceeding the limits and the discharge limits for these parameters and (3) a brief summary of the noncompliant event(s) and the steps that are being taken to achieve compliance.

### 3) **POTW's Compliance with Pretreatment Program Requirements**

This section shall contain a discussion of the Discharger's compliance status with the Pretreatment Program Requirements as indicated in the latest Pretreatment Compliance Audit (PCA) Report, Pretreatment Compliance Inspection (PCI) Report or Pretreatment Performance Evaluation (PPE) Report. It shall contain a summary of the following information:

- a. Date of latest PCA, PCI or PPE and report.
- b. Date of the Discharger's response.
- c. List of unresolved issues.
- d. Plan and schedule for resolving the remaining issues.

The reports shall be signed by a principal executive officer, ranking elected official, or other duly authorized employee who is responsible for the overall operation of the Publicly Owned Treatment Works (POTW)(40 CFR 403.12(j)). Signed copies of the reports shall be submitted to the Regional Administrator at USEPA, the State Water Resources Control Board and the Regional Water Board at the following addresses:

Regional Administrator

United States Environmental Protection Agency

Region 9, Mail Code: WTR-7

Clean Water Act Compliance Office

Water Division

75 Hawthorne Street

San Francisco, CA 94105

Pretreatment Program Manager

Regulatory Unit

State Water Resources Control Board

Division of Water Quality

1001 I Street

Sacramento, CA 95814

Pretreatment Coordinator  
NPDES Permits Division  
SF Bay Regional Water Quality Control Board  
1515 Clay Street, Suite 1400  
Oakland, CA 94612

## APPENDIX C

### REQUIREMENTS FOR INFLUENT, EFFLUENT AND SLUDGE MONITORING

The Discharger shall conduct sampling of its treatment plant's influent, effluent and sludge at the frequency as shown in Table E-5 of the Self-Monitoring Program (SMP).

The monitoring and reporting requirements of the POTW's Pretreatment Program are in addition to those specified in Tables E-3 and E-4 of the SMP. Any subsequent modifications of the requirements specified in Tables E-3 and E-4 shall be adhered to and shall not affect the requirements described in this Appendix unless written notice from the Regional Water Board is received. When sampling periods coincide, one set of test results, reported separately, may be used for those parameters that are required to be monitored by both Table E-5 and the Pretreatment Program. The Pretreatment Program monitoring reports shall be sent to the Pretreatment Program Coordinator.

#### 1. Influent and Effluent Monitoring

The Discharger shall monitor for the parameters using the required test methods listed in Tables E-3 and E-4 of the SMP. Any test method substitutions must have received prior written Regional Water Board approval. Influent and Effluent sampling locations shall be the same as those sites specified in the Self-Monitoring Program.

The influent and effluent sampled should be taken during the same 24-hour period. All samples must be representative of daily operations. A grab sample shall be used for volatile organic compounds, cyanide and phenol. In addition, any samples for oil and grease, polychlorinated biphenyls, dioxins/furans, and polynuclear aromatic hydrocarbons shall be grab samples. For all other pollutants, 24-hour composite samples must be obtained through flow-proportioned composite sampling. Sampling and analysis shall be performed in accordance with the techniques prescribed in 40 CFR Part 136 and amendments thereto. For effluent monitoring, the reporting limits for the individual parameters shall be at or below the minimum levels (MLs) as stated in the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (2000) [also known as the State Implementation Policy (SIP)]; any revisions to the MLs shall be adhered to. If a parameter does not have a stated minimum level, then the Discharger shall conduct the analysis using the lowest commercially available and reasonably achievable detection levels.

The following standardized report format should be used for submittal of the influent and effluent monitoring report. A similar structured format may be used but will be subject to Regional Water Board approval. The monitoring reports shall be submitted with the Semiannual Reports.

- A. Sampling Procedures – This section shall include a brief discussion of the sample locations, collection times, how the sample was collected (i.e., direct collection using vials or bottles, or other types of collection using devices such as automatic samplers, buckets, or beakers), types of containers used, storage procedures and holding times. Include description of prechlorination and chlorination/dechlorination practices during the sampling periods.



- B. Method of Sampling Dechlorination – A brief description of the sample dechlorination method prior to analysis shall be provided.
- C. Sample Compositing – The manner in which samples are composited shall be described. If the compositing procedure is different from the test method specifications, a reason for the variation shall be provided.
- D. Data Validation – All quality assurance/quality control (QA/QC) methods to be used shall be discussed and summarized. These methods include, but are not limited to, spike samples, split samples, blanks and standards. Ways in which the QA/QC data will be used to qualify the analytical test results shall be identified. A certification statement shall be submitted with this discussion stating that the laboratory QA/QC validation data has been reviewed and has met the laboratory acceptance criteria. The QA/QC validation data shall be submitted to the Regional Water Board upon request.
- E. A tabulation of the test results shall be provided.
- F. Discussion of Results – The report shall include a complete discussion of the test results. If any pollutants are detected in sufficient concentration to upset, interfere or pass through plant operations, the type of pollutant(s) and potential source(s) shall be noted, along with a plan of action to control, eliminate, and/or monitor the pollutant(s). Any apparent generation and/or destruction of pollutants attributable to chlorination/dechlorination sampling and analysis practices shall be noted.

## 2. **Sludge Monitoring**

Sludge should be sampled in the same 24-hour period during which the influent and effluent are sampled except as noted in (C) below. The same parameters required for influent and effluent analysis shall be included in the sludge analysis. The sludge analyzed shall be a composite sample of the sludge for final disposal consisting of:

- A. Sludge lagoons – 20 grab samples collected at representative equidistant intervals (grid pattern) and composited as a single grab, or
- B. Dried stockpile – 20 grab samples collected at various representative locations and depths and composited as a single grab, or
- C. Dewatered sludge- daily composite of 4 representative grab samples each day for 5 days taken at equal intervals during the daily operating shift taken from a) the dewatering units or b) from each truckload, and shall be combined into a single 5-day composite.

The U.S. EPA manual, POTW Sludge Sampling and Analysis Guidance Document, August 1989, containing detailed sampling protocols specific to sludge is recommended as a guidance for sampling procedures. The U.S. EPA manual Analytical Methods of the National Sewage Sludge Survey, September 1990, containing detailed analytical protocols specific to sludge, is recommended as a guidance for analytical methods.

In determining if the sludge is a hazardous waste, the Dischargers shall adhere to Article 2, "Criteria for Identifying the Characteristics of Hazardous Waste," and Article 3, "Characteristics of Hazardous Waste," of Title 22, California Code of Regulations, Sections 66261.10 to 66261.24 and all amendments thereto.

Sludge monitoring reports shall be submitted with the appropriate Semiannual Report. The following standardized report format should be used for submittal of the report. A similarly structured form may be used but will be subject to Regional Water Board approval.

- A. Sampling procedures – Include sample locations, collection procedures, types of containers used, storage/refrigeration methods, compositing techniques and holding times. Enclose a map of sample locations if sludge lagoons or stockpiled sludge is sampled.
- B. Data Validation – All quality assurance/quality control (QA/QC) methods to be used shall be discussed and summarized. These methods include, but are not limited to, spike samples, split samples, blanks and standards. Ways in which the QA/QC data will be used to qualify the analytical test results shall be identified. A certification statement shall be submitted with this discussion stating that the laboratory QA/QC validation data has been reviewed and has met the laboratory acceptance criteria. The QA/QC validation data shall be submitted to the Regional Water Board upon request.
- C. Test Results – Tabulate the test results and include the percent solids.
- D. Discussion of Results – The report shall include a complete discussion of test results. If the detected pollutant(s) is reasonably deemed to have an adverse effect on sludge disposal, a plan of action to control, eliminate, and/or monitor the pollutant(s) and the known or potential source(s) shall be included. Any apparent generation and/or destruction of pollutants attributable to chlorination/ dechlorination sampling and analysis practices shall be noted.

The Discharger shall also provide any influent, effluent or sludge monitoring data for nonpriority pollutants that the permittee believes may be causing or contributing to Interference, Pass Through or adversely impacting sludge quality.

## **APPENDIX B**

### **Comments**

**City of Millbrae Water Pollution Control Plant  
Comments Regarding Tentative Order for Renewal of NPDES Permit**

**July 17, 2008**

The City of Millbrae (City) appreciates the opportunity to submit the following comments on the Tentative Order (TO) reissuing the National Pollutant Discharge Elimination System (NPDES) permit for the discharge of treated wastewater to San Francisco Bay. The City would also like to commend your staff for their diligence and care in preparing these documents. Due to variations in formatting, page numbers listed are approximate.

**COMMENTS ON NPDES PERMIT**

**1. Proposed State criteria should not be used to develop water quality-based effluent limitations.**

(Page 5)

For section G, Water Quality-based Effluent Limitations, the reference to “a proposed state criterion” should be removed since a proposed state criteria may not be used under state law. Using a “proposed” state criteria before formal adoption would be considered underground rulemaking.

**2. The City requests that the dioxin-TEQ final limits be removed.**

(Page 10)

The City requests that the dioxin-TEQ numeric final effluent limits be removed because there is no approved numeric water quality objective for dioxin-TEQ. The congeners detected in the fish tissue samples which form the basis for the dioxin 303(d) listing and the congeners detected in publicly-owned treatment works are different. The City’s effluent characteristics for dioxin-TEQ indicate that it is not feasible to meet these limits. There is no value in developing a numerical standard at this time since dioxin at these levels can not even be measured. The recognized source of dioxin is air emissions and combustion. The City does not have the authority to control or prevent these sources.

**3. Chronic toxicity monitoring frequency requirements should be consistent throughout the permit.**

The following edit should be made for consistency with Table E-4, which requires annual chronic toxicity monitoring:

(Page F-36)

**2. Chronic Toxicity.** Chronic whole effluent toxicity testing is required ~~semiannually~~ annually in order to demonstrate compliance with the Basin Plan's narrative toxicity objective.

**4. The compliance schedule action plan for dioxin-TEQ is neither realistic nor commensurate with actual water quality impacts.**

(Page 25)

The congeners detected in fish tissue samples which form the basis for the dioxin 303(d) listing are different than the congeners detected in publicly-owned treatment works. As a result, there is nothing a municipal wastewater treatment plant could do to its effluent to reduce the concentrations of dioxin congeners found in fish tissue, which is the basis for these requirements.

Although an optional offset provision (as described in Task 5) may provide an alternative to compliance with a final effluent limit for dioxin-TEQ, such a program does not currently exist. Until such a program that includes a feasible implementation strategy is developed, the City believes this is not a realistic alternative and it is misleading to expect that such a program would lead to compliance.

For these reasons, the City requests that the compliance schedule for dioxin-TEQ be removed, along with the final limit.

**5. The City requests a monitoring frequency requirement for enterococcus of once per month.**

(Page E-4)

The Tentative Order provides no monitoring frequency for Enterococcus. The City believes that monthly enterococcus sampling is sufficient to verify compliance with the new limit. Additionally, the City also requests approval of the IDEXX Enterolert method for monitoring enterococcus.

In particular, the City requests the following edits:

**Table E-4. Effluent Monitoring**

Parameter	Units	Minimum Sampling Frequency			Required Analytical Test Method
		Continuous	C-24	G	
Flow Rate <sup>(2)</sup>	MGD	Cont/D			(1)
Oil and Grease <sup>(3)</sup>	mg/L			M	(1)
pH <sup>(4)</sup>	s.u.			3/W	(1)
CBOD <sub>5</sub> <sup>(5)</sup>	mg/L		3/W		(1)
TSS <sup>(5)</sup>	mg/L		3/W		(1)
Acute Toxicity <sup>(6)</sup>	% survival		M		(1)
Chlorine, Total Residual <sup>(7)</sup>	mg/L	Cont or 1/2h			(1)
Chronic Toxicity <sup>(8)</sup>	TUc		Y		(1)
Dissolved Oxygen	mg/L			3/W	(1)
Fecal Coliform Bacteria	MPN/100mL			2/W	(1)
Enterococci Bacteria <sup>(12)</sup>	MPN/100mL			M	(1)
Temperature	°C			3/W	(1)
Ammonia (total as N)	mg/L			M	(1)
Copper	µg/L		M		(1)
Cyanide	µg/L			M	(1)(11)
Dioxin-TEQ	µg/L			2/Y	(1)
Remaining Priority Pollutants	µg/L		2/Y <sup>(9)(10)</sup>		(1)

(12) The Discharger shall monitor for Enterococci using EPA-approved methods, including the IDEXX Enterolert method.

**6. The City requests the following revisions to the Cyanide Action Plan implementation to meet the intent of the Basin Plan amendment:**

- The cyanide action plan should be contingent on the site-specific objective becoming fully effective.
- RMP data should be used for tracking ambient cyanide concentrations, where applicable.

**7. The City requests the following revision to the Copper Action Plan implementation:**

- The City believes implementation of the copper action plan should be contingent on the site-specific objective becoming fully effective.

**8. The City requests that the below noted language be returned to the Fact Sheet's Ambient Background Data description to be consistent with other Bay-Area POTW permits.**

(Page F-18)

On May 15, 2003, a group of several San Francisco Bay Region dischargers (known as the Bay Area Clean Water Agencies, or BACWA) submitted a collaborative receiving water study, entitled the *San Francisco Bay Ambient Water Monitoring Interim Report* (2003). This study includes monitoring results from sampling events in 2002 and 2003 for the remaining priority pollutants not monitored by the RMP. The RPA was conducted and the WQBELs were calculated using RMP data from 1993 through 2003 for inorganics and organics at the Yerba Buena Island RMP station, and additional data from BACWA's *Ambient Water Monitoring: Final CTR Sampling Update* (2004) for the Yerba Buena Island RMP station. The Dischargers may use this study to fulfill all requirements of the August 6, 2001 Letter for receiving water monitoring.

**9. The City requests that the following language additions and deletions be made to the Monitoring and Reporting Program and the Fact Sheet relative to ammonia toxicity in the acute bioassay.**

(Page E-5)

4. The Discharger has demonstrated that ammonia is quickly dispersed and degraded to a non-toxic state rendering it harmless. This demonstration was made in an engineering study on the actual dilution occurring at the NBSU outfall diffuser performed by the Airfield Development Engineering Consultant on behalf of the NBSU and submitted to the Regional Water Board on December 12, 2000. Therefore, compliance with the acute toxicity limit maybe determined after the test samples have been adjusted to remove the influence of ammonia. If specific identifiable substances in the discharge can be demonstrated by the Discharger as being rapidly rendered harmless upon discharge to the receiving water, compliance with the acute toxicity limit may be determined after the test samples are adjusted to remove the influence of those substances. Written approval from the Executive Officer must be obtained to authorize such an adjustment.

(Page F-31)

4. The Discharger has demonstrated that ammonia is quickly dispersed and degraded to a non-toxic state rendering it harmless in the environment. This demonstration was made in an engineering study on the actual dilution occurring at the NBSU outfall diffuser performed by the Airfield Development Engineering Consultant on behalf of the NBSU and submitted to the Regional Water Board on December 12, 2000. Therefore, compliance with the acute toxicity limit may be determined after the test samples have been adjusted to remove the influence of ammonia. If the Discharger can demonstrate to the satisfaction of the Executive Officer that toxicity exceeding the levels cited above is caused by ammonia and that the ammonia in the discharge is not adversely impacting receiving water quality or beneficial uses, then such toxicity does not constitute a violation of this effluent limitation.

These revisions are based on the Basin Plan, page 3-4 under "Un-Ionized Ammonia."

**10. The City requests the following language change in the Monitoring and Reporting Program relative to reporting of water quality parameters analyzed in the acute bioassay.**

Significant revisions to the Regional Water Board’s electronic reporting system would be required for the discharger to fully comply with reporting these daily analyses with the analytical result.

(Page E-5)

5. Effluent used for fish bioassays must be dechlorinated prior to testing. Monitoring of the bioassay water shall include, on a daily basis, the following parameters: pH, dissolved oxygen, ammonia (if toxicity is observed), temperature, hardness, and alkalinity. These results shall be ~~reported~~ recorded and maintained with all other analytical documents. If a violation of acute toxicity requirements occurs or if the control fish survival rate is less than 90 percent, the bioassay test shall be restarted with new batches of fish. Bioassay tests shall continue back to back until compliance is demonstrated.

**11. The City objects to the required procedure for the invalidation of data points.**

(Page E-12)

The City objects to the language used to require correction of errors in data reporting. Human errors occur occasionally in data reporting. Inferring a time limit on the discovery and correction of these errors is confusing. The City understands that Regional Water Board staff will consider erroneously reported data points at any time when sufficient information is available, although they prefer that it be taken care of promptly.

*“g. If the Discharger wishes to invalidate any measurement, the letter of transmittal ~~will~~ should include identification of the measurement suspected to be invalid and notification of intent to submit; ~~within a specified schedule 60 days,~~ a formal request to invalidate the measurement; The formal request will include the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports the invalidation (e.g., laboratory sheet, log entry, test results, etc.), and discussion of the corrective actions taken or planned (with a time schedule for completion), to prevent recurrence of the sampling or measurement problem”.*

**12. The City requests that the following typographical errors be corrected:**

(Page H-12)

The Discharger shall conduct sampling of its treatment plant’s influent, effluent and sludge at the frequency as shown in Table E-~~65~~ of the Self-Monitoring Program (SMP).

(Page E-4)

Insert the characters “1/” before the “Y” for Chronic Toxicity monitoring frequency to be consistent with information in abbreviation key.



**Table E-4. Effluent Monitoring**

Parameter	Units	Minimum Sampling Frequency			Required Analytical Test Method
		Continuous	C-24	G	
Flow Rate <sup>(2)</sup>	MGD	Cont/D			(1)
Oil and Grease <sup>(3)</sup>	mg/L			M	(1)
pH <sup>(4)</sup>	s.u.			3/W	(1)
CBOD <sub>5</sub> <sup>(5)</sup>	mg/L		3/W		(1)
TSS <sup>(5)</sup>	mg/L		3/W		(1)
Acute Toxicity <sup>(6)</sup>	% survival		M		(1)
Chlorine, Total Residual <sup>(7)</sup>	mg/L	Cont or 1/2h			(1)
Chronic Toxicity <sup>(8)</sup>	TUc		<u>1</u> /Y		(1)
Dissolved Oxygen	mg/L			3/W	(1)
Fecal Coliform Bacteria	MPN/100mL			2/W	(1)
Temperature	°C			3/W	(1)
Ammonia (total as N)	mg/L			M	(1)
Copper	µg/L		M		(1)
Cyanide	µg/L			M	(1)(11)
Dioxin-TEQ	µg/L			2/Y	(1)
Remaining Priority Pollutants	µg/L		2/Y <sup>(9)</sup> (10)		(1)



# Bay Area Clean Water Agencies

Leading the Way to Protect Our Bay

A Joint Powers Public Agency

P.O. Box 24055, MS 702

Oakland, California 94623

July 14, 2007

**VIA EMAIL AND FACSIMILE: (510) 622-2460**

Mr. John H. Madigan  
San Francisco Bay Regional Water Quality Control Board  
1515 Clay Street, Suite 1400  
Oakland, CA 94612

**Subject: Comments on Tentative Order Reissuing the City of Millbrae Water Pollution Control Plant Discharge Permit, NPDES Permit (CA0037532)**

Dear Mr. Madigan:

The Bay Area Clean Water Agencies (BACWA) appreciate the opportunity to comment on the Tentative Order (TO) for the City of Millbrae (City), as well as make comments on policy issues related to the NPDES permit. BACWA members own and operate publicly-owned treatment works (POTWs) that discharge to San Francisco Bay and its tributaries. Collectively, BACWA members serve over 6.5 million people in the nine-county Bay Area, treating domestic, commercial and industrial wastewater. BACWA was formed to develop a region-wide understanding of the watershed protection and enhancement needs through reliance on sound technical, scientific, environmental and economic information and to ensure that this understanding leads to long-term stewardship of the San Francisco Bay Estuary. BACWA member agencies are public agencies, governed by elected officials and managed by professionals who are dedicated to protecting our water environment and the public health.

BACWA hopes that the following comments will result in changes made to the tentative order prior to issuance of the final NPDES permit for the City. Further, in order to avoid repetition, but to preserve these arguments, BACWA supports and incorporates by reference the comments made by the City in its comment letters.

## **1. BACWA objects to including numeric final limits for dioxin-TEQ.**

BACWA requests that the dioxin-TEQ numeric final effluent limits be removed because there is no approved numeric water quality objective for dioxin-TEQ, it is unclear that the City will be able to meet this limit, and there are no analytical methods that can accurately detect dioxins at these levels. BACWA believes that the Regional Water Board has the discretion to maintain the narrative standard that exists in the San Francisco Bay Basin Plan.

There is no value in developing a numerical standard at this time since dioxin at these levels cannot be measured. The dioxin sources are air emissions and combustion, neither of which the City or any BACWA member agency can control or prevent.

**2. The compliance schedule action plan for dioxin-TEQ is neither realistic nor commensurate with actual water quality impacts, and overly burdensome.**

It is highly unlikely that compliance schedule action plan activities will result in compliance with proposed final limits. Although an optional offset provision (as described in Task 7) may provide an alternative to compliance with a final effluent limit for dioxin-TEQ, such a program does not currently exist. Even though the Regional Water Board directed Regional Water Board staff to develop such a program, there do not appear to be any plans in place. Until such a program is developed with a feasible implementation strategy, BACWA believes this is not a realistic alternative and it is misleading to expect that such a program would lead to compliance.

**3. If the Regional Water Board retains the Cyanide Action Plan in this permit, it should be revised in several ways.**

BACWA believes these revisions to the Cyanide Action Plan are necessary to meet the intent of the Basin Plan amendment:

- The cyanide action plan should be contingent on the site-specific objective becoming fully effective.
- RMP data should be used for tracking ambient cyanide concentrations, where applicable.

**4. If the Regional Water Board retains the Copper Action Plan in this permit, its implementation should be revised:**

- BACWA believes implementation of the copper action plan should be contingent on the site-specific objective becoming fully effective.

**5. BACWA objects to the required procedure for the invalidation of data points.**

BACWA objects to the language used to require correction of errors in data reporting. Human errors occur occasionally in data reporting. Inferring a time limit on the discovery and correction of these errors is confusing. We understand that Regional Water Board staff will consider erroneously reported data points at any time when sufficient information is available, although they prefer that it be taken care of promptly. But the confusing nature of this language (reproduced below) means that some agencies will not understand this subtle point.

*“g. If the Discharger wishes to invalidate any measurement, the letter of transmittal should include identification of the measurement suspected to be invalid and notification of intent to submit the corrected data within a specified schedule, and a*

- Deleted: will
- Deleted: *submi*
- Deleted: t
- Deleted: ,
- Deleted: 60 days
- Formatted: Font color: Blue
- Formatted: Font color: Blue

formal request to invalidate the measurement. The formal request will include the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports the invalidation (e.g., laboratory sheet, log entry, test results, etc.), and discussion of the corrective actions taken or planned (with a time schedule for completion), to prevent recurrence of the sampling or measurement problem".

Deleted: ,

**6. BACWA requests a clarification regarding sanitary sewer overflow requirements.**

BACWA requests the following edit to section IV.A.5 of the Fact Sheet. Language in this section is not consistent with the correct reference in Prohibition III.E of the permit and should be revised as follows:

5. **Discharge Prohibition III.E (No sanitary sewer overflows to waters of the United States).** Sanitary sewer overflows that result in the discharge of raw or partially treated sewage not meeting secondary treatment requirements to waters of the United States is prohibited under the Clean Water Act and the Basin Plan. Discharge Prohibition No. 15 from Table 4-1 of the Basin Plan, and the Clean Water Act prohibit the discharge of wastewater to surface waters except as authorized under an NPDES permit. POTWs must achieve secondary treatment, at a minimum, and any more stringent limitations necessary to achieve water quality standards (33U.S.C. §1311(b)(1)(B) and (C)).

Deleted: surface waters

BACWA appreciates the Regional Water Board's close attention to the comments made herein. I would be more than happy to meet with you to discuss our comments and concerns in more detail as you wish.

Respectfully submitted,



Michele Pla  
BACWA Executive Director

cc: BACWA Executive Board  
Robert Cole, BACWA Permits Committee Chair  
Lila Tang, Regional Water Board  
Bill Johnson, Regional Water Board

## **APPENDIX C**

### **Response to Comments**

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN FRANCISCO BAY REGION**

**RESPONSE TO WRITTEN COMMENTS**

ON THE REISSUANCE OF NPDES PERMIT FOR:

City of Millbrae Water Pollution Control Plant and collection system  
400 East Millbrae Avenue  
Millbrae, CA 94030  
NPDES Permit No. CA0037532

- 
- I. City of Millbrae – July 17, 2008**  
**II. Bay Area Clean Water Agencies – July 14, 2008**  
**III. Staff Revisions**

Note: The format of this staff response begins with quotes from the party’s comments, followed with staff’s response. Interested persons should refer to the original letters to ascertain the full substance and context of each comment. Text changes are shown using underline for added text and ~~strikethrough~~ for deleted text.

---

**I. City of Millbrae**

The City of Millbrae submitted twelve comments.

City of Millbrae Comment 1.

***Proposed State criteria should not be used to develop water quality-based effluent limitations.***

*(Page 5)*

*For section G, Water Quality-based Effluent Limitations, the reference to “a proposed state criterion” should be removed since a proposed state criteria may not be used under state law. Using a “proposed” state criteria before formal adoption would be considered underground rulemaking.*

Response 1.

Section II.G of all of the Regional Water Board’s NPDES permits contains this reference to “a proposed state criterion.” We have not removed this reference because it is consistent with CFR 122.44(d)(1)(vi), as referenced in Section II.G of the Tentative Order (TO). Specifically, CFR 122.44.(d)(1)(vi) states that, regarding establishment of effluent limits for pollutants with reasonable potential to cause or contribute to an excursion above a narrative criterion, a calculated numeric water quality criterion may be used. It further states, “Such a criterion may be derived using **a proposed State criterion** [emphasis added], or an explicit State policy or regulation interpreting its narrative water quality criterion ....”

City of Millbrae Comment 2.

***The City requests that the dioxin-TEQ final limits be removed.***

*(Page 10)*

*The City requests that the dioxin-TEQ numeric final effluent limits be removed because there is no approved numeric water quality objective for dioxin-TEQ. The congeners detected in the fish tissue samples which form the basis for the dioxin 303(d) listing and the congeners detected in publicly-owned treatment works are different. The City's effluent characteristics for dioxin-TEQ indicate that it is not feasible to meet these limits. There is no value in developing a numerical standard at this time since dioxin at these levels can not even be measured. The recognized source of dioxin is air emissions and combustion. The City does not have the authority to control or prevent these sources.*

Response 2.

The numeric effluent limits for dioxin-TEQ are reasonable and appropriate. We derived them in accordance with 40 CFR 122.44(d)(1)(vi) (see our response to City of Millbrae Comment 1); they are based on the CTR objective for 2,3,7,8-TCDD and other relevant information. The TO includes dioxin-TEQ effluent limits because State and federal laws and regulations require them. By adopting the dioxin-TEQ limits, the Regional Water Board is complying with regulations implementing the Clean Water Act at 40 CFR 122.44(d), which require that permits include effluent limits for all pollutants that may be discharged at levels with a reasonable potential to cause or contribute to exceedances of water quality standards, including narrative objectives, such as the Basin Plan's bioaccumulation objective. The Basin Plan states, "Water quality-based effluent limitations will consist of narrative requirements and, where appropriate, numerical limits for the protection of the most sensitive beneficial uses of the receiving water."

Dioxin and similar compounds have bioaccumulated in San Francisco Bay fish in violation of the Basin Plan's narrative bioaccumulation water quality objective. Therefore, a numeric effluent limit is appropriate to protect San Francisco Bay's beneficial uses, which the bioaccumulation objective is intended to preserve. We used Toxic Equivalency Factors (TEFs) published by USEPA and the World Health Organization, together with the CTR water quality objective for 2,3,7,8-TCDD (the most toxic of the dioxins) to translate the Basin Plan's narrative bioaccumulation objective into numeric water quality-based effluent limits.

We do not intend to enforce compliance with the dioxins limits in situations where we cannot determine whether the limits are exceeded. However, neither 40 CFR 122.44(d) nor the Basin Plan allows consideration of whether analytical methods can actually measure dioxin-TEQ at concentrations as low as the limits. The Basin Plan states, "...when pollutant concentrations in waters are relatively low, the limits of quantification will be taken into account in determining compliance with, rather than the calculation of, effluent limits." Following this policy and the State Implementation Policy's Minimum Level (ML) concept, we developed effluent limits consistent with the water quality objective. We will use analysis-based Minimum Levels for compliance determination and enforcement.

We recognize that the ultimate sources of most dioxins in San Francisco Bay are mostly combustion-related air emissions, and that these sources are outside of the City of Millbrae's

direct control. In the context of the Basin Plan’s narrative bioaccumulation objective, however, we disagree that dioxins cannot be controlled. The Basin Plan states, “Controllable water quality factors are those actions, conditions, or circumstances resulting from human activities that may influence the quality of the waters of the State and that may be reasonably controlled.” USEPA concluded that dioxins are controllable when it placed San Francisco Bay on the 303(d) list of impaired waters due to dioxin concentrations in fish and other aquatic organisms. Air emissions, which are created through combustion, are a source of dioxins, but wastewater treatment plants are also sources of dioxins discharged to San Francisco Bay. Dioxins in wastewater are primarily a result of human activity and their discharge to waters can be controlled by removing solids from wastewater (dioxins are hydrophobic and bind to particles). Additional dioxin removal could result from plant upgrades. This could be burdensome and may not be cost effective at this time; however, such actions could be necessary to control dioxin discharges in the future.

City of Millbrae Comment 3.

***Chronic toxicity monitoring frequency requirements should be consistent throughout the permit.***

*The following edit should be made for consistency with Table E-4, which requires annual chronic toxicity monitoring:*

*(Page F-36)*

- 2. Chronic Toxicity.*** *Chronic whole effluent toxicity testing is required ~~semiannually~~ annually in order to demonstrate compliance with the Basin Plan’s narrative toxicity objective.*

Response 3.

We have revised the Fact Sheet as requested.

City of Millbrae Comment 4.

***The compliance schedule action plan for dioxin-TEQ is neither realistic nor commensurate with actual water quality impacts.***

*(Page 25)*

*The congeners detected in fish tissue samples which form the basis for the dioxin 303(d) listing are different than the congeners detected in publicly-owned treatment works. As a result, there is nothing a municipal wastewater treatment plant could do to its effluent to reduce the concentrations of dioxin congeners found in fish tissue, which is the basis for these requirements.*

*Although an optional offset provision (as described in Task 5) may provide an alternative to compliance with a final effluent limit for dioxin-TEQ, such a program does not currently exist. Until such a program that includes a feasible implementation strategy is developed, the City believes this is not a realistic alternative and it is misleading to expect that such a program would lead to compliance.*



*For these reasons, the City requests that the compliance schedule for dioxin-TEQ be removed, along with the final limit.*

Response 4

Though the dioxin congeners in San Francisco Bay fish tissue have a different profile (i.e., greater variety of congeners) than those in wastewater, the OCDD and OCDF congeners are found in both. USEPA's 303(d) listing of dioxins included OCDD and OCDF because they contributed to the basis for the listing. Furthermore, the dioxin-TEQ scheme toxicity-weights dioxin congeners so that the dioxin toxicity in different media, in this case wastewater versus fish tissue, can be compared directly even if the congeners present are different. When USEPA listed the fish tissue as impaired, it did so based on dioxin toxicity, and did not distinguish among the congeners. The preamble to the CTR and subsequent USEPA correspondence indicates that it prefers that we use the dioxin-TEQ scheme to address dioxins and furans in implementing the bioaccumulation objective through permit limits.

We acknowledge that a formal mass offset program does not currently exist. The TO refers to such a program simply as one possible means to overcome any technical infeasibility in meeting the dioxin-TEQ limits.

City of Millbrae Comment 5.

***The City requests a monitoring frequency requirement for enterococcus of once per month.***

*(Page E-4)*

*The Tentative Order provides no monitoring frequency for Enterococcus. The City believes that monthly enterococcus sampling is sufficient to verify compliance with the new limit. Additionally, the City also requests approval of the IDEXX Enterolert method for monitoring enterococcus.*

*In particular, the City requests the following edits:*

**Table E-4. Effluent Monitoring**

Parameter	Units	Minimum Sampling Frequency			Required Analytical Test Method
		Continuous	C-24	G	
Flow Rate <sup>(2)</sup>	MGD	Cont/D			(1)
Oil and Grease <sup>(3)</sup>	mg/L			M	(1)
pH <sup>(4)</sup>	s.u.			3/W	(1)
CBOD <sub>5</sub> <sup>(5)</sup>	mg/L		3/W		(1)
TSS <sup>(5)</sup>	mg/L		3/W		(1)
Acute Toxicity <sup>(6)</sup>	% survival		M		(1)
Chlorine, Total Residual <sup>(7)</sup>	mg/L	Cont or 1/2h			(1)
Chronic Toxicity <sup>(8)</sup>	TUc		Y		(1)
Dissolved Oxygen	mg/L			3/W	(1)
Fecal Coliform Bacteria	MPN/100mL			2/W	(1)
<u>Enterococci Bacteria</u> <sup>(12)</sup>	<u>MPN/100mL</u>			<u>M</u>	<u>(1)</u>
Temperature	°C			3/W	(1)
Ammonia (total as N)	mg/L			M	(1)
Copper	µg/L		M		(1)
Cyanide	µg/L			M	(1) (11)
Dioxin-TEQ	µg/L			2/Y	(1)
Remaining Priority Pollutants	µg/L		2/Y <sup>(9) (10)</sup>		(1)

*(12) The Discharger shall monitor for Enterococci using EPA-approved methods, including the IDEXX Enterolert method.*

**Response 5.**

We have made the requested revisions.

**City of Millbrae Comment 6.**

**The City requests the following revisions to the Cyanide Action Plan implementation to meet the intent of the Basin Plan amendment:**

- The cyanide action plan should be contingent on the site-specific objective becoming fully effective.
- RMP data should be used for tracking ambient cyanide concentrations, where applicable.

**Response 6.**

Our responses to the above points are as follows:

- Since the cyanide SSO has been approved by USEPA as of July 22, 2008, and is now fully effective, this comment is moot.

- We intend to impose regional monitoring for cyanide in 2009 and will use the data generated to evaluate if ambient concentrations exceed the trigger concentration; the provision as written allows for flexibility.

City of Millbrae Comment 7.

***The City requests the following revision to the Copper Action Plan implementation:***

- *The City believes implementation of the copper action plan should be contingent on the site-specific objective becoming fully effective.*

Response 7.

The copper action plan must be implemented when this permit takes effect to comply with antidegradation requirements. The copper effluent limits in the TO are higher than those in the previous Permit. To ensure that the higher limits do not result in water quality degradation, we included the requirement to implement the Copper Action Plan immediately. In doing so, we are relying on the same rationale set forth in the Copper SSO Staff Report's antidegradation analysis, which found that higher copper limits will not cause water quality degradation if dischargers control copper influent to their treatment plants by implementing Copper Action Plans.

City of Millbrae Comment 8:

***The City requests that the below noted language be returned to the Fact Sheet's Ambient Background Data description to be consistent with other Bay-Area POTW permits.***

*(Page F-18)*

*On May 15, 2003, a group of several San Francisco Bay Region dischargers (known as the Bay Area Clean Water Agencies, or BACWA) submitted a collaborative receiving water study, entitled the San Francisco Bay Ambient Water Monitoring Interim Report (2003). This study includes monitoring results from sampling events in 2002 and 2003 for the remaining priority pollutants not monitored by the RMP. The RPA was conducted and the WQBELs were calculated using RMP data from 1993 through 2003 for inorganics and organics at the Yerba Buena Island RMP station, and additional data from BACWA's Ambient Water Monitoring: Final CTR Sampling Update (2004) for the Yerba Buena Island RMP station. The Dischargers may use this study to fulfill all requirements of the August 6, 2001 Letter for receiving water monitoring.*

Response 8.

We have revised the TO as requested.

City of Millbrae Comment 9.

***The City requests that the following language additions and deletions be made to the Monitoring and Reporting Program and the Fact Sheet relative to ammonia toxicity in the acute bioassay.***

(Page E-5)

4. The Discharger has demonstrated that ammonia is quickly dispersed and degraded to a non-toxic state rendering it harmless. This demonstration was made in an engineering study on the actual dilution occurring at the NBSU outfall diffuser performed by the Airfield Development Engineering Consultant on behalf of the NBSU and submitted to the Regional Water Board on December 12, 2000. Therefore, compliance with the acute toxicity limit may be determined after the test samples have been adjusted to remove the influence of ammonia. If specific identifiable substances in the discharge can be demonstrated by the Discharger as being rapidly rendered harmless upon discharge to the receiving water, compliance with the acute toxicity limit may be determined after the test samples are adjusted to remove the influence of those substances. Written approval from the Executive Officer must be obtained to authorize such an adjustment.

(Page F-31)

4. The Discharger has demonstrated that ammonia is quickly dispersed and degraded to a non-toxic state rendering it harmless in the environment. This demonstration was made in an engineering study on the actual dilution occurring at the NBSU outfall diffuser performed by the Airfield Development Engineering Consultant on behalf of the NBSU and submitted to the Regional Water Board on December 12, 2000. Therefore, compliance with the acute toxicity limit may be determined after the test samples have been adjusted to remove the influence of ammonia. If the Discharger can demonstrate to the satisfaction of the Executive Officer that toxicity exceeding the levels cited above is caused by ammonia and that the ammonia in the discharge is not adversely impacting receiving water quality or beneficial uses, then such toxicity does not constitute a violation of this effluent limitation.

*These revisions are based on the Basin Plan, page 3-4 under "Un-Ionized Ammonia."*

#### Response 9.

We have not made the requested revisions; approval by the Executive Officer is still required to adjust acute toxicity effluent samples prior to analysis. This approach is consistent with other Region 2 permits and necessary because the City has not yet made a satisfactory case for this adjustment. The Executive Officer could approve the adjustment in the future, however, if for example, information were submitted showing that an acute toxicity result is caused solely by ammonia. Nevertheless, we have revised Fact Sheet Section IV.C.5, "Whole Effluent Acute Toxicity," as follows:

If acute toxicity is observed in the future and the Discharger believes that it is due to ammonia toxicity, the Discharger must show this through a Toxicity Identification Evaluation (TIE) acceptable to the Executive Officer. If the Discharger can demonstrate to the satisfaction of the Executive Officer that toxicity exceeding the levels cited above permit limit is caused by ammonia, and that the ammonia in the discharge is not adversely impacting receiving water quality or beneficial uses in compliance with effluent limits, then such toxicity does not constitute a violation of this the acute toxicity effluent limitation. This is based on the Basin Plan, at page 3-4 under "Un-Ionized Ammonia." If ammonia

toxicity is verified in the TIE, the Discharger may utilize an adjustment protocol approved by the Executive Officer for the routine bioassay testing.

City of Millbrae Comment 10.

**The City requests the following language change in the Monitoring and Reporting Program relative to reporting of water quality parameters analyzed in the acute bioassay.**

*Significant revisions to the Regional Water Board's electronic reporting system would be required for the discharger to fully comply with reporting these daily analyses with the analytical result.*

(Page E-5)

5. *Effluent used for fish bioassays must be dechlorinated prior to testing. Monitoring of the bioassay water shall include, on a daily basis, the following parameters: pH, dissolved oxygen, ammonia (if toxicity is observed), temperature, hardness, and alkalinity. These results shall be ~~reported~~ recorded and maintained with all other analytical documents. If a violation of acute toxicity requirements occurs or if the control fish survival rate is less than 90 percent, the bioassay test shall be restarted with new batches of fish. Bioassay tests shall continue back to back until compliance is demonstrated.*

Response 10.

We have revised the TO as requested.

City of Millbrae Comment 11.

**The City objects to the required procedure for the invalidation of data points.** *The City objects to the language used to require correction of errors in data reporting. Human errors occur occasionally in data reporting. Inferring a time limit on the discovery and correction of these errors is confusing. The City understands that Regional Water Board staff will consider erroneously reported data points at any time when sufficient information is available, although they prefer that it be taken care of promptly.*

(Page E-12)

*"g. If the Discharger wishes to invalidate any measurement, the letter of transmittal ~~will~~ should include identification of the measurement suspected to be invalid and notification of intent to submit; within a specified schedule ~~60 days~~, a formal request to invalidate the measurement.; The formal request will include the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports the invalidation (e.g., laboratory sheet, log entry, test results, etc.), and discussion of the corrective actions taken or planned (with a time schedule for completion), to prevent recurrence of the sampling or measurement problem"*.

Response 11.

We have not made the requested changes. The permit as written is consistent with other recently reissued permits, including Order R2-2008-0088 for the City of Burlingame Wastewater Treatment Facility, Orders R2-2007-0058 and -0060 for the San Francisco Airport sanitary and industrial wastewater treatment plants (all of which are NBSU facilities), and the revisions made

at BACWA’s request to Order R2-2008-0014 for the City of Benicia Wastewater Treatment Plant.

City of Millbrae Comment 12.

**The City requests that the following typographical errors be corrected:**

(Page H-12)

*The Discharger shall conduct sampling of its treatment plant’s influent, effluent and sludge at the frequency as shown in Table E-65 of the Self-Monitoring Program (SMP).*

(Page E-4)

*Insert the characters “1/” before the “Y” for Chronic Toxicity monitoring frequency to be consistent with information in abbreviation key.*

**Table E-4. Effluent Monitoring**

Parameter	Units	Minimum Sampling Frequency			Required Analytical Test Method
		Continuous	C-24	G	
Flow Rate <sup>(2)</sup>	MGD	Cont/D			(1)
Oil and Grease <sup>(3)</sup>	mg/L			M	(1)
pH <sup>(4)</sup>	s.u.			3/W	(1)
CBOD <sub>5</sub> <sup>(5)</sup>	mg/L		3/W		(1)
TSS <sup>(5)</sup>	mg/L		3/W		(1)
Acute Toxicity <sup>(6)</sup>	% survival		M		(1)
Chlorine, Total Residual <sup>(7)</sup>	mg/L	Cont or 1/2h			(1)
Chronic Toxicity <sup>(8)</sup>	TUc		1/Y		(1)
Dissolved Oxygen	mg/L			3/W	(1)
Fecal Coliform Bacteria	MPN/100mL			2/W	(1)
Temperature	°C			3/W	(1)
Ammonia (total as N)	mg/L			M	(1)
Copper	µg/L		M		(1)
Cyanide	µg/L			M	(1) (11)
Dioxin-TEQ	µg/L			2/Y	(1)
Remaining Priority Pollutants	µg/L		2/Y <sup>(9) (10)</sup>		(1)

Response 12.

We have made the re requested revisions.

## II. Bay Area Clean Water Agencies (BACWA)

BACWA submitted six comments.

### BACWA Comment 1.

***BACWA objects to including numeric final effluent limits for dioxin-TEQ. BACWA requests that the dioxin-TEQ numeric final effluent limits be removed because there is no approved numeric water quality objective for dioxin-TEQ, it is unclear that the City will be able to meet this limit, and there are no analytical methods can accurately detect dioxins at these levels. BACWA believes that the Regional Water Board has the discretion to maintain the narrative standard that exists in the San Francisco Bay Basin Plan. There is no value in developing a numerical standard at this time since dioxin at these levels cannot be measured. The dioxin sources are air emissions and combustion, neither of which the City or any BACWA member agency can control or prevent.***

### Response to Comment 1.

The City of Millbrae provided essentially the same comment. Please see our response to City of Millbrae Comment 2.

### BACWA Comment 2.

***The compliance schedule action plan for dioxin-TEQ is neither realistic nor commensurate with actual water quality impacts, and overly burdensome. It is highly unlikely that compliance schedule action plan activities will result in compliance with proposed final limits. Although an optional offset provision (as described in Task 7) may provide an alternative to compliance with a final effluent limit for dioxin-TEQ, such a program does not currently exist. Even though the Regional Water Board directed Regional Water Board staff to develop such a program, there do not appear to be any plans in place. Until such a program is developed with a feasible implementation strategy, BACWA believes this is not a realistic alternative and it is misleading to expect that such a program would lead to compliance.***

### Response 2.

The City of Millbrae provided essentially the same comment. Please see our response to City of Millbrae Comment 4.

### BACWA Comment 3.

***If the Regional Water Board retains the Cyanide Action Plan in this permit, it should be revised in several ways. BACWA believes these revisions to the Cyanide Action Plan are necessary to meet the intent of the Basin Plan amendment:***

- *The cyanide action plan should be contingent on the site-specific objective becoming fully effective.*
- *RMP data should be used for tracking ambient cyanide concentrations, where applicable.*

### Response 3.

The City of Millbrae provided essentially the same comment. Please see our response to City of Millbrae Comment 6.

**BACWA Comment 4. If the Regional Water Board retains the Copper Action Plan in this permit, its implementation should be revised:**

- *BACWA believes implementation of the copper action plan should be contingent on the site-specific objective becoming fully effective.*

**Response 4.**

The City of Millbrae provided essentially the same comment. Please see our response to City of Millbrae Comment 7.

**BACWA Comment 5**

***BACWA objects to the required procedure for the invalidation of data points.*** *BACWA objects to the language used to require correction of errors in data reporting. Human errors occur occasionally in data reporting. Inferring a time limit on the discovery and correction of these errors is confusing. We understand that Regional Water Board staff will consider erroneously reported data points at any time when sufficient information is available, although we prefer that it be taken care of promptly. But the confusing nature of this language means that some agencies will not understand this subtle point. BACWA requests that language be revised as follows:*

- g. If the Discharger wishes to invalidate any measurement, the letter of transmittal ~~will~~ should include identification of the measurement suspected to be invalid and notification of intent to submit the corrected data, within 60 days a specified schedule, and a formal request to invalidate the measurement. ~~The formal request will include the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports the invalidation (e.g., laboratory sheet, log entry, test results, etc.), and discussion of the corrective actions taken or planned (with a time schedule for completion), to prevent recurrence of the sampling or measurement problem.~~*

**Response 5.**

The City of Millbrae provided essentially the same comment. Please see our response to City of Millbrae Comment 11.

**BACWA Comment 6.**

***BACWA requests a clarification regarding sanitary sewer overflow requirements.*** *BACWA requests the following edit to section IV.A.5 of the Fact Sheet. Language in this section is not consistent with the correct reference in Prohibition III.E of the permit and should be revised as follows:*

- 5. Discharge Prohibition III.E (No sanitary sewer overflows to waters of the United States).*** *Sanitary sewer overflows that result in the discharge of raw or partially treated sewage not meeting secondary treatment requirements to ~~surface waters of the United States~~ is prohibited under the Clean Water Act and the Basin Plan. Discharge Prohibition No. 15 from Table 4-1 of the Basin Plan, and the Clean Water Act prohibit the discharge of wastewater to surface waters except as authorized under an NPDES permit. POTWs must achieve secondary treatment, at a minimum, and any more*



*stringent limitations necessary to achieve water quality standards (33U.S.C. §1311(b)(1)(B) and (C)).*

Response 6.

We have made the requested revision.

**III. Staff Revisions**

We made the following for consistency with other permits, and to ensure annual monitoring of chronic toxicity.

Revision 1

Footnote 8 to SMP Table E-4, Effluent Monitoring, has been revised as follows:

- (8) Critical Life Stage Toxicity Testing shall be performed and reported in accordance with the Chronic Toxicity Requirements specified in Section V.B of this MRP. ~~If the discharge demonstrates chronic toxicity in excess of the triggers specified in the “Chronic Toxicity Reduction Evaluation” subsection below, routine monitoring will be required. However, if the discharge does not demonstrate chronic toxicity in excess of those triggers, the monitoring frequency will be twice during the next five years, once during wet weather, and once during dry weather.~~

We made the following revisions in response to USEPA’s approval of the cyanide site-specific objectives, which occurred after the TO was circulated for comment. Because the TO contained alternative limits derived from the site-specific objectives to be triggered when the new objectives were put into effect, these revisions are not substantive.

Revision 2

Fact Sheet Section III.C.5, Antidegradation Policy:

- The final effluent limits for cyanide are higher than the previous interim effluent limit in Order No. 01-143, ~~but the same as the alternate effluent limits derived from the cyanide SSOs.~~

Revision 3

Fact Sheet Section IV.C.2.f:

- f. **Shallow/Deep Water Discharge.** Discharge from the Millbrae WPCP to Lower San Francisco Bay is viewed as a deep water discharge, which is defined by the Basin Plan as a discharge through a diffuser that receives a minimum initial dilution of 10 to 1. Pursuant to the Basin Plan, WQBELs established by this Order (except those for bioaccumulative pollutants and the non-persistent pollutants ammonia ~~and cyanide~~) are therefore based on an initial dilution of 10 to 1.

Revision 4

Fact Sheet Section IV.C.3.e, Table F-10, Summary of RPA Results:

**Table F-10. Summary of RPA Results**

CTR #	Priority Pollutants	MEC or Minimum DL <sup>[a][b]</sup> (µg/L)	Governing WQO/WQC (µg/L)	Maximum Background or Minimum DL <sup>[a][b]</sup> (µg/L)	RPA Results <sup>[c]</sup>
1	Antimony	0.5	4300	1.8	No

CTR #	Priority Pollutants	MEC or Minimum DL <sup>[a][b]</sup> (µg/L)	Governing WQO/WQC (µg/L)	Maximum Background or Minimum DL <sup>[a][b]</sup> (µg/L)	RPA Results <sup>[c]</sup>
2	Arsenic	1.8	36	2.46	No
3	Beryllium	0.1	No Criteria	0.215	Ud
4	Cadmium	0.13	9.4	0.13	No
5a	Chromium (III)	1	No Criteria	Not Available	No
5b	Chromium (VI)	1.4	50	4.4	Ud
6	<b>Copper</b>	<b>13</b>	<b>4.2</b>	<b>2.55</b>	<b>Yes</b>
7	Lead	0.58	8.5	0.80	No
8	<b>Mercury (303d listed) <sup>[d]</sup></b>	<b>0.028</b>	<b>0.025</b>	<b>0.0086</b>	<b>Yes</b>
9	Nickel	6.5	13	3.7	No
10	Selenium	3	5.0	0.39	No
11	Silver	1	2.2	0.052	No
12	Thallium	0.1	6.3	0.21	No
13	Zinc	27	86	5.1	No
14	<b>Cyanide</b>	<b>17</b>	<b>1.02.9</b>	<b>&lt; 0.4</b>	<b>Yes</b>

Revision 5

Fact Sheet Section IV.C.4.b.(2):

- (2) For non-bioaccumulative constituents (except ammonia and cyanide), a conservative allowance of 10:1 dilution for discharges to San Francisco Bay has been assigned for protection of beneficial uses. The 10:1 dilution allowance was granted in Order No. 01-143 and is also based on the Basin Plan's Prohibition Number 1, which prohibits discharges with less than 10:1 dilution. Limiting the dilution credit is based on SIP provisions in Section 1.4.2, which considers the following:

Revision 6

Fact Sheet Section IV.C.4.b.(4):

Subsection deleted.

Revision 7

Fact Sheet Section IV.C.4.c.(2)

(2) Cyanide

- (a) *Cyanide WQC*. The most stringent applicable WQC criteria for cyanide are established by the Basin Plan NTR for protection of aquatic life in San Francisco Bay. The Basin Plan NTR establishes site specific objectives of 9.4 µg/L (acute) and 2.9 µg/L (chronic) both the saltwater Criterion Maximum Concentration (acute criterion) and the Criterion Chronic Concentration (chronic criterion) at 1.0 µg/L.

- (b) *RPA Results*. This Order establishes effluent limitations for cyanide because the MEC of 17 µg/L exceeds the governing WQC of 2.9 ± µg/L, demonstrating Reasonable Potential by Trigger 1.

- (c) *Cyanide WQBELs*. WQBELs for cyanide, calculated according to SIP procedures using a CV of 0.73 based on the mean and standard deviation of the effluent data set, and using the site specific objectives of 9.4 µg/L (acute) and 2.9 µg/L (chronic), are an MDEL of 44 µg/L and an AMEL of 20 µg/L. ~~The Regional Water Board has proposed site-specific criteria for cyanide, described in *Draft Staff Report on Proposed Site-Specific Water Quality Objectives and Effluent Limit Policy for Cyanide for San Francisco Bay*, dated November 10, 2005. Alternate cyanide WQBELs based on these site-specific criteria and on the Discharger's current cyanide data would also be an AMEL of 20 µg/L and an MDEL of 44 µg/L.~~
- (d) *Immediate Compliance Feasible*. Statistical analysis of effluent cyanide data collected from February 2004 through January 2007 shows that the 95th percentile (11 µg/L) is less than the AMEL (20 µg/L); the 99th percentile (16 µg/L) is less than the MDEL (44 µg/L); and the mean (4.5 µg/L) is less than the long term average of the projected lognormal distribution of the effluent data set after accounting for effluent variability (12 µg/L). Based on this analysis, the Regional Water Board concludes that immediate compliance is feasible.
- (e) *Antibacksliding*. Antibacksliding requirements are satisfied, as Order No. 01-143 did not include final effluent limitations for cyanide.

Revision 8

Fact Sheet Section IV.C.4.e, Table F-12, Effluent Limit Calculations:

PRIORITY POLLUTANTS Units	Copper ug/L		Mercury ug/L	Cyanide <sup>[1]</sup> ug/L		Dioxin TEQ ug/L	Total Ammonia ug/L
	BP & CTR SW Aq Life	Alternate limits using SSOs (December 2004)	BP SW Aq Life	NTR- Criterion for the Bay	Alternate- Limits- Using- Proposed- SSOs	Basin Plan HH	Basin Plan Aq. Life
Basis and Criteria type							
CTR Criteria -Acute	5.5	-----	2.1	4.0	9.4	-----	--
CTR Criteria -Chronic	4.2	-----	0.025	4.0	2.9	-----	--
SSO Criteria -Acute (December 2004) (Diss.)		3.9			9.4		
SSO Criteria -Chronic (December 2004) (Diss.)		2.5			2.9		
Water Effects ratio (WER)	2.4	2.4	1	4	1	1	1
Lowest WQO	4.2		0.025	4.0	4.0 2.9	1.4E-08	1505
Site Specific Translator - MDEL	0.88	0.88					
Site Specific Translator - AMEL	0.74	0.74					
Dilution Factor (D) (if applicable)	9	9	0	72	9	0	73
No. of samples per month	4	4	4	4	4	4	30
Aquatic life criteria analysis required? (Y/N)	Y	Y	Y	Y	Y	N	Y
HH criteria analysis required? (Y/N)	N	N	Y	Y	Y	Y	N
Applicable Acute WQO	13.09	10.64	2.1	4	9.4		14,296
Applicable Chronic WQO	10.05	8.11	0.025	4	2.9		1,505
HH criteria	-----	-----	0.05	220,000	220,000	1.40E-08	0
Background (Maximum Conc for Aquatic Life calc) <sup>[2]</sup>	2.55	2.55	0.0086	0.4	0.4	7.10E-08	100
Background (Average Conc for Human Health calc)	-----	-----	0.0022	0.4	0.4	5.00E-08	--
Is the pollutant Bioaccumulative(Y/N)? (e.g., Hg)	N	N	Y	N	N	Y	N
ECA acute	108.0	83.4	2.1	44.2	90.4		1,050,604
ECA chronic	77.6	58.1	0.025	44.2	25.4		104,070
ECA HH			0.051	46059974	2199996.4	1.40E-08	
No. of data points <10 or at least 80% of data reported non detect? (Y/N)	N	N	N	N	N	Y	N
Avg of effluent data points	7.4	7.4	0.0087	4.5	4.5		38
Std Dev of effluent data points	2.0	2.0	0.0052	3.2	3.2		7.4
CV calculated	0.27	0.27	0.60	0.73	0.73	N/A	0.20
CV (Selected) - Final	0.27	0.27	0.60	0.73	0.73	0.60	0.20
ECA acute mult99	0.55	0.55	0.320	0.27	0.27		0.65
ECA chronic mult99	0.73	0.73	0.526	0.47	0.47		0.98
LTA acute	59.82	46.22	0.672	42.04	24.56		681,047
LTA chronic	57.00	42.71	0.013	20.72	11.91		101,617
minimum of LTAs	57.00	42.71	0.013	42.04	11.91		101,617
AMEL mult95	1.24	1.24	1.55	1.68	1.68	1.55	1.06
MDEL mult99	1.80	1.80	3.12	3.68	3.68	3.11	1.54
AMEL (aq life)	70.70	52.97	0.02	20.15	19.98		107,719
MDEL(aq life)	102.88	77.08	0.04	44.20	43.83		156,758
MDEL/AMEL Multiplier	1.46	1.46	2.01	2.19	2.19	2.01	1.46
AMEL (human hith)			0.051	46059974	2199996	1.4E-08	
MDEL (human hith)			0.102	35231584	4826245	2.8E-08	
minimum of AMEL for Aq. life vs HH	71	53	0.020	20.4	20	1.4E-08	1.1E+05
minimum of MDEL for Aq. Life vs HH	103	77	0.041	44.2	44	2.8E-08	1.6E+05
Current limit in permit (30-day average)	17 (Interim)	17 (Interim)	0.087 (Interim)	40 (Interim)	10 (Interim)	1.4E-07 (Interim)	-----
Current limit in permit (daily)	-----	-----	-----	-----	-----	-----	-----
Final limit - AMEL	71	53	0.020	20	20	1.4E-08	1.1E+05
Final limit - MDEL	100	77	0.041	44	44	2.8E-08	1.6E+05
Max Effl Conc (MEC)	13	13	0.028	47	17	8.3E-08	5.9E+04