



California Regional Water Quality Control Board

San Francisco Bay Region



Linda S. Adams
Secretary for
Environmental Protection

1515 Clay Street, Suite 1400, Oakland, California 94612
(510) 622-2300 • Fax (510) 622-2460
<http://www.waterboards.ca.gov/sanfranciscobay>

Arnold Schwarzenegger
Governor

Sent by CERTIFIED MAIL
Return Receipt Requested

October 14, 2008
CIWQS Place ID: 257754
File No: 2149.4009 (TY)

Ms. Pam Jeane
Deputy Chief Engineer
Sonoma County Water Agency
P.O. Box 11628
Santa Rosa, California 95406

**Subject: Transmittal of Final Order No. R2-2008-0090, NPDES Permit No. CA0037800,
and Cease and Desist Order No. R2-2008-0091 for Sonoma Valley County
Sanitation District, Sonoma, Sonoma County**

Dear Ms. Jeane:

Attached are copies of Final Orders No. R2-2008-0090 and No. R2-2008-0091 adopted by the Board on October 8, 2008. The requirements of these Orders are effective starting on December 1, 2008. Please note that we corrected a discrepancy in Order No. R2-2008-0090. The correct interim effluent limit for dioxins-TEQ in Table 8 (Page 15) should be 6.251×10^{-5} $\mu\text{g/L}$ as indicated in Page F-43 of Attachment F, Fact Sheet, finding IV.E.4.c(5)(v). This minor modification is made pursuant to 40 CFR124.5.

If you have any questions regarding this letter, please contact Tong Yin at (510) 622-2418 or e-mail at TYin@waterboards.ca.gov.

Sincerely,

Bruce H. Wolfe
Executive Officer

Attachments: Order Nos. R2-2008-0090 and R2-2008-0091

Copy (sent via email):

Nancy Yoshikawa, U.S. EPA, Region 9, yoshikawa.nancy@epamail.epa.gov

Philip Isorena, SWRCB DWQ, pisorena@waterboards.ca.gov

Jae Kim, Tetra Tech, jae.kim@tetrattech-ffx.com

Ken Greenberg, U.S. EPA, Region 9, greenberg.Ken@epamail.epa.gov