



**California Regional Water Quality Control Board
San Francisco Bay Region**



Matthew Rodriguez
Secretary for
Environmental Protection

1515 Clay Street, Suite 1400, Oakland, California 94612
(510) 622-2300 • FAX (510) 622-2460
<http://www.waterboards.ca.gov/sanfranciscobay>

Edmund G. Brown Jr.
Governor

**TENTATIVE ORDER NO. R2-2012-XXXX
NPDES NO. CAG912002**

**GENERAL WASTE DISCHARGE REQUIREMENTS FOR:
Discharge or Reuse of Extracted and Treated Groundwater Resulting from the Cleanup of
Groundwater Polluted by Volatile Organic Compounds (VOC), Fuel Leaks and Other Related
Wastes (VOC and Fuel General Permit)**

Table 1. Administrative Information

This Order was adopted by the Regional Water Quality Control Board on:	
This Order shall become effective on:	March 15, 2012
This Order shall expire on:	March 15, 2017
The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified the discharges under this General National Pollutant Discharge Elimination System (NPDES) Permit as minor discharges based on the discharges' impacts to receiving water bodies.	
To obtain coverage under this General Permit, dischargers must submit a Notice of Intent (NOI) Form as described in Attachment B and a filing fee equivalent to the first year's annual fee. If the NOI is complete, Authorization to Discharge will be issued by the Regional Water Quality Control Board Executive Officer.	
Authorized dischargers who need to continue discharging after the expiration date of this Order shall file a completed NOI form no later than 180 days in advance of this Order's expiration date. Such dischargers for which coverage is extended will become subject to the new Order upon authorization by the Executive Officer.	

I, Bruce H. Wolfe, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on the date indicated above.

Bruce H. Wolfe, Executive Officer

Contents

I.Scope of General Permit3

II.Findings3

III.Discharge Prohibitions8

IV.Effluent Limitations and Discharge Specifications9

 A. Effluent Limitations (Surface Water Discharges Only).....9

 B. Reclamation Specifications – Water Reuse11

V.Receiving Water Limitations12

 A. Surface Water Limitations12

 B. Groundwater Limitations13

VI.Provisions13

 A. Standard Provisions13

 B. Monitoring and Reporting Program Requirements.....13

 C. Special Provisions14

VII.Compliance Determination.....18

Tables

Table 1. Administrative Information1

Table 2. Effluent Limitations for Toxic Pollutants9

Table 3. Trigger Pollutants.....15

Attachments

- Attachment A – Definitions
- Attachment B – Notice of Intent Application Form and Instructions
- Attachment C – Notice of Termination
- Attachment D – Standard Provisions
- Attachment E – Monitoring and Reporting Program
- Attachment F – Fact Sheet

I. SCOPE OF GENERAL PERMIT

Facilities that may be covered under this Order are groundwater treatment facilities located at active or closed sites, such as service stations or construction sites. These groundwater treatment facilities are in operation to extract and treat groundwater polluted by volatile organic compounds (VOC), fuel, and fuel additives. This Order covers discharges from these facilities to all surface waters such as creeks, streams, rivers including flood control canals, lakes, or San Francisco Bay. Such discharges may occur directly to surface waters or through constructed storm drain systems.

II. FINDINGS

The California Regional Water Quality Control Board, San Francisco Bay Region (hereinafter, the Regional Water Board), finds:

- A. Background.** There are 20 permittees authorized (as of November 2011) to discharge pursuant to Order No. R2-2006-0075, NPDES Permit No. CAG912002 (General Waste Discharge Requirements for Discharge or Reuse of Extracted and Treated Groundwater Resulting from the Cleanup of Groundwater Polluted by Fuel Leaks and Other Related Waste at Service Stations and Similar Sites). Of this group, 15 submitted Notices of Intent (NOI) applications and applied for an NPDES permit to continue their discharge of treated wastewater from their groundwater extraction and treatment facilities (hereinafter Facility or Facilities).

In addition, there are 56 permittees currently authorized to discharge pursuant to Order No. R2-2009-0059, NPDES Permit No. CAG912003 (General Waste Discharge for Discharge or Reuse of Extracted and Treated Groundwater Resulting from the Cleanup of Groundwater Polluted by VOC). Order No. R2-2009-0059 will not be reissued upon expiration on September 30, 2014, and permittees with a continued need to discharge shall seek coverage under this General Permit.

For the purposes of this Order, references to the “Discharger” or “permittee” in applicable federal and State laws, regulations, plans, or policy are held to be equivalent to references to the Discharger(s) herein. A discharger who is authorized under this Order is hereinafter a Discharger.

- B. Facility Description.** Dischargers typically use aeration and/or granular activated carbon (GAC) systems to treat their groundwater prior to discharge. Facilities that use other types of treatment systems that are effective at removal of VOC or fuel pollutants may be covered by this Order subject to the approval of the Executive Officer. Treated wastewaters are typically discharged through storm drain systems, rivers, and/or creeks to San Francisco Bay. To obtain coverage under this Order, a discharger must include a complete description of the treatment system installed at its facility in the Notice of Intent (NOI) application form (Attachment B).
- C. Regional Water Board Preference for Reuse or Discharge to POTW:** The Regional Water Board adopted Resolution No. 88-160 on October 19, 1988. The Resolution urges Dischargers of extracted groundwater from site cleanup projects to reuse their treated groundwater. When reuse is not technically and/or economically feasible, to discharge to a publicly owned treatment works (POTW). Only if neither reuse nor discharge to a POTW is technically or economically feasible,

and if beneficial uses of the receiving water are not adversely affected, the Regional Water Board may authorize the discharge of treated extracted groundwater in accordance with the requirements of this Order.

D. Legal Authorities. This Order is issued pursuant to Clean Water Act (CWA) section 402 and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code (CWC) (commencing with section 13370). It shall serve as a NPDES permit for point source discharges from each Facility, regulated under this Order, to surface waters. This Order also serves as General Waste Discharge Requirements (GWDRs) pursuant to CWC article 4, chapter 4, division 7 of the Water Code (commencing with section 13260).

States may request authority to issue general NPDES permits pursuant to title 40 of the Code of Federal Regulations (40 CFR) section 122.28. On June 8, 1989, the State Water Resources Control Board (State Water Board) submitted an application to the USEPA requesting revisions to its NPDES Program in accordance with 40 CFR 122.28, 123.62, and 403.10. The application included a request to add general permit authority to its approved NPDES Program. On September 22, 1989, USEPA Region 9 approved the State Water Board's request and granted authorization for the State to issue general NPDES permits.

E. Background and Rationale for Requirements. The Regional Water Board developed the requirements in this Order based on information submitted as part of NOIs, through monitoring and reporting programs, and other available environmental information. The Fact Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through E and G through H are also incorporated into this Order.

F. California Environmental Quality Act (CEQA). Under CWC section 13389, this action to adopt an NPDES permit is exempt from Chapter 3 of CEQA.

G. Technology-based Effluent Limitations. CWA section 301(b) and NPDES regulations at 40 CFR 122.44 requires that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. Discharges authorized by this Order must meet technology-based effluent limitations based on Best Professional Judgment (BPJ) in accordance with 40 CFR 125.3. A detailed discussion of the technology-based effluent limitations development and BPJ is included in the Fact Sheet (Attachment F).

G. Water Quality-Based Effluent Limitations (WQBELs). CWA section 301(b) and NPDES regulations at 40 CFR 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. NPDES regulations at 40 CFR 122.44(d)(1)(i) mandate that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs must be established using: (1) USEPA criteria guidance under CWA section 304(a),

supplemented where necessary by other relevant information; (2) on an indicator parameter for the pollutant of concern; or (3) using a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in 40 CFR 122.44(d)(1)(vi).

H. Water Quality Control Plans. The *Water Quality Control Plan for the San Francisco Bay Basin* (Basin Plan) is the Regional Water Board's master water quality control planning document. It designates beneficial uses and water quality objectives (WQOs) for waters of the State, including surface waters and groundwater. It also includes programs of implementation to achieve WQOs. The Basin Plan was duly adopted by the Regional Water Board and approved by the State Water Board, Office of Administrative Law and USEPA.

The Basin Plan states that the beneficial uses of any specifically identified water body generally apply to its tributary streams. The Basin Plan may not specifically identify beneficial uses for every receiving water regulated under this permit, but may identify present and potential uses for the downstream water body, to which the receiving water, via an intermediate water body, is tributary. These potential and existing beneficial uses are municipal and domestic supply, fish migration and fish spawning, industrial service supply, navigation, industrial process supply, marine habitat, agricultural supply, estuarine habitat, groundwater recharge, shellfish harvesting, water contact and non-contact recreation, ocean, commercial, and sport fishing, wildlife habitat, areas of special biological significance, cold freshwater and warm freshwater habitat, and preservation of rare and endangered species for surface waters and municipal and domestic supply, industrial service supply, industrial process supply, agricultural supply, and freshwater replenishment for groundwaters. In addition, the Basin Plan implements State Water Board Resolution No. 88-63, which established State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Requirements of this Order implement the Basin Plan.

On September 18, 1975, the State Water Board adopted the *Water Quality Control Plan for Control of Temperature in the Coastal Interstate Waters and Enclosed Bays and Estuaries of California* (hereinafter the Thermal Plan). The Thermal Plan contains objectives governing cooling water discharges, providing different and specific numeric and narrative water quality objectives for new and existing discharges.

The State Water Board's *Water Quality Control Plan for Enclosed Bays and Estuaries—Part 1, Sediment Quality* became effective on August 25, 2009. This plan supersedes other narrative sediment quality objectives and establishes new sediment quality objectives and related implementation provisions for specifically defined sediments in most bays and estuaries.

I. National Toxics Rule (NTR) and California Toxics Rule (CTR). USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. About 40 criteria in the NTR apply in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria (WQC) for priority pollutants.

- J. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- K. Recycled Water Policy.** The State Water Board adopted Resolution No. 2009-0011 (*Policy for Water Quality Control for Recycled Water*) on February 3, 2009. The policy is intended to promote sustainable local water supplies by increasing the acceptance and promoting the use of recycled water. It sets a goal of increasing recycled water use statewide by at least one million acre feet per year by 2030. The policy also requires Regional Water Boards to exercise their authority to the fullest extent possible to encourage recycled water use, and to develop watershed-based salt and nutrient management plans to ensure that groundwater resources are not degraded by recycled water use.
- L. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes. [40 CFR 131.21; 65 Fed. Reg. 24641 (April 27, 2000)] Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- M. Stringency of Requirements for Individual Pollutants.** This Order contains both technology-based and water quality based effluent limitations for individual pollutants. Derivation of these limitations is discussed in the Fact Sheet (Attachment F.) This Order's technology-based pollutant restrictions on benzene, carbon tetrachloride, chloroform, 1,1-dichloroethane, 1,2-dichloroethane, 1,1-dichloroethylene, ethylbenzene, methylene chloride, tetrachloroethylene, toluene, cis-1,2-dichloroethylene, trans-1,2-dichloroethylene, 1,1,1-trichloroethane, 1,1,2-trichloroethane, trichloroethylene, vinyl chloride, total xylenes, methyl tertiary butyl ether, total petroleum hydrocarbons, and trichlorotrifluoroethane implement the minimum applicable federal technology-based requirements and meet requirements of the Basin Plan.

WQBELs have been derived to implement WQOs that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutants WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR 131.38. The procedure for calculating individual WQBELs for priority pollutants is based on the SIP. Most beneficial uses and WQOs contained in the Basin Plan were approved under State law, and submitted to and approved by USEPA. Any WQOs and beneficial uses submitted to USEPA prior to May 30,

2000, but not approved by USEPA before that date, are nonetheless “applicable water quality standards for the purposes of the CWA” pursuant to 40 CFR 131.21(c)(1).

- N. Antidegradation Policy.** NPDES regulations at 40 CFR 131.12 require that state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California’s antidegradation policy in State Water Board Resolution No. 68-16, which incorporates the federal antidegradation policy where the federal policy applies under federal law and requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies.
- O. Anti-Backsliding Requirements.** CWA sections 402(o)(2) and 303(d)(4) and 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed.
- P. Endangered Species Act.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code sections 2050 to 2097) or the federal Endangered Species Act (16 U.S.C.A. sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the State. Dischargers are responsible for meeting all requirements of applicable State and federal law pertaining to threatened and endangered species.
- Q. Monitoring and Reporting.** NPDES regulations at 40 CFR 122.48 require that all NPDES permits specify requirements for recording and reporting monitoring results. CWC sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.
- R. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with 40 CFR section 122.41, and additional conditions applicable to specified categories of permits in accordance with 40 CFR 122.42 and as modified for this General Permit, are provided in Attachment D. Dischargers must comply with all standard provisions and with those additional conditions that are applicable under 40 CFR 122.42. Dischargers must also comply with the Regional Standard Provisions provided in Attachment G. The Regional Water Board has also included in this Order special provisions applicable to the Dischargers. The attached Fact Sheet (Attachment F) provides rationale for the special provisions contained in this Order.
- S. Provisions and Requirements Implementing State Law.** The provisions/requirements in subsections IV.B (Reclamation Specifications) and V.B (Groundwater Limitations) of this Order are included to implement State law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations.

- T. Notification of Interested Parties.** The Regional Water Board notified the Dischargers and interested agencies and persons of its intent to prescribe GWDRs for the discharge and has provided them with an opportunity to submit their written comments and recommendations. The Fact Sheet (Attachment F) provides details of the notification.
- U. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. The Fact Sheet (Attachment F) provides details of the public hearing.

IT IS HEREBY ORDERED, that this Order supersedes Order No. R2-2006-0075, except for enforcement purposes, and in order to meet the provisions contained in CWC Division 7 (commencing with section 13000) and regulations adopted thereunder, and the provisions of the federal CWA and regulations and guidelines adopted thereunder, the Discharger shall comply with the following requirements in this Order.

III. DISCHARGE PROHIBITIONS

- A.** The discharge of extracted and treated groundwater polluted by fuel, fuel components, VOC, and related wastes to surface waters from service stations, construction sites, and similar sites, is prohibited unless an NOI application for proposed discharge has been submitted, and the Executive Officer has provided the Discharger with an Authorization to Discharge.
- B.** Discharges other than the following are prohibited: extracted groundwater treated only with treatment chemicals approved by the Executive Officer and added in a manner consistent with the proper operation and maintenance of the treatment facility.
- C.** The discharge of extracted and treated groundwater from a specific site in excess of the flow rate specified by the Executive Officer in the Authorization to Discharge is prohibited.
- D.** Discharges to a storm drain shall not cause scouring or erosion at the point where the storm drain discharges into the receiving water, and shall not cause or contribute to scouring of banks, excessive sedimentation, or flooding of the storm drain system or receiving water downstream of the point of discharge.
- E.** Neither the treatment nor the discharge of pollutants shall create a pollution, contamination, or nuisance, as defined by CWC section 13050.
- F.** Bypass or overflow of untreated or partially treated groundwater polluted by fuel, fuel components, VOC, or other related wastes to waters of the State either at the treatment system or from any of the collection or transport systems or pump stations tributary to the treatment system is prohibited, except as provided for in the conditions stated in section I.G.2 and I.G.4 of Attachment D.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations (For Dischargers to Surface Water Only)

- Toxic Pollutants:** The discharge of treated groundwater shall maintain compliance with the following effluent limitations at Monitoring Location EFF-001 as specified in the Authorization to Discharge:

Table 2. Effluent Limitations for Toxic Pollutants

No.	Compound	CAS Number	Column A: Discharge to Drinking Water Areas ⁽¹⁾		Column B: Discharge to Other Surface Water Areas	
			Average Monthly Effluent Limitation (µg/L)	Maximum Daily Effluent Limitation (µg/L)	Average Monthly Effluent Limitation (µg/L)	Maximum Daily Effluent Limitation (µg/L)
1	Benzene	71432	---	1	---	5
2	Carbon Tetrachloride	56235	0.25 ⁽²⁾	0.50	4.4	5
3	Chloroform	67663	---	5	---	5
4	1,1-Dichloroethane	75343	---	5	---	5
5	1,2-Dichloroethane	107062	0.38 ⁽²⁾	0.5	---	5
6	1,1-Dichloroethylene	75354	0.057 ⁽²⁾	0.11 ⁽²⁾	3.2	5
7	Ethylbenzene	100414	---	5	---	5
8	Methylene Chloride	75092	4.7	5	---	5
9	Tetrachloroethylene (PCE)	127184	0.8	1.6	---	5
10	Toluene	108883	---	5	---	5
11	Cis 1,2-Dichloroethylene	156592	---	5	---	5
12	Trans 1,2-Dichloroethylene	156605	---	5	---	5
13	1,1,1-Trichloroethane	71556	---	5	---	5
14	1,1,2-Trichloroethane	79005	0.6	1.2	---	5
15	Trichloroethylene (TCE)	79016	2.7	5	---	5
16	Vinyl Chloride	75014	---	0.5	---	1
17	Total Xylenes	1330207	---	5	---	5
18	Methyl Tertiary Butyl Ether (MTBE)	1634044	---	5	---	5

No.	Compound	CAS Number	Column A: Discharge to Drinking Water Areas ^[1]		Column B: Discharge to Other Surface Water Areas	
			Average Monthly Effluent Limitation (µg/L)	Maximum Daily Effluent Limitation (µg/L)	Average Monthly Effluent Limitation (µg/L)	Maximum Daily Effluent Limitation (µg/L)
19	Total Petroleum Hydrocarbons[TPHs (as gasoline or as diesel)]	---	---	50	---	50
20	Ethylene Dibromide (1,2-Dibromoethane)	106934	---	0.05 ^[2]	---	5
21	Trichloro-trifluoroethane	76131	---	5	---	5
22	Total Chlorine Residual	---	---	0.0 ^[3]	---	0.0 ^[3]
Table Notes: [1] Drinking water areas are defined as surface waters with the existing or potential beneficial uses of "Municipal and Domestic Supply" and "Groundwater Recharge" (the latter includes recharge areas to maintain salt balance or to halt salt water intrusion into fresh water aquifers). [2] If reported detection level is greater than effluent limit, then a non-detect result using a 0.5 µg/L detection level will not be deemed to be out of compliance. [3] There shall be no detectable levels of residual chlorine in the effluent (a non-detect result using a detection level equal or less than 0.08 milligram per liter (mg/L) will not be deemed to be out of compliance). This limit only applies to Dischargers that chlorinate their extracted groundwater.						

2. pH: The pH of the discharge shall not exceed 8.5 nor be less than 6.5.

3. Acute Toxicity:

- a.** Representative samples of the discharge, with compliance measured at Monitoring Location EFF-001 as described in the Authorization to Discharge, shall meet the following limits for acute toxicity. Bioassays shall be conducted in compliance with Section V.A of the Monitoring and Reporting Program (Attachment E).

The survival of test fish in 96-hour static renewal bioassays with the discharge shall be not less than a three sample moving median of 90% survival and a single test value of not less than 70% survival.

- b.** These acute toxicity limitations are further defined as follows:

- (1) 3-sample median. A bioassay test showing survival of less than 90 percent represents a violation of this limitation, if one or more of the past two or less bioassay tests show less than 90 percent survival.
- (2) Single sample. A bioassay test showing survival of less than 70 percent represents a violation of this limitation.

- c. Bioassays shall be performed using the most up-to-date USEPA protocol. Bioassays shall be conducted using rainbow trout as the test species in compliance with *Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms*, currently 5th Edition (EPA-821-R-02-012), with exceptions granted to the Discharger by the Executive Officer and the Environmental Laboratory Accreditation Program (ELAP) upon the Discharger's request with justification.

B. Groundwater Reuse Specifications (For Dischargers that Reuse All or a Portion of Treated Groundwater)

1. **Reuse Policy:** As noted in the findings, the Regional Water Board adopted Resolution No. 88-160 on October 19, 1988. The Resolution urges Dischargers of extracted groundwater from site cleanup projects to reuse their effluent and that when reuse is not technically and/or economically feasible, to discharge to a POTW.
2. **Reuse Allowed:** This Order permits reuse of extracted treated groundwater in conjunction with the discharge to surface water. Reuse of extracted treated groundwater can take many forms, such as irrigation of landscaping or agriculture, dust control or soil compaction on construction sites, and industrial water supply.
3. **Water Reuse Specifications (Water Reuse Only)**
 - a. Water for beneficial reuse shall meet the requirements in Section IV.A - Effluent Limitations.
 - b. Water reuse activities shall be described in the Discharger's NOI, including the method of any additional treatment and the location and type of water reuse.
 - c. The reuse of treated groundwater shall not impair the quality of waters of the State, nor shall it create a nuisance as defined by CWC section 13050(m).
 - d. Adequate measures shall be taken to minimize public contact with the reused groundwater and to prevent the breeding of flies, mosquitoes, and other vectors of public health significance during or after the process of reuse.
 - e. Appropriate public warnings must be posted to advise the public that the water is not suitable for drinking. Signs must be posted in the area, and all reused water valves and outlets appropriately labeled.
 - f. There shall be no cross-connection between the potable water supply and piping containing treated groundwater intended for reuse.
 - g. Water reuse consisting of recharge or reinjection is not authorized under this Order. Any reinjection must be performed in accordance with a cleanup order approved by the Regional Water Board, or another lead oversight agency.

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Discharges shall not cause the following in surface receiving waters:

1. The discharge of waste shall not cause the following conditions to exist in waters of the State at any place:
 - a. Floating, suspended, or deposited macroscopic particulate matter or foam;
 - b. Bottom deposits or aquatic growths to the extent that such deposits or growths cause nuisance or adversely affect beneficial uses;
 - c. Alteration of temperature, turbidity, or apparent color beyond present natural background levels;
 - d. Visible, floating, suspended, or deposited oil or other products of petroleum origin; and
 - e. Toxic or other deleterious substances to be present in concentrations or quantities that will cause deleterious effects on aquatic biota, wildlife, or waterfowl, or which render any of these unfit for human consumption either at levels created in the receiving waters or as a result of biological concentration.

2. The discharge of waste shall not cause the following limits to be exceeded in waters of the State in any place within one foot of the water surface:

a. Dissolved oxygen:

For all tidal waters:

In the Bay downstream of Carquinez Bridge - 5.0 mg/L minimum

Upstream of Carquinez Bridge - 7.0 mg/L minimum

For nontidal waters:

Waters designated as cold water habitat - 7.0 mg/L minimum

Waters designated as warm water habitat - 5.0 mg/L minimum

For all inland surface waters:

The median dissolved oxygen concentration for any three consecutive months shall not be less than 80% of the dissolved oxygen content at saturation. When natural factors cause concentrations less than that specified above,

the discharge shall not cause further reduction in ambient dissolved oxygen concentrations.

- b. Dissolved Sulfide Natural background levels
 - c. pH: The pH shall not be depressed below 6.5 nor raised above 8.5, nor caused to vary from normal ambient pH by more than 0.5 pH units.
 - d. Un-ionized Ammonia 0.025 mg/L as an annual median; 0.16 mg/L as a maximum for Central Bay and upstream; 0.4 mg/L as a maximum for Lower Bay.
 - e. Nutrients Waters shall not contain biostimulatory substances in concentrations that promote aquatic growths to the extent that such growths cause nuisance or adversely affect beneficial uses.
3. Discharges shall not cause or contribute to a violation of any applicable water quality standard for receiving waters adopted by the Regional Water Board or the State Water Board as required by the CWA and regulations adopted there under. If more stringent applicable water quality standards are promulgated or approved pursuant to CWA section 303, or amendments thereto, the Regional Water Board will revise and modify this Order in accordance with such more stringent standards.

B. Groundwater Limitations – No discharges to groundwater authorized by this Order

VI. PROVISIONS

A. Standard Provisions

Dischargers shall comply with federal Standard Provisions included in Attachment D of this Order.

B. Monitoring and Reporting Program Requirements

1. Dischargers shall comply with the Monitoring and Reporting Program (Attachment E), and future revisions thereto, including applicable sampling and reporting requirements in the standard provisions listed in VI.A, above.
2. Dischargers authorized under this Order, especially those Dischargers with flow rates exceeding 10 gallons per minute, may be required to comply with additional monitoring requirements. The Executive Officer will specify such additional monitoring requirements in the Authorization to Discharge letter. Examples of additional monitoring that could be required are listed below:
 - a. Monitoring in response to a complaint received about a facility authorized to discharge under this permit,

- b. Storm water monitoring,
- c. Dioxins and furans monitoring,
- d. Regional Monitoring Program (RMP) monitoring,
- e. Additional discharge observations, and
- f. Additional effluent and ambient priority pollutant scans.

C. Special Provisions

1. Reopener Provisions

The Regional Water Board may modify or reopen this Order prior to its expiration date in any of the following circumstances as allowed by law:

- a. If present or future investigations demonstrate that the discharges governed by this Order have or will have a reasonable potential to cause or contribute to, or will cease to have, adverse impacts on water quality or beneficial uses of the receiving waters.
 - b. If new or revised WQOs or total maximum daily loads (TMDLs) come into effect for the San Francisco Bay Estuary and contiguous water bodies (whether Statewide, regional, or site-specific). In such cases, effluent limitations in this Order will be modified as necessary to reflect updated WQOs and waste load allocations in TMDLs. Adoption of effluent limitations contained in this Order is not intended to restrict in any way future modifications based on legally adopted WQOs or TMDLs, or as otherwise permitted under federal regulations governing NPDES permit modifications.
 - c. If State Water Board precedential decisions, new policies, new laws, or new regulations on chronic toxicity or total chlorine residual become available.
 - d. If an administrative or judicial decision on a separate NPDES permit or WDRs addresses requirements similar to this discharge.
 - e. Or as otherwise authorized by law.
 - f. The Discharger may request permit modification based on any of the circumstances described above. In any such request, the Discharger shall include an antidegradation and anti-backsliding analysis.
- 2. NOI or Modified NOI Application.** The NOI or Modified NOI application for each point of proposed discharge to a storm drain system shall contain the information required in the NOI Application as explained in Attachment B of this Order and as may be amended by the Executive Officer.
- 3. NOI Review.** Upon receipt of a complete NOI application package for proposed discharge, the Executive Officer will review the application to determine whether the proposed Discharger is eligible to discharge waste under this Order. The application package shall document that:
- a. The proposed discharge results from the cleanup of groundwater polluted by fuel leaks,

VOC leaks, and other related wastes;

- b.** The proposed Discharger has met the provisions of Regional Water Board Resolution No. 88-160 (*Regional Water Board Position on the Disposal of Extracted Groundwater from Groundwater Cleanup Projects*); and
- c.** The proposed treatment system and associated operation, maintenance, and monitoring plans are capable of ensuring that the discharge will meet the provisions, prohibitions, effluent limitations, and receiving water limitations of this Order.
- 4. Discharge Authorization.** If the Regional Water Board Executive Officer determines that the proposed Discharger is eligible to discharge waste under this Order, the Executive Officer will issue an Authorization to Discharge. This Authorization to Discharge may be terminated by the Executive Officer at any time.
- 5. Non-Compliance Is A Violation.** Upon receipt of the Regional Water Board Executive Officer's Authorization to Discharge, the Discharger shall comply with all applicable conditions and limitations of this Order and its Attachments. Any noncompliance (violations of requirements in this Order or Monitoring Program) constitutes a violation of the CWA and the CWC and is grounds for enforcement action, and/or termination or modification of authorization to discharge.
- 6. Triggers.** The following triggers are not effluent limitations, and must not be construed as such. Instead, the triggers are levels above which additional investigation is required to determine further action. If any constituent in the discharge exceeds the corresponding trigger as listed in Table 3, below, the Discharger shall take three additional influent and three additional effluent samples for each exceeded constituent during the following calendar quarter and conduct activities as required in Provisions VI.C.7 or VI.C.8. If additional monitoring has already been completed, the Discharger shall summarize the results including a description of plans underway to address the previous exceedance, such as details of source elimination, changes in operation of existing treatment units, or the re-design of any treatment unit.

Table 3. Trigger Pollutants

Pollutant	Chemical Abstract Service (CAS) Number	Trigger (µg/L) ^{[1],[2]}
Antimony	7440360	6
Arsenic	7440382	10
Beryllium	7440417	4
Cadmium	7440439	1.1
Chromium (VI)	18540299	11 ^[3]
Copper ^[4]	7440508	5.9
Copper ^[5]	7440508	3.4
Copper ^[6]	7440508	4.7
Lead	7439921	3.2
Mercury	7439976	0.025
Nickel ^[4]	7440020	30
Nickel ^[5]	7440020	13
Nickel ^[6]	7440020	19
Selenium	7782492	5
Silver	7440224	2.2

Pollutant	Chemical Abstract Service (CAS) Number	Trigger ($\mu\text{g/L}$) ^{[1],[2]}
Thallium	7440280	1.7
Zinc	7440666	86
Cyanide	57125	2.9
Acrylonitrile	107131	0.059
Bromoform	75252	4.3
Chlorodibromomethane	124481	0.401
Dichlorobromomethane	75274	0.56
1,2-Dichloropropane	78875	0.52
1,3-Dichloropropylene	542756	0.5
1,1,2,2-Tetrachloroethane	79345	0.17
Pentachlorophenol	87865	0.28
2,4,6-Trichlorophenol	88062	2.1
Benzidine	92875	0.00012
Benzo(a)anthracene	56553	0.0044
Benzo(a)pyrene	50328	0.0044
Benzo(b)fluoranthene	205992	0.0044
Benzo(k)fluoranthene	207089	0.0044
Bis(2-chloroethyl)ether	111444	0.031
Bis(2-ethylhexyl)phthalate	117817	1.8
Chrysene	218019	0.044
Dibenzo(a,h)anthracene	53703	0.0044
3,3'-Dichlorobenzidine	91941	0.04
2,4-Dinitrotoluene	121142	0.11
1,2-Diphenylhydrazine	122667	0.040
Hexachlorobenzene	118741	0.00075
Hexachlorobutadiene	87683	0.44
Hexachloroethane	67721	1.9
Indeno(1,2,3-c,d)pyrene	193395	0.0044
N-nitrosodimethylamine	62759	0.00069
N-nitrosodi-n-propylamine	621647	0.005
Aldrin	309002	0.00013
alpha-BHC	319846	0.0039
beta-BHC	319857	0.014
gamma-BHC	58899	0.019
Chlordane	57749	0.00057
4,4-DDT	50393	0.00059
4,4-DDE	72559	0.00059
4,4-DDD	72548	0.00083
Dieldrin	60571	0.00014
alpha-Endosulfan	959988	0.0087
beta-Endosulfan	33213659	0.0087
Endrin	72208	0.0023
Endrin aldehyde	7421934	0.76
Heptachlor	76448	0.00021
Heptachlor epoxide	1024573	0.00010
PCBs, sum	1336363	0.00017
Toxaphene	8001352	0.0002
1,4-dioxane	123911	3
Turbidity (NTU)	---	5
Odor-Threshold (Units)	---	3
TPHs (other than gasoline and diesel)	---	50 ^[7]
Sulfate	---	250,000
Foaming agents	---	500
Color (Units)	-	15
Table Notes:		
[1] Units are in $\mu\text{g/L}$ unless noted otherwise right after the name of pollutant		
[2] If a discharger is reporting non-detect monitoring data with a reporting level higher than the trigger, the reason for the higher detection level shall be consistent with Appendix 4 of the SIP (Minimum Levels) and must be explained within the monitoring report. Please refer to the Regional Water Board web site for the latest version of SIP.		
[3] If total chromium concentration exceeds 11 $\mu\text{g/L}$, then analysis for chromium (VI) shall also be conducted.		
[4] Applicable to Suisun Bay and San Pablo Bay segments of San Francisco Bay.		
[5] Applicable to Central Bay and Lower Bay segments of San Francisco Bay		

Pollutant	Chemical Abstract Service (CAS) Number	Trigger ($\mu\text{g/L}$) ^{[1],[2]}
[6] Applicable to South San Francisco Bay, south of Hayward Shoals.		
[7] If a discharger is reporting monitoring data with a detection level higher than 50 $\mu\text{g/L}$, the reason for the higher detection level shall be explained within the monitoring report.		

- 7. Triggers Case 1:** If the results of all three additional discharge samples **do not** exceed the triggers, the Discharger shall report the results in the next Monitoring Report, and shall return to the schedule of sampling and analysis in the attached Monitoring and Reporting Program (Attachment E).
- 8. Triggers Case 2:** If the results of **any one of the three** additional discharge samples including the first discharge sample, show exceedance of the same trigger, the Discharger shall investigate the source (e.g., comparing influent and discharge sample results), and investigate source control and/or treatment options for each triggered pollutant. The Discharger shall document its progress on these efforts in the Annual Self-Monitoring Report required by section IX.B of the Monitoring and Reporting Program (Attachment E). Until the Executive Officer determines that the “triggered pollutants” investigation is complete, the Discharger must implement the following monitoring schedule for the triggered pollutants:
- a.** In case of a triggered inorganic pollutant; the Discharger shall accelerate monitoring of the discharge to quarterly and provide information, updated annually, confirming that pollutant source is background and explain the reasons why treatment of that pollutant is not feasible. Specifically, the annual monitoring reports shall include site-specific background groundwater concentrations, types of treatment available, and costs of treatment systems for each triggered inorganic pollutant, and
 - b.** In case of a triggered organic pollutant; the Discharger shall accelerate monitoring of the discharge to every two weeks and provide information, updated annually, confirming the reason(s) why that pollutant could not be treated to the level not exceeding the trigger for that pollutant.
- 9.** The Executive Officer may require the Discharger to perform additional investigations or take additional actions if the Discharger: (1) exceeds a trigger value for the same pollutant and confirms (Trigger Case 2 above) the exceedance greater than two times in one calendar year; and (2) is not pursuing resolution of trigger exceedances in a timely fashion in the judgment of the Executive Officer. These two trigger exceedances do not include the data collected to verify the trigger (i.e., effluent data collected to confirm the trigger exceedance). These conditions are also grounds for termination of the Authorization to Discharge.
- 10. Individual NPDES Permit May Be Required.** The USEPA Administrator may request the Regional Water Board Executive Officer to require any Discharger authorized to discharge waste by the General Permit to apply for and obtain an individual NPDES permit. The Executive Officer may require any Discharger authorized to discharge waste by the General Permit to apply for and obtain an individual NPDES permit. Cases where an individual NPDES permit may be required include the following:

- a. The Discharger is not in compliance with the conditions of this Order or as authorized by the Executive Officer;
- b. A change has occurred in the availability of demonstrated technology or practices for the control or abatement of pollutants applicable to the point source;
- c. Effluent limitation guidelines are promulgated for point sources covered by the General NPDES Permit; or
- d. A water quality control plan containing requirements applicable to such point sources is approved.

11. Treatment Reliability. Dischargers shall, at all times, retain a professional engineer certified in the State of California to oversee the design, and operation and maintenance of the treatment system to properly operate and maintain all facilities that are used by the Dischargers to achieve compliance with this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. All of these procedures shall be described in an Operation and Maintenance (O&M) Manual. The Discharger shall keep in a state of readiness all systems necessary to achieve compliance with the conditions of this Order. All systems, both those in service and reserve, shall be inspected and maintained on a regular basis. Records shall be kept of the tests (e.g., analytical or treatment system tests) and made available to the Regional Water Board for at least five years. Additional requirements for compliance with this provision are explained in Attachments B and C of the Order.

12. No Preemption. This Order permits the discharge of treated groundwater to waters of the State subject to the prohibitions, effluent limitations, and provisions of this Order. It does not pre-empt or supersede the authority of municipalities, flood control agencies, or other local agencies to prohibit, restrict, or control discharges of waste to storm drain systems or other watercourses subject to their jurisdiction. For example, this Order provides no water or groundwater rights and does not preempt the authority of any local or state agencies as relates to water rights.

VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in Section IV of this Order will be determined as specified below:

A. General

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in the Monitoring and Reporting Program and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

B. Multiple Sample Data

When determining compliance with an AMEL or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of “Detected, but Not Quantified” (DNQ) or “Not Detected” (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

ATTACHMENT A – ACRONYMS AND DEFINITIONS**Acronyms**

CIWQS	California Integrated Water Quality System
AMEL	Average Monthly Effluent Limitation
Basin Plan	Water Quality Control Plan for the San Francisco Bay Basin
BPJ	Best Professional Judgment
CFR	Code of Federal Regulations
CTR	California Toxics Rule
CV	Coefficient of Variation
CWA	Federal Clean Water Act
DNQ	Detected, but Not Quantified
DO	Dissolved oxygen
ECA	Effluent Concentration Allowance
EFF	Effluent
MDEF	Maximum Daily Effluent Limitation
MDL	Method Detection Limit
ML	Minimum Level
MTBE	Methyl Tertiary Butyl Ether
ND	Not Detected
NTR	National Toxics Rule
NOI	Notice of Intent
NPDES	National Pollutant Discharge Elimination System
PCE	Tetrachloroethylene
POTW	Publicly Owned Treatment Work
RL	Reporting Level
RPA	Reasonable Potential Analysis
SIP	State Implementation Policy
SSTs	Site-Specific Translators
TCE	Trichloroethylene
TPHG	Total Petroleum Hydrocarbons as Gasoline
TPHD	Total Petroleum Hydrocarbons as Diesel
µg/L	Microgram per Liter
USEPA	U.S. Environmental Protection Agency
VOC	Volatile Organic Compounds

Definitions

Arithmetic Mean (μ), also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n \quad \text{where: } \Sigma x \text{ is the sum of the measured ambient water concentrations, and } n \text{ is the number of samples.}$$

Average Monthly Effluent Limitation (AMEL) is the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Bioaccumulative pollutants are those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV) is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Detected, but Not Quantified (DNQ) are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Duly Authorized Representative is one whose:

- a. Authorization is made in writing by a principal executive officer or ranking elected official;
- b. Authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as general partner in a partnership, sole proprietor in a sole proprietorship, the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company (A duly authorized representative may thus be either a named individual or any individual occupying a named position).

Effluent Concentration Allowance (ECA) is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Estimated Chemical Concentration is the estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Field Blank is defined as an individual sample demonstrated to be free from the contaminants of interest and other potentially interfering substances, and treated as a sample in all respects, including exposure to grab-sampling site conditions, storage, preservation, and all analytical procedures. The purpose of the field blank is to determine if the field or sample transporting procedures and environments have

contaminated the sample.

Flow Sample is defined as the accurate measurement of the average daily flow volume using a properly calibrated and maintained flow-measuring device.

Grab Sample is defined as an individual sample collected in a short period of time not exceeding 15 minutes. Grab samples shall be collected during normal peak loading conditions for the parameter of interest, which may or may not be during hydraulic peaks. It is used primarily in determining compliance with maximum daily limits and average monthly limits. Grab samples represent only the condition that exists at the time the wastewater is collected.

Instantaneous Maximum Effluent Limitation is the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation is the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL) means the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median is the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL) is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML) is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Not Detected (ND) are those sample results less than the laboratory's MDL.

Ocean Waters are the territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Quality Assurance Officer is a qualified individual who was not otherwise involved in sample collection, transport, or analysis (please refer to the following web site for a more detailed description: http://www.waterboards.ca.gov/swamp/docs/swampqapp_template032404.doc) to investigate the cause of data error.

Persistent Pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Reporting Level (RL) is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Source of Drinking Water is any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ) is a measure of variability that is calculated as follows:

$$\sigma = \left(\frac{\sum[(x - \mu)^2]}{(n - 1)} \right)^{0.5}$$

where:

x is the observed value;

μ is the arithmetic mean of the observed values; and

n is the number of samples.

Toxicity Reduction Evaluation (TRE) is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

ATTACHMENT B – NOTICE OF INTENT (NOI) APPLICATION FORM AND INSTRUCTIONS

Complete and submit this NOI to apply for Authorization or Reauthorization to Discharge and/or reuse extracted and treated groundwater resulting from the cleanup of groundwater polluted by volatile organic compounds (VOC), fuel leaks, and other related waste under the requirements of NPDES Permit No. CAG912002 (VOC and Fuel General Permit)

I certify under penalty of law that this document and all attachments are prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the design engineer whose signature and engineering license number is documented in this notice, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of a fine and imprisonment.

 Name (print)

 Signature and Date

 Title/Organization

 Address of Responsible Official

This Application is for Groundwater Treatment Facility located at (provide street address):

This NOI form and all required attachment shall be uploaded to Geo-Tracker, http://www.waterboards.ca.gov/ust/electronic_submittal/index.shtml (contact Lourdes Gonzales at (510) 622-2365 or lgonzales@waterboards.ca.gov if you have any questions). If electronic submittal is not possible, applicants may submit the NOI package to the following address: California Regional Water Quality Control Board, San Francisco Bay Region, located at 1515 Clay Street, Suite 1400, Oakland, California 94612. Please include a check for \$11,195 (as of December 2011), or the most current fee amount, payable to State Water Resources Control Board.

Table B-1. Mark only one as applicable

1	This is a new discharge.	
2	This discharge is currently authorized under Order No. R2-2009-0059 (VOC General Permit), which requires authorized dischargers, who need to continue discharging after September 30, 2014, to file a completed NOI form no later than April 3, 2014.	
3	This discharge is currently authorized under this Order (VOC and Fuel General Permit), which requires authorized dischargers who need to continue discharging after January 11, 2017, to file a completed NOI form no later than July 15, 2016.	
4	This discharge is currently authorized under this Order (VOC and Fuel General Permit) and this Form is submitted for modification of the current Authorization to	

	Discharge.	
--	------------	--

Table B-2. Mark or provide information as applicable

1	I have contacted the local sanitary sewer agency serving the above address and determined that discharging to the local sanitary sewer system is not a feasible option.	
2	I have contacted the local agencies having jurisdiction over the use of the storm drain system or watercourse and inform them about this proposed discharge.	
3	Approximately, what percentage of the total effluent is reused or will be reused?	%

Table B-3. Facility and Professional Engineer(s) information

1	Facility Name Discharger Name Discharger’s Contact Person Name, Mail Address, Phone number, and Email Address	
2	Authorized Person to Sign & Submit Reports	
3	Billing Information Contact Person Name, Mail Address, Phone number, and Email Address	
4	Design Professional Engineer’s Name, California License Number, Mail Address, Phone Number, and Email Address	
5	Operation and Maintenance Professional Engineer’s Name, California License Number, Mail Address, Phone Number, and Email Address	
6	Groundwater treatment system design capacity as certified by Professional Engineer in gallons per minute (gpm).	_____ gpm
7	Attach design capacity certification report including flow schematics showing every components of the treatment system to this application. The Professional Engineer shall affix his/her stamp including signature and engineering license number to the certification report.	
8	Type of Site or Project. For example: active service station, closed service station, solvent spills/leaks active or closed groundwater cleanup sites, short term	

	dewatering project, long term dewatering Project, or other (please explain if “other”)	
9	Watershed. To determine the watershed, refer to the State of California Watershed Browser located online at www.conservation.ca.gov/dlrp/watershedportal/Watershed Browser/Pages/WatershedBrowser.aspx or the Guide to San Francisco Bay Area Creeks located online at http://museumca.org/creeks/index.html .	
10	Discharge path to Receiving Water. Please list the complete path of the discharge and attach an aerial map [e.g., the discharge would travel about a quarter of a mile inside a storm drain system before reaching a river (provide the name of the river), and then would travel two miles in the river before reaching the bay].	
11	Project Brief Description and Tentative Completion Date	

Table B-4. Treatment System Description

	Unit	Number	Size or capacity (e.g. pounds of GAC) and Further Description (If Applicable)
1	Total number of extraction well(s) on site		
2	Extraction Wells with Dedicated Treatment Unit(s)		
3	Wellhead Treatment Unit(s)		
4	Settling Tank(s) in series		
5	Settling Tank(s) in parallel		
6	Oil/Water Separator(s)		
7	Filter(s) for particulates in groundwater		
8	Air Strippers with Air Filters		
9	Air Strippers without Air Filters		
10	Other Treatment Unit(s) (e.g. units installed for removing 1,4-dioxane)		
11	Granular Activated Carbon (GAC) Vessel(s) in Series		
12	GAC Vessel(s) in Parallel		
13	Chemical Additives		
14	Effluent Reuse Tank(s)		

Table B-5. Discharge location information

Discharge Point Location	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
Storm Drain Location where discharge enters:	_____ ° _____ ’ _____ ”	_____ ° _____ ’ _____ ”	Not applicable (complete the row below)
Location where discharge enters receiving water either	_____ ° _____ ’ _____ ”	_____ ° _____ ’ _____ ”	

directly or via storm drain system:			
-------------------------------------	--	--	--

Table B-6. List of pollutants (For new and existing discharges. For existing discharges, complete one table for influent and one for effluent)

Monitoring data since effective date of the initial discharge authorization letter, or estimated from groundwater monitoring data for new discharges	Pollutant 1	Pollutant 2	Pollutant 3	Add Columns and/or tables as needed (all detected pollutants with effluent limitations and all triggered pollutants exceeding the triggers shall be listed in this table)
Number of Samples				
Maximum Concentration				
Average Concentration (average of detected pollutants only)				
Number of times the effluent limitation was exceeded				
Median Concentration				
Minimum Concentration				
Number of Non-Detects				
Lowest Reporting Limit				
Highest Reporting Limit				
Number of Samples with Lowest Reporting Limit				
Most recent sample Date, Method Number				

Note: The Regional Water Board may modify this form at any time to reflect any new fees and other needed improvements as applicable.

ATTACHMENT C – NOTICE OF TERMINATION ATTACHMENT C – NOTICE OF TERMINATION

**Complete and Submit to Request Termination of Coverage Under Requirements of General Waste Discharge Requirements for Discharge or Reuse of Extracted and Treated Groundwater resulting from the Cleanup of Groundwater Polluted by Volatile Organic Compounds (VOC), Fuel Leaks, and Other Related Wastes
 NPDES Permit No. CAG912002 (VOC and Fuel General Permit)**

For Groundwater Treatment Facility located at:

 Facility Street Address, City, Zip Code _____
 CIWQS Place Identification Number

A PDF electronic copy of this Form shall be uploaded on GeoTracker and a confirmation email shall be sent to the responsible staff member at this office, currently Lourdes Gonzales, at lgonzales@waterboards.ca.gov.

Table C-1. Mark only one as applicable

1	Temporary groundwater dewatering project, e.g., during a construction project, has been completed.	
2	Groundwater cleanup work has been completed.	
3	Method of groundwater cleanup has been changed with no need to discharge treated groundwater.	
4	Extract and treat method of groundwater cleanup will be stopped for a while and only monitoring of groundwater will occur at this site. Please attach documentation that the agency overseeing cleanup has no objection to cessation of groundwater extraction and treatment.	
5	Other reason. Please specify below (e.g. discharge to POTW has been granted):	

Table C-2. Agency Approval (applicable if Table C-1 row 2, 3, or 4 marked)

	Name, address, email, and phone number of the agency and agency staff overseeing the clean-up work	Have you provided a copy of this termination notice to this staff? (Yes/No. If No, please explain the reason)
1		

I, the Discharger, certify under penalty of law that this notice is prepared under my direction or supervision and last/final date of this Discharge was _____. I am aware that discharging without a discharge authorization is in violation of California Water Code.

 Name (print) _____
 Signature and Date

 Title/Organization (Discharger’s Organization) _____
 Address, email, and phone number

Note: The Regional Water Board may modify this form at any time to reflect the new requirements and other needed improvements.

ATTACHMENT D –STANDARD PROVISIONS**I. STANDARD PROVISIONS – PERMIT COMPLIANCE****A. Duty to Comply**

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 CFR § 122.41(a).)
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 CFR § 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 CFR § 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR § 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 CFR § 122.41(e).)

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 CFR § 122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations (40 CFR § 122.5(c)).

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 CFR § 122.41(i); Wat. Code, § 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 CFR § 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 CFR § 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 CFR § 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (40 CFR § 122.41(i)(4).)

G. Bypass

1. Definitions
 - a. “Bypass” means the intentional diversion of waste streams from any portion of a treatment facility. (40 CFR § 122.41(m)(1)(i).)
 - b. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 CFR § 122.41(m)(1)(ii).)
2. Bypass of extracted groundwater. During a dewatering project, the Discharger may allow any bypass of uncontaminated extracted groundwater to occur which originates from uncontaminated extraction well(s). The Discharger shall monitor the water quality of these extractions wells to confirm that the extracted water remains uncontaminated. The Discharger may also allow any bypass to occur which does not cause exceedances of effluent limitation, but only if it is for essential maintenance to assure efficient operation. In this case, weekly monitoring results of pollutants of concern shall be reported in the quarterly monitoring reports.
3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 CFR § 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR § 122.41(m)(4)(i)(A));

- b. There were no feasible alternatives to the bypass, such as turning off the extraction wells pump(s), discharge to a POTW, retention of untreated wastes, maintenance during normal periods of equipment downtime, or the use of auxiliary treatment facilities. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 CFR § 122.41(m)(4)(i)(B)); and
 - c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 CFR § 122.41(m)(4)(i)(C).)
4. The Regional Water Board may not take enforcement action against a Discharger for bypass, if the Regional Water Board determines that the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above have been met. (40 CFR § 122.41(m)(4)(ii).)
 5. Notice
 - a. Anticipated bypass of uncontaminated extracted groundwater. If the Discharger knows in advance of the need for a bypass of uncontaminated extracted groundwater, it shall submit the necessary information in the initial or modified Notice of Intent, if possible at least 45 days before the date of the bypass. The necessary information includes but not limited to the name and number of extraction wells, flow rates for each well, the distance to other contaminated wells, and monitoring data such as turbidity, color, conductivity, pH, temperature, metals, TPH, VOC, SVOC, PAHs, Oxygenates.
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 CFR § 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 CFR § 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 CFR § 122.41(n)(2)).
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR § 122.41(n)(3)):

- a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 CFR § 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 CFR § 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR § 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 CFR § 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 CFR § 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 CFR § 122.41(f).)

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must submit a completed Notice of Intent form (see Attachment B), 180 days in advance of the Order expiration date, to obtain a new permit. (40 CFR § 122.41(b).)

C. Transfers

Any authorization to discharge issued under this Order is not transferable to any person except after filing a modified Notice of Intent with the Regional Water Board. If the new Discharger has a different professional engineer, the modified Notice of Intent shall be revised accordingly.\

III. STANDARD PROVISIONS – MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 CFR § 122.41(j)(1).)
- B. Monitoring results must be conducted according to test procedures under 40 CFR Part 136 or other test procedures specified in this Order. (40 CFR § 122.41(j)(4); § 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A. The Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to

complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time (40 CFR § 122.41(j)(2).)

B. Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements (40 CFR § 122.41(j)(3)(i));
2. The individual(s) who performed the sampling or measurements (40 CFR § 122.41(j)(3)(ii));
3. The date(s) analyses were performed (40 CFR § 122.41(j)(3)(iii));
4. The individual(s) who performed the analyses (40 CFR § 122.41(j)(3)(iv));
5. The analytical techniques or methods used (40 CFR § 122.41(j)(3)(v)); and
6. The results of such analyses. (40 CFR § 122.41(j)(3)(vi).)

C. Claims of confidentiality for the following information will be denied (40 CFR § 122.7(b)):

1. The name and address of any permit applicant or Discharger (40 CFR § 122.7(b)(1)); and
2. Permit applications and attachments, permits and effluent data. (40 CFR § 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 CFR § 122.41(h); California Water Code (CWC), § 13267.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 CFR § 122.41(k).)
2. All permit applications shall be signed by a responsible person as explained below:
 - a. **For a corporation.** All permit applications shall be signed by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means: (i) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy- or decision-making functions for the corporation, or (ii) the manager of one or more manufacturing,

- production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures. (40 CFR § 122.22(a)(1).)
- b. **For a partnership or sole proprietorship.** All permit applications shall be signed by a general partner or the proprietor, respectively. (40 CFR § 122.22(a)(2).)
- c. **For a municipality, State, federal, or other public agency.** All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 CFR § 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
- a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 CFR § 122.22(b)(1));
- b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 CFR § 122.22(b)(2)); and
- c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 CFR § 122.22(b)(3).)
4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 CFR § 122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 CFR § 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 CFR § 122.22(1)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form (40 CFR § 122.41(1)(4)(i).) or paper or electronic forms provided or specified by the Regional Water Board or State Water Board.
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or other reporting form specified by the Regional Water Board. (40 CFR § 122.41(1)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 CFR § 122.41(1)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 CFR § 122.41(1)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be uploaded on GeoTracker (http://www.waterboards.ca.gov/ust/electronic_submission/index.shtml) within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 CFR § 122.41(1)(6)(i).)

2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 CFR § 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 CFR § 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 CFR § 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 CFR § 122.41(l)(6)(iii).)

F. Planned Changes

The discharger shall file with the Executive Officer an amended Notice of Intent at least 60 days before making any material change in the character, location, or volume of the discharge. In case of proposing any change of treatment system or operation and maintenance procedures, a professional engineer certified in State of California shall certify the adequacy of the design and/or the procedures. A modified Notice of Intent is required under this provision only when (40 CFR § 122.41(l)(1)) the alteration or addition could significantly change the nature or increase the quantity of pollutants discharged (pollutants regulated or not regulated by this Order). Three examples of significant changes are a change in discharge location, a change of the engineer responsible for the design and/or operation and maintenance of the treatment system, and an increase in discharge flow rates.

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with the requirements in this Order. (40 CFR § 122.41(l)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 CFR § 122.41(l)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 CFR § 122.41(l)(8).)

VI. STANDARD PROVISIONS – ENFORCEMENT

The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Non-Municipal Facilities

Existing manufacturing, commercial, mining, and silvicultural Dischargers shall notify the Regional Water Board as soon as they know or have reason to believe (40 C.F.R. § 122.42(a)):

1. That any activity has occurred or will occur that would result in the discharge, on a routine or frequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" (40 C.F.R. § 122.42(a)(1)):
 - a. 100 micrograms per liter ($\mu\text{g/L}$) (40 C.F.R. § 122.42(a)(1)(i));
 - b. 200 $\mu\text{g/L}$ for acrolein and acrylonitrile; 500 $\mu\text{g/L}$ for 2,4-dinitrophenol and 2-methyl-4,6-dinitrophenol; and 1 milligram per liter (mg/L) for antimony (40 C.F.R. § 122.42(a)(1)(ii));
 - c. Five (5) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge (40 C.F.R. § 122.42(a)(1)(iii)); or
 - d. The level established by the Regional Water Board in accordance with section 122.44(f). (40 C.F.R. § 122.42(a)(1)(iv).)
2. That any activity has occurred or will occur that would result in the discharge, on a non-routine or infrequent basis, of any toxic pollutant that is not limited in this Order, if that discharge will exceed the highest of the following "notification levels" (40 C.F.R. § 122.42(a)(2)):
 - a. 500 micrograms per liter ($\mu\text{g/L}$) (40 C.F.R. § 122.42(a)(2)(i));
 - b. 1 milligram per liter (mg/L) for antimony (40 C.F.R. § 122.42(a)(2)(ii));
 - c. Ten (10) times the maximum concentration value reported for that pollutant in the Report of Waste Discharge (40 C.F.R. § 122.42(a)(2)(iii)); or
 - d. The level established by the Regional Water Board in accordance with section 122.44(f). (40 C.F.R. § 122.42(a)(2)(iv).)

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Contents

I. General Monitoring Provisions.....E-2
 II. Monitoring Locations.....E-2
 III. Influent Monitoring Requirements.....E-3
 IV. Effluent Monitoring RequirementsE-3
 V. Whole Effluent Acute Toxicity Testing Requirements.....E-3
 VI. Reclamation Monitoring RequirementsE-4
 VII. Receiving Water Monitoring Requirements – Surface Water and Groundwater E-4
 VIII. Other Monitoring RequirementsE-6
 IX. Reporting RequirementsE-8
 A. General Monitoring and Reporting Requirements.....E-8
 B. Self Monitoring Reports (SMRs).....E-8
 C. Discharge Monitoring Reports (DMRs) - Not Applicable.....E-12
 D. Other ReportsE-12

Tables

Table E-1. Monitoring Station LocationsE-2
 Table E-2. Schedule for Sampling, Measurements, and AnalysisE-4
 Table E-3. SMR Reporting for CIWQS.....E-10
 Table E-4. Monitoring Periods and Reporting ScheduleE-11

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

National Pollutant Discharge Elimination System (NPDES) regulations at 40 CFR 122.48 require that all NPDES permits specify monitoring and reporting requirements. California Water Code (CWC) Sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This Monitoring and Reporting Program establishes monitoring and reporting requirements that implement the federal and State regulations.

I. GENERAL MONITORING PROVISIONS

- A.** The Discharger shall comply with this Monitoring and Reporting Program. The Executive Officer may amend this Monitoring and Reporting Program pursuant to 40 CFR 122.62, 122.63, and 124.5.
- B.** The Discharger shall conduct all monitoring in accordance with Attachment D, section III, and all tests must be performed by laboratories certified for the analyses in accordance with the California Water Code Section 13176. Equivalent test methods must be more sensitive than those specified in 40 CFR 136 and must be specified in the permit or in the related discharge authorization letter.
- C.** Monthly discharge flow volume, total quarterly flow, and annual flow shall be recorded.
- D.** The number and frequency of bypasses and accidental spills shall be recorded.
- E.** A copy of this Order, a complete copy of the Notice of Intent (NOI) filed, documentation of the Authorization to Initiate Discharge received from the Regional Water Board, a full copy of the Operation and Maintenance (O&M) Manual, and any other documents relevant to the operation and maintenance of the treatment facility shall be stored at or near the treatment facility, and made available to Regional Water Board staff, U.S. EPA staff, or their contractors upon request. The Discharger shall inspect its facility as frequently as required by the O&M Manual.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-1. Monitoring Station Locations

Discharge Point Name (if applicable)	Monitoring Location Name	Monitoring Location Description (include Latitude and Longitude when available)
---	INF-001	At a point in the extraction system immediately prior to inflow to the treatment unit.
001	EFF-001	At a point in the discharge line immediately following treatment and before it joins or is diluted by any other waste stream, body of water, or substance.
---	RSW-001U	At a point 50 feet upstream from the point of discharge into the receiving water, or if access is limited, at the first point upstream which is accessible.
---	RSW-001D	At a point 50 feet downstream from the point of discharge into the receiving water, or if access is limited, at the first point downstream which is accessible.

Discharge Point Name (if applicable)	Monitoring Location Name	Monitoring Location Description (include Latitude and Longitude when available)
---	REU-001	At a point immediately prior to reuse location. Not applicable if effluent is not reused or reclaimed.

III. INFLUENT MONITORING REQUIREMENTS

The Discharger shall monitor influent to the facility at Monitoring Location INF-001 in accordance with the schedule shown on Column 1 of Table E.2.

IV. EFFLUENT MONITORING REQUIREMENTS

Dischargers shall monitor discharges of treated wastewater from the facility at Monitoring Location EFF-001, in accordance with the schedule shown on Column 2 of Table E.2. Effluent sampling shall occur concurrently (within 30 minutes) with influent sampling.

- A. Monitoring during bypass.** When any type of bypass occurs, grab samples shall be collected on a daily basis for all constituents at all affected discharge points that have effluent limits for the duration of the bypass.
- B. Required Actions After Any Effluent Violation.** If the analytical results show violation of any effluent limitation, the Discharger shall take a confirmation effluent sample, together with receiving water samples (see Column 3 of Table E-2) within 24 hours of becoming aware of the violation of effluent limit. The Discharger must have the confirmation sample analyzed by expedited methods and obtain results within 24 hours of sample collection. If the analytical results are also in violation of the effluent limit, the Discharger shall terminate the discharge until it has corrected the cause of violation. In this case, both the initial and confirmed results are violations. However, if the confirmation effluent sampling shows compliance, the Regional Water Board will consider only the initial exceedance as a violation.

V. WHOLE EFFLUENT ACUTE TOXICITY TESTING REQUIREMENTS

The Discharger shall monitor acute toxicity at EFF-001 as follows.

- A.** Compliance with the acute toxicity effluent limitations of this Order shall be evaluated by measuring survival of test organisms to 96-hour static renewal bioassays at Monitoring Location EFF-001.
- B.** Test organisms shall be rainbow trout unless the Executive Officer specifies otherwise in writing.
- C.** All bioassays shall be performed according to the most up-to-date protocols in 40 CFR 136m currently in *Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms*, 5th Edition.
- D.** If specific identifiable substances in the discharge can be demonstrated by the Discharger as being rapidly rendered harmless upon discharge to the receiving water, compliance with the acute toxicity limitation may be determined after the test samples are adjusted to remove the influence of those substances. Written approval from the Executive Officer must be obtained to authorize such an adjustment.

- E. The sample may be taken from effluent prior to chlorination. Monitoring of the bioassay water shall include, on a daily basis, the following parameters: pH, dissolved oxygen, ammonia, (if toxicity is observed), temperature, hardness, and alkalinity. These results shall be reported. If a violation of acute toxicity requirements occurs, the bioassay test shall be repeated with new fish as soon as practical and shall be repeated until a test fish survival rate of 90 percent or greater is observed. If the control fish survival rate is less than 90 percent, the bioassay test shall be restarted with new fish and shall continue as soon as practical until an acceptable test is completed (i.e., control fish survival rate is 90 percent or greater).

VI. RECLAMATION MONITORING REQUIREMENTS

The Discharger shall monitor reuse effluent at Monitoring Location REU-001, as shown on Column 2 of Table E.2.

VII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER AND GROUNDWATER

The Discharger shall monitor receiving water at Monitoring Locations RSW-001U and RSW-001D as shown on Column 3 of Table E.2.

- A. Receiving water sampling shall occur concurrently with effluent sampling.
- B. Receiving water samples shall be collected at each station on each sampling day during the period within 1 hour following low slack water. Where sampling at lower slack water period is not practical, sampling shall be performed during higher slack water period. Samples shall be collected within the discharge plume and 50 feet down current of the discharge point so as to be representative, unless otherwise stipulated.
- C. Samples should be collected within one foot below the surface of the receiving water body. Explanation shall be provided in the monitoring report if this specification could not be met.

Table E-2. Schedule for Sampling, Measurements, and Analysis

Required Analytical Test Method Number, Technique, Standard Methods (SM), USEPA Method Number (EPA), 40 CFR Part (or equivalent)/Sampling Station	Column 1 Minimum Sampling Frequency for Influent INF-001	Column 2 Minimum Sampling Frequency for Effluent EFF-001 or Effluent for Reuse REU-001	Column 3 Minimum Sampling Frequency for Receiving Surface Water RSW-001U and RSW-001D
Unit is “µg/L” and Type of Sample is “Grab” unless noted otherwise	Grab	Grab	Grab
Discharge Flow (gpm & gpd)		Continuous	
Reclamation Flow Rate (gpm & gpd or gallons reclaimed during the calendar quarter if reclamation is not continuous)		Continuous	
Fish Toxicity, 96-hr (% survival), EPA-821-R-02-012 Test, Method 2019.0		Q/Y	
All Applicable Standard Observations (No Unit)	D/M	D/M	V
Volatile Organic Compounds, EPA 8260b	2/Y	D/M	V
1,4-Dioxane (See Footnotes 1 and 3), EPA 8270c		2/Y	
Semi Volatile Organic Compounds except PAHs (See Note 1), EPA 8270c	D/Q	D/M	
Turbidity		D/Q/Y	

Required Analytical Test Method Number, Technique, Standard Methods (SM), USEPA Method Number (EPA), 40 CFR Part (or equivalent)/Sampling Station	Column 1 Minimum Sampling Frequency for Influent INF-001	Column 2 Minimum Sampling Frequency for Effluent EFF-001 or Effluent for Reuse REU-001	Column 3 Minimum Sampling Frequency for Receiving Surface Water RSW-001U and RSW-001D
Unit is “µg/L” and Type of Sample is “Grab” unless noted otherwise	Grab	Grab	Grab
pH	D/M/Q/Y	D/M/Q/Y	V
Dissolved Oxygen (mg/L)			V
Total Dissolved Solids (mg/L) (construction and dewatering projects)		D/M	
Temperature (°C)		D/M/Q/Y	
Electrical Conductivity		D/M/Q/Y	
Hardness (mg/L as CaCO ₃)			T
Salinity (parts per thousand)			T
Ethylene Dibromide (EDB) (See Footnote 1), 504	D/Q	D/M	V
Benzene, Toluene, Ethylbenzene, and/or Total Xylenes (See Footnote 1), EPA 8020	D/Q	D/M	V
Methyl Tertiary Butyl Ether (MTBE) (See Footnote 1), EPA 8020	D/Q	D/M	V
Total Petroleum Hydrocarbons as Gasoline (See Footnote 1), EPA 8015 Modified	D/Q	D/M	V
Total Petroleum Hydrocarbons as Diesel (See Footnote 1), EPA 8015 Modified	D/Q	D/M	V
Total Petroleum Hydrocarbons other than Gasoline and Diesel (required if Petroleum Hydrocarbons other than Gasoline and Diesel present in the soil and groundwater) (See Footnote 1), EPA 8015 Modified	D/Q	D/M	V
Polynuclear Aromatic Hydrocarbons (PAHs) (See Footnote 1), 8310	D/Q	D/M	V
Tertiary Amyl Methyl Ether (TAME), Diisopropyl Ether (DIPE), Ethyl Tertiary Butyl Ether (ETBE), Tertiary Butyl Alcohol (TBA), Ethanol, and/or Methanol (See Footnote 1)	D/Y	D/Y	
Total Chlorine Residual (See Footnote 1), (Field Kit, EPA 330 or SM 4500-Cl)	D/Q	D/M	V
Ammonia as Nitrogen (See Footnote 1), SM 450NH ₃ B+C or D	D/Q	D/M	
BOD ₅ (See Footnote 1), SM 5210B	D/Q	D/M	
Total Suspended Solids (See Footnote 1), SM 2540D	D/Q	D/M	
Antimony (EPA 204.2), Arsenic (EPA 206.3), Beryllium (GFAA or ICPMS), Cadmium (GFAA or ICPMS), Hexavalent and Total Chromium (SM 3500), Copper (EPA 200.9), Cyanide (SM 4500-CN C or I), Lead (EPA 200.9), Mercury (EPA 1631), Nickel (EPA 249.2), Selenium (SM 3114B OR C), Silver (EPA 272.2), Thallium (EPA 279.2), and Zinc (EPA 200.8) (See Note 2)		D/Y	
Other pollutants such as non VOC-related odor, sulfate and foaming agents (See Footnote 1), SM	D/Q	D/M	V
Notes:			
Note 1: if known to be present in the influent			
Note 2: Inorganic compounds samples shall be analyzed for total (unfiltered) constituents with the reporting levels not exceeding the following: 0.002 ug/l for Mercury; 0.25 ug/l for Cadmium and Silver; 1 ug/l for Nickel, Thallium, and Zinc; 2.0 ug/l for Arsenic and Selenium; 1 ug/l for Cyanide; and 0.5 ug/l for Antimony, Beryllium, Total Chromium, Copper, and Lead (SIP Appendix 4 Minimum Levels http://www.waterboards.ca.gov/iswp/docs/final.pdf). If the Discharger exceeds the trigger for mercury of 0.025, the Discharger may consider re-sampling and re-analyzing another sample using ultra-clean techniques as described in USEPA methods 1669 and 1631 to eliminate the possibility of artifactual contamination of the sample.			
Note 3: Use techniques such selective ion mode or isotope dilution to achieve reporting levels below 3 ug/l.			
Definitions: ug/L = microgram per liter or parts per billion (ppb); g/day = grams per day; gpm = gallons per minute; mg/L = milligram per liter or parts per million (ppm); gpd = gallons per day; MFL = million fibers per liter			

Required Analytical Test Method Number, Technique, Standard Methods (SM), USEPA Method Number (EPA), 40 CFR Part (or equivalent)/Sampling Station	Column 1 Minimum Sampling Frequency for Influent INF-001	Column 2 Minimum Sampling Frequency for Effluent EFF-001 or Effluent for Reuse REU-001	Column 3 Minimum Sampling Frequency for Receiving Surface Water RSW-001U and RSW-001D
Unit is “µg/L” and Type of Sample is “Grab” unless noted otherwise	Grab	Grab	Grab

GC = Gas Chromatography; GCMS = Gas Chromatography/Mass Spectrometry; FAA = Flame Atomic Absorption; GFAA = Graphite Furnace Atomic Absorption; Hydride = Gaseous Hydride Atomic Absorption; ICP = Inductively Coupled Plasma; and ICPMS = Inductively Coupled Plasma/Mass Spectrometry.

Legends:
 D/M Once during the first and fifth day of startup; monthly thereafter. For VOC, if a discharger has no VOC detected in the influent or the effluent other than Total Petroleum Hydrocarbons, Benzene, Toluene, Ethylbenzene, Xylenes, Tertiary Amyl Methyl Ether (TAME), DiIsopropyl Ether (DIPE), Ethyl Tertiary Butyl Ether (ETBE), Tertiary Butyl Alcohol (TBA), Ethanol, or Methanol then frequency of VOC monitoring may be reduced to once a year.
 D/Q Once during the first and fifth day of startup; quarterly thereafter.
 Y Once during the first week of startup; annually thereafter.
 2/Y Once during the first week of startup; twice per year thereafter.
 D/Y Once during the first and fifth day of startup; annually thereafter.
 Q/Y Quarterly for first year of operation, annually thereafter.
 D/Q/Y Once during the first and fifth day of startup; quarterly for first year of operation, annually thereafter.
 D/M/Q/Y Once during the first and fifth day of startup; monthly for first year of operation, quarterly for the second year, and annually thereafter. In case of pH analysis, this monitoring requirement is only for facilities with a treatment process that would cause no pH variances in the effluent. If any chemical used in the treatment process may cause pH variances in the effluent, the frequency of pH monitoring in the effluent shall be increased to twice per week for the first month of operation and weekly thereafter if pH monitoring data for the first month of operation demonstrate compliance with pH effluent limits.
 V Receiving Waters sampling must be performed together (on the same calendar day) with the required effluent confirmation sampling that is required when a violation of an effluent limit is known, and the sample analyzed for that specific violated parameter and the Dissolved Oxygen level. In no case, should a Discharger continue discharging in known violation of effluent limits just to comply with this receiving water sampling requirement.
 T Sampling shall be performed when Cadmium, Chromium (total), Copper, Lead, Nickel, Silver, or Zinc triggers are exceeded.

VIII. OTHER MONITORING REQUIREMENTS

A. Startup Phase Monitoring. During the original startup for the treatment system, sampling of the effluent must occur on the first day and fifth day of operation (weekend days may be excluded).

1. On the first day of the original startup, the system shall be allowed to run until at least three to five well volumes are removed and until three consecutive readings for pH, conductivity, and temperature are within five percent of each other; then, the influent and effluent shall be sampled and submitted for analyses. Prior to receipt of the results of the initial samples, all effluent shall be discharged into a holding tank (that is contained, not discharged to the receiving water) or discharged to the sanitary sewer until the results of the analyses show the discharge to be within the effluent limits established in this Order and/or as authorized by the Executive Officer. The treatment system may be shut down after the first day's sampling to await the analyses results and thereby reduce the amount of storage needed. For the stored effluent, if the results of the analyses show the discharge to be in violation, the effluent shall: (1) be retreated until the retreated effluent is in compliance, or (2) be disposed of in accordance with the applicable provisions of California Code of Regulations.
2. If the first day's sampling shows compliance, the treatment system shall be operated for a total of five days with the discharge to the storm sewer or other conveyance system leading to the receiving water, and be sampled again during the fifth day. While the fifth day's samples are being analyzed, the effluent may be discharged to the receiving water as long as the

analyses are received within 72 hours of sampling, and then, continue to be discharged to the receiving water if the analyses show compliance. Otherwise, the original startup procedures and sampling must be repeated. If the treatment system is shut down more than 72 hours during the original startup (awaiting analyses results, etc.), the original startup procedures and sampling must be repeated.

B. Chemical Additives Monitoring: If applicable, monitoring related to chemical usage shall be conducted by the Discharger as required in its treatment system design specification and Operation and Maintenance Manual.

C. Standard Observations for Receiving Water

1. Floating and suspended materials (e.g., oil, grease, algae, and other macroscopic particulate matter): presence or absence, source, and size of affected area.
2. Discoloration and turbidity: description of color, source, and size of affected area.
3. Odor: presence or absence, characterization, source, distance of travel, and wind direction.
4. Beneficial water use: presence of water-associated waterfowl or wildlife, fisherperson, and other recreational activities in the vicinity of each sampling station.
5. Hydrographic condition, if relevant:
 - a. Time and height of corrected high and low tides (corrected to nearest National Oceanic and Atmospheric Administration location for the sampling date and time of sample and collection).
 - b. Depth of water columns and sampling depths.
6. Weather condition:
 - a. Air temperature.
 - b. Wind direction and estimated velocity.
 - c. Total precipitation during the five days prior to observation.

E. Standard Observations for Onsite Usage of Reclaimed Water

1. Floating and suspended materials of waste origin (to include oil, grease, algae, and other macroscopic particulate matter): presence or absence, source, and size of affected area.
2. Discoloration and turbidity: description of color, source, and size of affected area.
3. Odor: presence or absence, characterization, source, distance of travel, and wind direction.
4. Weather condition:
 - a. Air temperature.

- b. Wind direction and estimated velocity.
 - c. Total precipitation during the previous five days and on the day of observation.
5. Deposits, discolorations, and/or plugging in the conveyance system that could adversely affect the system reliability and performance.
 6. Operation of the valves, outlets, sprinkler heads, and/or pressure shutoff valves in conveyance system.

F. Standard Observations for Groundwater Treatment System

1. Odor: presence or absence, characterization, source, distance of travel, and wind direction.
2. Weather condition: wind direction and estimated velocity.
3. Deposits, discolorations, and/or plugging in the treatment system (stripping tower, carbon filters, etc.) that could adversely affect the system reliability and performance.
4. Operation of the float and/or pressure shutoff valves installed to prevent system overflow or bypass.

IX. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

The Discharger shall comply with all Standard Provisions (Attachment D) and in this document related to monitoring, reporting, non-compliance reporting, and record keeping.

B. Self Monitoring Reports (SMRs)

1. **SMR Format.** At any time during the term of this Order, the State or Regional Water Board may notify the Discharger to electronically submit SMRs using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). The CIWQS website will provide additional directions for SMR submittal. In the interim, the Dischargers shall submit SMRs using the submittal method specified in the Authorization to Discharge letter.
2. **SMR Due Dates and Contents.** The Discharger shall submit SMRs by the due dates, and with the contents, specified below:
 - a. The Discharger shall submit quarterly SMRs no later than 45 days after the end of each calendar quarter, including the results of all required monitoring.
 - b. The Discharger shall submit annual reports by February 15 of each year, covering the previous calendar year. The annual report shall contain all data required for the fourth quarter in addition to summary data required for annual reporting. This report may be submitted in lieu of the report for the fourth quarter of a calendar year.

- c. The Discharger shall report in the SMR the results for all monitoring specified in this Monitoring and Reporting Program under sections III through VIII. If there has been no discharge during the entire reporting period, quarterly and annual reports must still be submitted to report that has been the case.
- d. The Discharger shall attach a cover letter to the monitoring reports. The information contained in the cover letter shall clearly identify number of permit violations; discuss corrective actions taken or planned; and the proposed time schedule for corrective actions. Identified violations must include a description of the requirement that was violated and a description of the violation. In the cover letter, the Discharger shall also document the volume of the effluent reused during that reporting period.
- e. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with the effluent limitations. The Discharger shall not include laboratory reports unless requested.
- f. Monitoring reports must be submitted to the Regional Water Board signed, certified, and using the submittal method specified by the Authorization to Discharge letter.
- g. The monitoring reports shall also include a description of operation and maintenance (O&M) of the groundwater extraction and treatment system consistent with the O&M manual, which shall be available to all personnel who are responsible for operation and maintenance activities.
- h. The monitoring reports shall include the results of analyses and observations as follows:
 - (1) Calculations for all limitations that require averaging of measurements shall utilize an arithmetic mean unless otherwise specified in this permit.
 - (2) A table identifying by method number the analytical procedures used for analyses. Any special methods shall be identified and should have prior approval of the Regional Water Board's Executive Officer.
 - (3) Laboratory results shall be summarized in tabular form but actual laboratory reports do not need to be included in the report. A summary of quality assurance/quality control activities data such as field, travel, and laboratory blanks shall be reported for each analyzed constituent or group of constituents.
 - (4) A summary of the monitoring data to include information such as source of the sample (influent, effluent, or receiving water); the constituents; the methods of analysis used; the laboratory reporting limits in $\mu\text{g/L}$; the sample results ($\mu\text{g/L}$); the date sampled; and the date sample was analyzed.
 - (5) Flow (in gpm) and mass removal data (in kilograms).
 - (6) Summary of treatment system status during the reporting period (e.g., in operation/on standby) and reason(s) for non-routine treatment system shut down.

- (7) The annual reports shall contain tabular summary of the monitoring data obtained during the previous year. In addition, the annual reports shall contain a comprehensive discussion of the compliance record and the corrective actions taken or planned which may be needed to bring the Discharger into full compliance with the waste discharge requirements including any trigger study required by Special Provision VI.C.6 and the progress in satisfaction of Special Provisions VI.C.7 and VI.C.8 of this Order. The annual report shall document that the annual fee has been paid.
- (8) If, during any calendar quarter, a Discharger becomes aware that any monitoring data obtained for compliance with this Order may be invalid, the Discharger shall submit a claim of invalid monitoring data, as uploaded on GeoTracker with a confirmation email to the Regional Water Board staff in charge of this permit, within 45 days after end of that calendar quarter. The Discharger shall include with this claim, the name, phone number, and email of its assigned staff to investigate the cause(s) of errors and the corrective actions taken, or date when actions will be completed to eliminate or reduce future data errors. The Discharger shall also provide, in this claim, a date that the O&M Manual will be updated to include errors prevention measures. These preventive measures shall include but not be limited to accelerated monitoring (e.g., twice a month monitoring for at least one month) to provide valid monitoring data indicating the effectiveness of the proposed preventive measures.
- i. Additional Specifications for Submitting SMRs to CIWQS — If the Discharger submits SMRs to CIWQS, it shall submit analytical results and other information using one of the following methods:

Table E-3. SMR Reporting for CIWQS

Parameter	Method of Reporting	
	EDF/CDF data upload or manual entry	Attached File
All parameters identified in influent, effluent, and receiving water monitoring tables (except Dissolved Oxygen and Temperature)	Required for All Results	
Dissolved Oxygen Temperature	Required for Monthly Maximum and Minimum Results Only ⁽¹⁾	Discharger may use this method for all results or keep records
Cyanide Arsenic Cadmium Chromium Copper Lead Mercury Nickel Selenium Silver Zinc Dioxins and Furans (by U.S. EPA Method 1613)	Required for All Results ⁽²⁾	
Antimony	Not Required	Discharger may use this

Beryllium Thallium Pollutants by U.S. EPA Methods 601, 602, 608, 610, 614, 624, and 625	(unless identified in influent, effluent, or receiving water monitoring tables), But Encouraged ⁽¹⁾	method and submit results with application for permit reissuance, unless data submitted by CDF/EDF upload
Analytical Method	Not Required (Discharger may select “data unavailable”) ⁽¹⁾	
Collection Time Analysis Time	Not Required (Discharger may select “0:00”) ⁽¹⁾	

Footnotes for Table E-5:

- [1] The Discharger shall continue to monitor at the minimum frequency specified in the monitoring tables, keep records of the measurements, and make the records available upon request.
- [2] These parameters require EDF/CDF data upload or manual entry regardless of whether monitoring is required by this Monitoring and Reporting Program or other provisions of this Order (except for biosolids, sludge, or ash provisions).

3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-4. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period
Continuous	Effective startup date	All
Daily	Effective startup date	(Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling.
Weekly	Effective startup date	Effective startup day through one week after Effective startup date
Monthly	First day of calendar month following the last day of the startup date	1 st day of calendar month through last day of calendar month
Quarterly	Closest of January 1, April 1, July 1, or October 1 following (or on) the last day of the startup date	January 1 through March 31 April 1 through June 30 July 1 through September 30 October 1 through December 31
Semiannually	Closest of January 1 or July 1 following (or on) the last day of the startup date	January 1 through June 30 July 1 through December 31
Annually	January 1 following (or on) the last day of the start -up date	January 1 through December 31

- 4. **ML and MDL Reporting.** The Discharger shall report with each sample result the applicable Reporting Level (RL) and the current Method Detection Limit (MDL), as determined by the procedure in 40 CFR Part 136. The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:
 - a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).

- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported. For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc.>"). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.
- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
- d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from *extrapolation* beyond the lowest point of the calibration curve.

C. Discharge Monitoring Reports (DMRs) - Not Applicable

D. Other Reports

1. Startup Report: A report on the startup phase shall be included in the first quarterly monitoring report. This report shall include a certification that a professional engineer certified in the State of California oversees the treatment system operation and maintenance activities including the startup work.
2. Spill Reports: If any hazardous substance is discharged in or on any waters of the state, or discharged and deposited where it is, or probably will be discharged in or on any waters of the state, the Discharger shall report such a discharge to this Regional Water Board, at (510) 622-2369 and to the California Emergency Management Agency at (800) 852-7550 within 24 hours of becoming aware of the spill. A written report shall be uploaded on GeoTracker, with an confirmation email to staff, within five (5) working days and shall contain information relative to:
 - a. Nature of waste or pollutant,
 - b. Quantity involved,
 - c. Duration of incident,
 - d. Cause of spilling,
 - e. Spill Prevention, Control, and Countermeasure Plan (SPCC) in effect, if any,
 - f. Estimated size of affected area,
 - g. Nature of effects (i.e., fish kill, discoloration of receiving water, etc.),

- h. Corrective measures that have been taken or planned, and a schedule of these activities, and
 - i. Persons/agencies notified.
- 3. Reports of Treatment Unit Bypass and Permit Violation:** In the event the Discharger violates or threatens to violate the conditions of the waste discharge requirements and prohibitions or intends to permit a treatment unit bypass, the Discharger shall notify the Regional Water Board within 24 hours of when the Discharger or Discharger's agent has knowledge of the incident and confirm this notification in writing and uploaded on GeoTracker with a confirmation email to Regional Water Board staff, within 5 working days of the initial notification. The written report shall include time, date, duration and estimated volume of waste bypassed, method used in estimating volume and person notified of the incident. The report shall include pertinent information explaining reasons for the noncompliance and shall indicate what steps were taken to prevent the problem from recurring.

A treatment unit bypass may occur due to:

- a. Maintenance work, power failures, or breakdown of waste treatment equipment,
 - b. Accidents caused by human error or negligence,
 - c. The self-monitoring program results exceeding effluent limitations,
 - d. Any activity that would result in a frequent or routine discharge of any toxic pollutant not limited by this Order, or
 - e. Other causes, such as acts of nature.
- 4. Additional Reporting:** If a violation of the effluent limitations should occur, the Discharger shall direct the effluent to a holding tank and contained, or the extraction and treatment system shall be shut down. The confirmation sampling shall be conducted when the discharge is directed to a holding tank and contained or right before the extraction and treatment system is shut down. The content of the holding tank shall be retreated until the retreated effluent is in compliance, be discharged to a publicly owned treatment works (POTW), or be disposed in accord with the provisions of applicable California Code of Regulations. The Discharger shall obtain permission from the POTW for any temporary or permanent discharges to the sanitary sewer. All confirmation sampling results shall be reported.

ATTACHMENT F – FACT SHEET

Contents

I. Permit Information.....	F-3
II. Facility Description	F-6
A. Description of Wastewater Treatment	F-6
B. Discharge Points and Receiving Waters	F-6
C. Summary of Existing Requirements	F-6
D. Compliance Summary.....	F-8
E. Planned Changes.....	F-8
III. Applicable Plans, Policies, and Regulations	F-8
A. Legal Authorities.....	F-8
B. California Environmental Quality Act (CEQA)	F-9
C. State and Federal Regulations, Policies, and Plans.....	F-9
D. Impaired Water Bodies on CWA 303(d) List	F-10
IV. Rationale For Effluent Limitations and Discharge Specifications.....	F-11
A. Discharge Prohibitions.....	F-11
B. Shallow Water Discharges and Basin Plan Discharge Prohibition 1	F-12
C. Technology-Based Effluent Limitations	F-13
D. Water Quality-Based Effluent Limitations (WQBELs)	F-15
E. Reclamation Specifications.....	F-26
V. Rationale for Receiving Water Limitations	F-26
A. Surface Water Limitations	F-26
B. Groundwater Limitations	F-26
VI. Rationale for Monitoring and Reporting Requirements	F-26
A. Influent Monitoring.....	F-27
B. Effluent Monitoring	F-27
C. Whole Effluent Toxicity Testing Requirements	F-27
D. Reporting Requirements	F-28
VII. Rationale for Provisions	F-28
A. Standard Provisions (Provision VI.A)	F-28
B. Monitoring and Reporting Program Requirements (Provision VI.B).....	F-28
C. Special Provisions (Provision VI.C).....	F-28
VIII. Public Participation	F-32
A. Notification of Interested Parties	F-32
B. Written Comments	F-32
C. Public Hearing	F-33
D. Waste Discharge Requirements Petitions	F-33
E. Information and Copying	F-33
F. Register of Interested Persons.....	F-33
G. Additional Information	F-34

Tables

Table F-1. Facility Information.....	F-5
Table F-2. Historic Effluent Limitations.....	F-7
Table F-3. Summary of Technology-Based Effluent Limitations.....	F-14
Table F-4. SSTs for Copper and Nickel for San Francisco Bay	F-18
Table F-5. Summary of RPA Results.....	F-20
Table F-6. Summary of WQBELs	F-23
Table F-7. Summary of Final Effluent Limitations	F-25
Table F-8. Basis for Table 3 Trigger Compounds	F-30

ATTACHMENT F – FACT SHEET

As described in Section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order. This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for dischargers in California. Except where identified as “not applicable”, all sections or subsections are applicable to the discharges regulated under this Order.

This Order is intended to cover discharges of extracted and treated groundwater resulting from the cleanup of groundwater polluted by volatile organic compounds (VOC), fuel leaks, and other related wastes.

I. PERMIT INFORMATION

From 1980 to date, approximately 11,000 sites with underground fuel or VOC storage tanks in the San Francisco Bay Region are known to be leaking or to have leaked. Historically, a number of these sites were cleaned-up by extracting and treating contaminated groundwater, and discharging treated groundwater to surface water. Because the number of such applications exceeded the capacity of available Regional Water Board staff to develop and bring individual waste discharge requirements to the Regional Water Board for adoption, in the early 1990s, the Regional Water Board issued National Pollutant Discharge Elimination System (NPDES) General Permits to cover such discharges.

In 1991, the Regional Water Board issued a NPDES General Permit for the discharge of extracted and treated groundwater resulting from the cleanup of groundwater polluted by fuel leaks and other related wastes at service stations and similar sites (Fuel General Permit). The permit has been reissued three times, in 1996, 2001, and 2006. The 2006 permit (Regional Water Board Order No. R2-2006-0075) expired on January 12, 2012. There are 20 current Dischargers covered under this permit. In 2011, 15 Dischargers submitted Notice of Intent (NOI) applications to either continue discharging or initiate the discharge of treated groundwater to surface water under the Fuel General Permit after it expires.

In 1994, the Regional Water Board issued the first NPDES General Permit for the discharge of extracted and treated groundwater resulting from the cleanup of groundwater polluted by volatile organic compounds (VOC General Permit). The permit was reissued in 1999, 2004, and 2009. The current VOC General Permit (Regional Water Board Order No. R2-2009-0059) was adopted on August 12, 2009, became effective October 1, 2009, and expires September 30, 2014. There are 56 current Dischargers covered under this permit.

The Fuel General Permit needs to be reissued because 15 Dischargers have submitted NOI applications to either continue discharging or initiate the discharge of treated groundwater to surface water. In addition, within the next five years, it is anticipated that a number of fuel contaminated sites will be conducting cleanup by extracting contaminated groundwater, treating, and discharging treated groundwater. Some Publicly Owned Treatment Works (POTWs) do not accept new discharges from groundwater clean-ups, and therefore, a number of sites conducting groundwater

clean-up will require Waste Discharge Requirements from the Regional Water Board for discharge to surface water. The number of clean-ups anticipated exceeds the capacity of available Regional Water Board staff to develop and bring individual waste discharge requirements to the Regional Water Board for adoption. These circumstances create the need for an expedited system to process the anticipated requests. The reissuance of the Fuel General Permit will expedite the processing of requirements, enable the Regional Water Board to better utilize limited staff resources, and permit clean-ups to begin promptly.

What is New in this Permit Reissuance - Because the nature and treatment of pollutants present in fuel-contaminated groundwater and VOC-contaminated groundwater is similar, the Regional Water Board expects to cover both types of discharges under this General Permit. It is also anticipated that the total number of VOC and fuel contaminated sites that will be conducting cleanup by extracting contaminated groundwater, treating, and discharging treated groundwater to surface water will decline. This decline is the result of several factors:

- (i) Fewer open cases as the Regional Water Board close cases, but find not as many new cases to take their place,
- (ii) Significant shift in groundwater cleanup technology away from "pump and treat" and toward in-situ methods, due to the latter's greater effectiveness, and
- (iii) Wider use of the Regional Water Board low-threat closure tool for both fuel and VOC cleanup sites.

For the above reasons, two separate general NPDES permits will not be needed and when the VOC General Permit expires, those requiring continued permit coverage and new dischargers are expected to submit NOI applications for coverage under this Order.

The following VOC and fuel clean-up discharges are normally not eligible for coverage: discharges from clean-ups involving significant contamination by metals, or other conservative pollutants and discharges from sites with other NPDES discharges (e.g., process waste). Dischargers that combine extracted groundwater with stormwater before treatment are normally not eligible for coverage under this Order because the amount of rainwater varies and may exceed the treatment system capacity.

The following table (Table F-1) is a standard template primarily useful for individual permits. For this General Permit, it provides cross-references to the specific sections of the Notice of Intent (NOI) Form, in Attachment B, that each Discharger enrolled under this Order must initially complete and submit as part of the NOI.

Table F-1. Facility Information

California Integrated Water Quality System (CIWQS) Regulatory measure and Place ID	A CIWQS Place ID and Regulatory measure identification number will be assigned to a facility when the Executive Officer issues the Authorization to Initiate Discharge
Discharger	NOI Form in Attachment B
Name of Facility	
Facility Address	
Facility Contact, Title, Phone, and email address	
Consultant Name, Phone, and email address	
Authorized Person to Sign and Submit Reports	
Mailing Address and Contact Person Name, Phone, and email address	
Billing Address and Contact Person Name, Phone, and email address	
Type of Project	
Major or Minor Facility	Minor
Pretreatment Program	Not Applicable
Reclamation Requirements	Producer (See NOI in Attachment B)
Facility Permitted Flow	NOI Form in Attachment B
Facility Design Flow	
Watershed	
Receiving Water Type	

- A. Site Owners or Operators who apply for an authorization to discharge under this Order and who are granted such authorization are hereinafter called Discharger(s). The groundwater treatment facility is considered the Facility regulated under this Order (hereinafter Facility). For the purposes of this Order, references to the “Discharger(s)” or “permittee(s)” in applicable federal and State laws, regulations, plans, or policy are held to be equivalent to references to the Discharger(s) herein.
- B. The Facilities regulated under the previous general NPDES permit, Regional Water Board Order No. R2-2006-0075, discharge wastewater to multiple receiving waters of the State and/or the United States, mainly in Santa Clara County. The previous permit was adopted on November 13, 2006, became effective on January 12, 2007, and expired on January 12, 2012. The terms and conditions of the previous Order were automatically continued in effect until new Waste Discharge Requirements and NPDES permit are adopted pursuant to this Order. During the term of Order No. R2-2006-0075, 78 facilities were authorized to discharge treated groundwater to the receiving water documented in the NOI submitted for each discharge. Out of 78 facilities, 66 completed groundwater cleanup or changed to different cleanup methods that obviate the need to discharge any treated groundwater.
- C. As of November 2011, 15 Dischargers had filed a report of waste discharge by submitting an NOI to continue their discharge authorization under this NPDES General Permit. In the process of reviewing and approving NOIs, supplemental information may be requested from a subset of these

facilities. It may also be necessary to visit facilities for which an NOI has been submitted, to observe operations and collect additional data to determine the eligibility of authorizing those discharges under this Order. This Order requires Dischargers to submit monitoring data according to the requirements contained in the Monitoring and Reporting Program (Attachment E). If monitoring data indicate significant contamination by metals, pesticides, or other conservative pollutants, Dischargers authorized under this Order may be required to apply for an individual NPDES permit.

II. FACILITY DESCRIPTION

The facilities that may be covered under this Order are groundwater treatment facilities located at active or closed sites with solvent and/or fuel leaks. These groundwater treatment facilities are in operation to extract and treat groundwater polluted mainly by VOC and/or fuel components. This Order covers discharges from these facilities to all surface waters such as creeks, streams, rivers including flood control canals, lakes, or San Francisco Bay. Such discharges may occur directly to surface waters or through constructed storm drain systems.

A. Description of Wastewater Treatment

Dischargers authorized under this Order typically use aeration and/or granular activated carbon (GAC) systems to treat their groundwater prior to discharge. Facilities that use other types of treatment systems that are effective at removal of VOC pollutants may be covered by this Order subject to the approval of the Executive Officer. The most common VOC pollutants contained in the influent of these treatment systems are tetrachloroethylene and trichloroethylene. The most common pollutants contained in groundwater influent that has been contaminated by fuel leaks are benzene, ethylbenzene, toluene, total xylenes, methyl tertiary butyl ether (MTBE), and other petroleum hydrocarbons collectively called total petroleum hydrocarbons (TPHs). Other volatile or semi-volatile organic compounds may also be present in the influent of a subset of facilities regulated under this permit. Less commonly, inorganic pollutants, such as metals, are present in the influent and effluent, and may be naturally occurring.

Except for some inorganic compounds and some other organic compounds such as 1,4 dioxane, the concentrations of organic pollutants in the effluents of the discharges are usually below detectable levels. The reported detection limit for most VOC is 0.5 microgram per liter ($\mu\text{g/L}$); and the reported detection limits for semi-volatile organic compounds are typically 5.0 or 10.0 $\mu\text{g/L}$. The Dischargers reported design flow rates ranging from 5 gpm to 840 gpm, and discharge flow rates ranging from 2.5 gpm to 605 gpm, with an average design flow rate of approximately 121 gpm.

B. Discharge Points and Receiving Waters

The NOI Form (Attachment B) requires every Discharger to provide the discharge location and a map highlighting the discharge path to surface waters.

C. Summary of Existing Requirements

The effluent limitation contained in the previous Fuel General Permit, Regional Water Board Order No. R2-2006-0075, is summarized in Table F-2.

Table F-2. Historic Effluent Limitations

No.	Compound	CAS Number	Column A: Discharge to Drinking Water Areas ^[2]		Column B: Discharge to Other Surface Water Areas	
			Average Monthly Effluent Limitation (µg/L)	Maximum Daily Effluent Limitation (µg/L)	Average Monthly Effluent Limitation (µg/L)	Maximum Daily Effluent Limitation (µg/L)
1	Benzene	71432		1		5
2	Carbon Tetrachloride	56235	0.25 ^[1]	0.50	4.4	5
3	Chloroform	67663		5		5
4	1,1-Dichloroethane	75343		5		5
5	1,2-Dichloroethane	107062	0.38 ^[1]	0.5		5
6	1,1-Dichloroethylene	75354	0.057 ^[1]	0.11 ^[1]	3.2	5
7	Ethylbenzene	100414		5		5
8	Methylene Chloride (Dichloromethane)	75092	4.7	5		5
9	Tetrachloroethylene	127184	0.8	1.6		5
10	Toluene	108883		5		5
11	Cis 1,2-Dichloroethylene	156592		5		5
12	Trans 1,2-Dichloroethylene	156605		5		5
13	1,1,1-Trichloroethane	71556		5		5
14	1,1,2-Trichloroethane	79005	0.6	1.2		5
15	Trichloroethylene	79016	2.7	5		5
16	Vinyl Chloride	75014		0.5		1
17	Total Xylenes	1330207		5		5
18	Methyl Tertiary Butyl Ether (MTBE)	1634044		5		5
19	Total Petroleum Hydrocarbons (as Gasoline or as Diesel)			50		50
20	Ethylene Dibromide (1,2-Dibromoethane)	106934		0.05 ^[1]		5
21	Trichlorotrifluoroethane	76131		5		5

Footnotes for Table F-2:

- [1] If reported detection level is greater than effluent limit, then a non-detect result using a 0.5 µg/L detection level will not be deemed to be out of compliance.
- [2] Drinking water areas are defined as surface waters with the existing or potential beneficial uses of “municipal and domestic supply” and “groundwater recharge” (the latter includes recharge areas to maintain salt balance or to halt salt water intrusion into fresh water aquifers).

D. Compliance Summary

Forty-four (44) effluent limit and 17 late reporting violations (for a total of 61 violations) are reported in CIWQS during the term of the Fuel General Permit. On average, the Dischargers reported effluent limit compliance rates of about 99% for TPHd, TPHg, and on-time report submittal, and almost 100% for the remaining pollutants with effluent limits in Table F-2. Regional Water Board enforcement staff completed enforcement actions for 53 of these violations, and continues to review the remaining 8 violations.

E. Planned Changes

As required in Attachment D, a Discharger authorized under this Order shall submit a modified NOI before making any material change in the character, location, or volume of the discharge.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in the Order are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code [(CWC), commencing with section 13370]. It shall serve as a NPDES permit for point source discharges from these facilities to surface waters. This Order also serves as General Waste Discharge Requirements (GWDRs) pursuant to CWC article 4, chapter 4, division 7 (commencing with section 13260). States may request authority to issue general NPDES permits pursuant to Code of Federal Regulations, Title 40, Chapter 1, Subchapter D, part 122.28 (40 CFR 122.28). 40 CFR 122.28 provides for the issuance of general permits to regulate discharges of waste which result from similar operations, are the same types of waste, require the same effluent limitations, require similar monitoring, and are more appropriately regulated under a general permit rather than individual permits. This general permit meets the requirements of 40 CFR 122.28 because the discharges and proposed discharges:

- result from similar operations (all involve extraction, treatment, and discharge of groundwater);
- are the same types of waste (all are groundwater containing VOC, fuel components, and other related wastes due to leaks and spills);
- require similar effluent limitations for the protection of the beneficial uses of surface waters in the San Francisco Bay Region (this general permit does not cover direct discharges to the Pacific Ocean);
- require similar monitoring; and
- are more appropriately regulated under a general permit rather than individual permits.

B. California Environmental Quality Act (CEQA)

Under CWC section 13389, this action to issue an NPDES permit is exempt from the provisions of CEQA.

C. State and Federal Regulations, Policies, and Plans

- 1. Water Quality Control Plans.** *The Water Quality Control Plan for the San Francisco Bay Basin* (the Basin Plan) is the Regional Water Board's master water quality control planning document. It designates beneficial uses and water quality objectives (WQOs) for waters of the State, including surface and groundwater. It also includes implementation programs to achieve WQOs. The Basin Plan was duly adopted by the Regional Water Board and approved by the State Water Resources Control Board (State Water Board), the Office of Administrative Law, and USEPA. Requirements of this Order implement the Basin Plan.

The Basin Plan designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. The Basin Plan states that the beneficial uses of any specifically identified water body generally apply to its tributary streams. The Basin Plan may not specifically identify beneficial uses for every receiving water regulated under this permit, but identifies present and potential uses for the downstream water body, to which the receiving water, via an intermediate water body, is tributary. These potential and existing beneficial uses are: municipal and domestic supply, fish migration and fish spawning, industrial service supply, navigation, industrial process supply, marine habitat, agricultural supply, estuarine habitat, groundwater recharge, shellfish harvesting, water contact and non-contact recreation, ocean, commercial, and sport fishing, wildlife habitat, areas of special biological significance, cold freshwater and warm freshwater habitat, and preservation of rare and endangered species for surface waters and municipal and domestic supply, industrial service supply, industrial process supply, agricultural supply, and freshwater replenishment for groundwaters. In addition, the Basin Plan implements State Water Board Resolution No. 88-63, which established state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Requirements of this Order implement the Basin Plan.

On September 18, 1975, the State Water Board adopted the *Water Quality Control Plan for Control of Temperature in the Coastal Interstate Waters and Enclosed Bays and Estuaries of California* (hereinafter the Thermal Plan). The Thermal Plan contains objectives governing cooling water discharges, providing different and specific numeric and narrative water quality objectives for new and existing discharges.

The State Water Board's *Water Quality Control Plan for Enclosed Bays and Estuaries—Part I, Sediment Quality* became effective on August 25, 2009. This plan supersedes other narrative sediment quality objectives and establishes new sediment quality objectives and

related implementation provisions for specifically defined sediments in most bays and estuaries.

- 2. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and amended it on May 4, 1995, and November 9, 1999. About 40 criteria in the NTR and apply in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that applied in the State. The CTR was amended on February 13, 2001. These rules contain water quality criteria (WQC) for priority toxic pollutants.
- 3. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated through the NTR and to the WQOs established in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- 4. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes [65 Fed. Reg. 24641 (April 27, 2000), codified at 40 CFR 131.21]. Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- 5. Antidegradation Policy.** 40 CFR 131.12 requires that state WQS include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution 68-16, which incorporates the federal antidegradation policy where the federal policy applies under federal law and requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies.
- 6. Anti-Backsliding Requirements.** CWA Sections 402(o)(2) and 303(d)(4) and 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed.

D. Impaired Water Bodies on CWA 303(d) List

In November 2006, USEPA approved a revised list of impaired water bodies prepared pursuant to CWA section 303(d), which requires identification of specific waterbodies where it is expected that water quality standards will not be met after implementation of technology-based effluent limitations on point sources. In November 2010, USEPA partially approved an updated 303(d) list. Where it has not already done so, the Regional Water Board plans to adopt Total Maximum Daily Loads (TMDLs) for pollutants on the 303(d) list. TMDLs establish wasteload allocations for point sources and load allocations for non-point source and are established to achieve the water quality standards for the impaired waterbodies. The SIP requires final effluent limitations for all 303(d)-listed pollutants to be based on total maximum daily loads and associated waste load allocations.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in 40CFR: Section 122.44(a) requires that permits include applicable technology-based limitations and standards; and Section 122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water.

Several specific factors affecting the development of limitations and requirements in this Order are discussed as follows.

A. Discharge Prohibitions

- 1. Prohibition III.A (Unauthorized discharges of extracted and treated groundwater are prohibited):** This discharge prohibition is retained from the previous General Permit and is based on CWC Section 13260, which requires filing of a report of waste discharge (ROWD) before discharges can occur. Discharges which have not been described in a Discharger's NOI are prohibited.
- 2. Prohibition III.B (Discharges of effluent other than extracted groundwater treated only with approved chemicals are prohibited):** This prohibition is retained from the previous General Permit and is based on the fact that the requirements in the Order were developed for discharges of treated groundwater from VOC or fuel contaminated groundwater sites so only discharges associated with this type of activity can be permitted under this Order.
- 3. Prohibition III.C (Discharges in excess of the authorized flow rate are prohibited):** This prohibition is retained from the previous General Permit. The basis for the prohibition is the same rationale documented for Prohibition III.A. Dischargers have submitted an NOI that included a description of treatment facility design and the maximum design flow rate, certified by a professional engineer. Flows in excess of the design flow rate may result in lowering the reliability of achieving compliance with water quality requirements.

4. **Prohibition III.D (No scouring or erosion due to discharge of extracted and treated groundwater at the point where a storm drain discharges to a receiving water):** This prohibition is retained from the previous permit, with slight revisions for consistency with similar provisions of the Municipal Regional Stormwater NPDES Permit (Order No. R2-2009-0074), and is based on the sediment and erosion control goals of section 4.19 of the Basin Plan.
5. **Prohibition III.E (No pollution, contamination, or nuisance):** This prohibition is based on CWC section 13050, and has been retained from the previous General Permit.
6. **Prohibition III.F (No bypass or overflow of untreated or partially treated polluted groundwater):** This prohibition is retained from the previous General Permit and is based on 40 CFR 122.41(m).

B. Shallow Water Discharges and Basin Plan Discharge Prohibition 1

The Basin Plan (Chapter 4, Table 4-1, Discharge Prohibition 1) prohibits discharges not receiving a minimum 10:1 initial dilution or to dead end sloughs. In accordance with the Basin Plan, this Order continues to grant Dischargers an exception to the discharge prohibition for discharges to shallow waters. The exception is based on section 4.2 of the Basin Plan, which states that an exception to Prohibition 1 will be considered where:

“A discharge is approved as part of a groundwater clean-up project, and in accordance with Resolution No. 88-160 ‘Regional Board Position on the Disposal of Extracted Groundwater from Groundwater Clean-Up Projects’ and it has been demonstrated that neither reclamation nor discharge to a publicly owned treatment works is technically and economically feasible, and the discharger has provided certification of the adequacy and reliability of treatment facilities and a plan that describes procedures for proper operation and maintenance of all treatment facilities.”

The Basin Plan further states:

“Significant factors to be considered by the Regional Water Board in reviewing requests for exceptions will be the reliability of the discharger’s system in preventing inadequately treated wastewater from being discharged to the receiving water and the environmental consequences of such discharges.”

To comply with the exception, this Order requires Dischargers to document in the NOI application that neither reclamation nor discharge to a POTW is technically and economically feasible. In addition, to prevent inadequately treated wastewater from being discharged to receiving waters, Dischargers are required to document in the NOI that the discharge of inadequately treated waste will be reliably prevented.

C. Technology-Based Effluent Limitations

1. Scope and Authority

The CWA requires technology-based effluent limitations (TBELs) based on several levels of controls:

- Best practicable treatment control technology (BPT) represents the average of the best performance by plants within an industrial category or subcategory. BPT standards apply to toxic, conventional, and non-conventional pollutants.
- Best available technology economically achievable (BAT) represents the best existing performance of treatment technologies that are economically achievable within an industrial point source category. BAT standards apply to toxic and non-conventional pollutants.
- Best conventional pollutant control technology (BCT) represents the control from existing point sources of conventional pollutants including BOD, TSS, fecal coliform, pH, and oil and grease. The BCT standard is established after considering the “cost reasonableness” of the relationship between the cost of attaining a reduction in effluent discharge and the benefits that would result, and also the cost effectiveness of additional industrial treatment beyond BPT.
- New source performance standards (NSPS) represent the best available demonstrated control technology standards. The intent of NSPS guidelines is to set limitations that represent state-of-the-art treatment technology for new sources.

The CWA requires USEPA to develop effluent limitations, guidelines, and standards (ELGs) representing application of BPT, BAT, BCT, and NSPS. Section 402(a)(1) of the CWA and 40 CFR 125.3 authorize the use of Best Professional Judgment (BPJ) to derive TBELs on a case-by-case basis where ELGs are not available for certain industrial categories and/or pollutants of concern. Where BPJ is used, the permit writer must consider specific factors outlined in 40 CFR 125.3.

2. Applicable Technology-Based Effluent Limitations

Regional Water Board staff used BPJ in developing TBELs in this Order. BPJ is defined as the highest quality technical opinion developed by a permit writer after consideration of all reasonably available and pertinent data or information that forms the basis for the terms and conditions of a NPDES permit. The authority for BPJ is contained in CWA section 402(a)(1).

In the treatment systems regulated by this Order, organic compounds, including VOC and petroleum compounds, are removed from contaminated groundwater using such technologies as air stripping and activated carbon. Treated groundwater is then discharged to surface waters. When properly designed and operated, these treatment systems can lower the concentration of such pollutants to levels below analytical detection limits.

USEPA Region 9 issued a document titled *NPDES Permit Limitations for Discharge of Contaminated Groundwater: Guidance Document* (USEPA, 1986) in which USEPA concluded that the cost of reducing concentrations of most organic compounds commonly detected in contaminated groundwater to a non-detect concentration of 5 µg/L, and to a non-detect concentration for vinyl chloride of 1 µg/L, is considered economically achievable.

Based on an understanding that available treatment technologies can economically remove organic pollutants from contaminated groundwater, the Regional Water Board has established TBELs using BPJ at 5.0 µg/L for benzene, carbon tetrachloride, chloroform, 1,1-dichloroethane, 1,2-dichloroethane, 1,1-dichloroethylene, ethylbenzene, methylene chloride, tetrachloroethylene, Toluene, Cis 1,2-Dichloroethylene, Trans 1,2-Dichloroethylene, 1,1,1-Trichloroethane, 1,1,2-Trichloroethane, Trichloroethylene, and total xylenes, and at 1.0 µg/L for vinyl chloride.

Petroleum-based compounds and fuel additives are commonly found at sites with fuel or fuel VOC commingled plumes. This Order therefore retains TBELs for TPHs, ethylene dibromide, and MTBE from the previous Fuel General Permit. Limitations for TPH are 50 µg/L and for ethylene dibromide and MTBE are 5 µg/L, which reflect a level of treated wastewater quality that is economically achievable by the treatment technologies contemplated by this Order.

Because a number of facilities covered under the Fuel General Permit are former semiconductor manufacturing operations, which used trichlorotrifluoroethane (Freon 113) in a manufacturing process and have detected concentrations of this compound in contaminated groundwater, this Order retains the effluent limitation from the previous Fuel General Permit for Freon. The effluent limitation of 5 µg/L reflects a level of treated wastewater quality that is economically achievable by the treatment technologies contemplated by this Order.

Table F-3, below, summarizes the TBELs established by this Order.

Table F-3. Summary of Technology-Based Effluent Limitations

No.	Compound	Limitations Established by BPJ	
		USEPA	RWB
1	Benzene	5	---
2	Carbon Tetrachloride	5	---
3	Chloroform	5	---
4	1,1-Dichloroethane	5	---
5	1,2-Dichloroethane	5	---
6	1,1-Dichloroethylene	5	---
7	Ethylbenzene	5	---
8	Methylene Chloride	5	---
9	Tetrachloroethylene	5	---
10	Toluene	5	---
11	Cis-1,2-Dichloroethylene	5	---

No.	Compound	Limitations Established by BPJ	
		USEPA	RWB
12	Trans-1,2-Dichloroethylene	5	---
13	1,1,1-Trichloroethane	5	---
14	1,1,2-Trichloroethane	5	---
15	Trichloroethylene	5	---
16	Vinyl Chloride	1	---
17	Total Xylenes	5	---
18	Methyl Tertiary Butyl Ether (MTBE)	5	5
19	Total Petroleum Hydrocarbons (TPH)	---	50
20	Ethylene Dibromide (1,2-Dibromoethane)	---	5
21	Trichlorotrifluoroethane	---	5

D. Water Quality-Based Effluent Limitations (WQBELs)

WQBELs have been derived to implement WQOs that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law. The procedures for calculating individual WQBELs are based on the SIP and the Basin Plan. Most Basin Plan beneficial uses and WQOs were approved under State law and submitted to and approved by USEPA prior to May 30, 2000. Any WQOs and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless “applicable water quality standards for purposes of the [Clean Water] Act” pursuant to 40 CFR 131.21(c)(1). Collectively, this Order’s restrictions on individual pollutants are no more stringent than those required by CWA water quality standards.

1. Scope and Authority

- a. 40 CFR 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have reasonable potential to cause or contribute to an excursion of a water quality standard, including numeric and narrative objectives within a standard. As specified in 40 CFR 122.44(d)(1)(i), permits are required to include WQBELs for all pollutants “which the Director determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any state water quality standard.”

The process for determining “reasonable potential” and calculating WQBELs when necessary is intended to protect the designated beneficial uses of the receiving water as specified in the Basin Plan, and achieve applicable WQOs contained in other state plans and policies, and applicable WQC contained in the CTR and NTR.

- b. NPDES regulations and the SIP provide the basis to establish Maximum Daily Effluent Limitations (MDELs).
 - (1) NPDES Regulations. NPDES regulations at 40 CFR 122.45(d) state, “For continuous discharges all permit effluent limitations, standards, and prohibitions, including those necessary to achieve water quality standards, shall *unless impracticable* be stated as maximum daily and average monthly discharge limitations for all discharges other than publicly owned treatment works.”
 - (2) SIP. SIP section 1.4 requires WQBELs to be expressed as MDELs and average monthly effluent limitations (AMELs).
- c. MDELs are used in this Order to protect against acute water quality effects. The MDELs are necessary for preventing fish kills or mortality to aquatic organisms.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

The WQOs applicable to the receiving waters for these discharges are from the Basin Plan; the CTR, established by USEPA at 40 CFR 131.38; and the NTR, established by USEPA at 40 CFR 131.36. Some pollutants have WQOs established by more than one of these three sources.

- a. **Basin Plan.** The Basin Plan specifies numeric WQOs for 10 priority toxic pollutants, as well as narrative WQOs for toxicity and bioaccumulation in order to protect beneficial uses. The pollutants for which the Basin Plan specifies numeric objectives are arsenic, cadmium, chromium (VI), copper in fresh and marine water, lead, mercury, nickel, silver, zinc, and cyanide. The narrative toxicity objective states, “All waters shall be maintained free of toxic substances in concentrations that are lethal to or that produce other detrimental responses in aquatic organisms.” The bioaccumulation objective states, “Controllable water quality factors shall not cause a detrimental increase in concentrations of toxic substances found in bottom sediments or aquatic life. Effects on aquatic organisms, wildlife, and human health will be considered.” Effluent limitations and provisions contained in this Order are designed to implement these objectives, based on available information.

The Basin Plan also contains a narrative objective for surface waters designated for use as a domestic or municipal supply (MUN) which states that these surface waters shall not contain concentrations of constituents in excess of the maximum contaminant levels (MCLs) or secondary MCLs specified in Title 22 of the California Code of Regulations. Effluent limitations and provisions contained in this Order are designed to implement these objectives, based on available information.

- b. **CTR.** The CTR specifies numeric aquatic life criteria for 23 priority toxic pollutants and numeric human health criteria for 57 priority toxic pollutants. These criteria apply to all inland surface waters and enclosed bays and estuaries of the San Francisco Bay Region, although Tables 3-3 and 3-4 of the Basin Plan include numeric objectives for certain of

these priority toxic pollutants, which supersede criteria of the CTR (except in the South Bay south of the Dumbarton Bridge).

Human health criteria are further identified as “water and organisms” and “organisms only.” The CTR criteria applicable to “water and organisms” are applied in the Reasonable Potential Analysis (RPA) for discharges to receiving waters with a MUN designation, and criteria applicable to “organisms only” were used in the RPA for discharges to receiving waters that are not MUN-designated.

- c. **NTR.** The NTR establishes numeric aquatic life criteria for selenium and numeric “organisms only” human health criteria for 33 toxic pollutants for waters of San Francisco Bay upstream to, and including Suisun Bay and the San Joaquin-Sacramento River Delta.
- d. **Sediment Quality Objectives.** The *Water Quality Control Plan for Enclosed Bays and Estuaries – Part 1, Sediment Quality* contains a narrative WQO, “Pollutants in sediments shall not be present in quantities that, alone or in combination, are toxic to benthic communities in bays and estuaries of California.” This WQO is to be implemented by integrating three lines of evidence: sediment toxicity, benthic community condition, and sediment chemistry. The policy requires that is the Regional Water Board determines that a discharge has reasonable potential to cause or contribute to an exceedance of this WQO, it is to impose the WQO as a receiving water limit.
- e. **Basin Plan Receiving Water Salinity Policy.** The Basin Plan (like the CTR and the NTR) states that the salinity characteristics (i.e., freshwater vs. saltwater) of the receiving water are to be considered in determining the applicable WQOs. Freshwater criteria apply to discharges to waters with salinities equal to or less than one part per thousand (ppt) at least 95 percent of the time. Saltwater criteria apply to discharges to waters with salinities equal to or greater than 10 ppt at least 95 percent of the time in a normal water year. For discharges to water with salinities between these two categories, or tidally influenced freshwaters that support estuarine beneficial uses, the WQOs are the lower of the salt or freshwater WQOs (the latter calculated based on ambient hardness) for each substance.

Receiving waters considered by for this permit are the San Francisco Bay and other estuarine and tidally influences waters, and inland freshwaters. The Basin Plan implements State Water Board Resolution No. 88-63, which establishes State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply (MUN). Because of marine influence on all reaches of San Francisco Bay and other tidally influenced waters, total dissolved solids levels exceed 3,000 mg/L and thereby meet an exception to State Water Board Resolution No. 88-63. The RPA therefore separately considered criteria that were applicable to receiving waters with a MUN designation and to receiving waters that are not MUN-designated. Aquatic life criteria were based on the most stringent of the fresh and salt water criteria, to be fully protective of all receiving waters.

- f. **Receiving Water Hardness.** Ambient hardness values are used to calculate freshwater WQOs that are hardness dependent. In determining the WQOs for this Order, Regional Water Board staff used a hardness value of 100 mg/L as CaCO₃, which is a conservative value and generally protective of aquatic life in all circumstances contemplated by the General Permit.
- g. **Site-Specific Translators (SSTs).** NPDES regulations at 40 CFR 122.45(c) require that effluent limitations for metals be expressed as total recoverable metal. Since applicable WQOs for metals are typically expressed as dissolved metal, translators must be used to convert metals concentrations from dissolved to total recoverable and vice versa. The CTR includes default translators; however, site-specific conditions, such as water temperature, pH, suspended solids, and organic carbon greatly affect the form of metal (dissolved, non-filterable, or otherwise) present in the water and therefore available to cause toxicity. In general, the dissolved form of the metal is more available and more toxic to aquatic life than non-filterable forms. Site-specific translators can be developed to account for site-specific conditions, thereby preventing exceedingly stringent or under protective WQOs.

Receiving waters for discharges from the facilities covered under the General Permit are varied, and therefore site specific conditions are varied. In determining the need for and calculating WQBELs for all metals except for copper and nickel, the Regional Water Board has used default translators established by the USEPA in the CTR at 40 CFR 131.38 (b) (2), Table 2 to be protective in all circumstances. Most discharges are anticipated to eventually enter San Francisco Bay, and therefore, the site specific translators were applied in determining criteria for copper and nickel. For copper, the Regional Water Board applied the SSTs adopted by Regional Water Board Resolution No. R2-2007-0042 for North and Central San Francisco Bay, and the SST contained in the Basin Plan Table 7.2.1-1 for South San Francisco Bay. For nickel, the Regional Water Board applied the translators for North and Central San Francisco Bay based on the recommendation of the Clean Estuary Partnership’s *North of Dumbarton Bridge Copper and Nickel Development and Selection of Final Translators* (2005), and applied the translators contained in Table 7.2.1-1 of the Basin Plan for South San Francisco Bay. These translators for copper and nickel are summarized below.

Table F-4. SSTs for Copper and Nickel for San Francisco Bay

<i>San Francisco Bay Segment</i>	Copper		Nickel	
	AMEL Translator	MDEL Translator	AMEL Translator	MDEL Translator
North	0.38	0.66	0.27	0.57
Central	0.73	0.87	0.65	0.85
South	0.53	0.53	0.44	0.44

3. Determining the Need for WQBELs

Assessing whether a pollutant has Reasonable Potential is the fundamental step in determining whether or not a WQBEL is required.

a. Reasonable Potential Methodology

For priority pollutants and most other toxic pollutants, the RPA identifies the observed maximum effluent concentration (MEC) for each pollutant based on effluent concentration data. There are three triggers in determining Reasonable Potential according to SIP Section 1.3.

- (1) The first trigger (Trigger 1) is activated if the MEC is greater than or equal to the lowest applicable WQO ($MEC \geq WQO$), which has been adjusted, if appropriate, for pH, hardness, and translator data. If the MEC is greater than or equal to the adjusted WQO, then that pollutant has Reasonable Potential, and a WQBEL is required.
- (2) The second trigger (Trigger 2) is activated if the observed maximum ambient background concentration (B) is greater than the adjusted WQO ($B > WQO$), and the pollutant is detected in any of the effluent samples ($MEC > ND$).
- (3) The third trigger (Trigger 3) is activated if a review of other information determines that a WQBEL is required to protect beneficial uses, even though both MEC and B are less than the WQO/WQC.

b. Effluent Data

Each Discharger currently covered under the Fuel General Permit was required to conduct effluent monitoring pursuant to the Self-Monitoring Program for Order No. R2-2006-0075. The Regional Water Board analyzed the Dischargers' priority pollutant data and the nature of the discharges to determine if discharges have Reasonable Potential. Effluent data used to conduct this RPA consisted of data submitted as part of each facility's NOI which was combined with data submitted by facilities as part of the NOI application for coverage under the VOC General Permit. The Regional Water Board analyzed effluent quality data collected from 2004 to 2011 for a total of 55 facilities (43 from the VOC General Permit and 12 from the Fuel General Permit) in the San Francisco Bay Region. Effluent monitoring data from three NOIs received after the July 15, 2011, due date were not included in this RPA.

From this analysis, it was concluded that the data for metals would be excluded for use in RPA pursuant to SIP 1.2. The reason is that the metals were detected only occasionally and at low levels likely from natural background in the groundwater.

c. Ambient Background Data

The SIP states that, for calculating WQBELs, ambient background concentrations are either the observed maximum ambient water column concentrations or, for objectives intended to protect human health from carcinogenic effects, the arithmetic mean of

observed ambient water concentrations. Ambient background concentrations are the observed maximum detected water column concentrations for aquatic life protection.

Because the receiving waters for discharges from the facilities covered under this Order are varied, receiving water background concentrations were not considered for this RPA.

d. Reasonable Potential Determination for Priority Pollutants

The MECs and the most stringent applicable WQC used in the RPA are presented in the following table, along with the RPA results (yes or no) for each pollutant. Reasonable Potential was not determined for all pollutants because there are not applicable WQC for all pollutants, or monitoring data are not available for others. Based on a review of the effluent data, the pollutants that demonstrate reasonable potential by Trigger 1 are benzene, bromoform, chlorodibromomethane, 1,2-dichloroethane, 1,1-dichloroethylene, methylene chloride, trichloroethylene, vinyl chloride, and bis(2-ethylhexyl)phthalate.

The Regional Water Board has also determined that Reasonable Potential exists to exceed water quality objectives, by Trigger 3, for the organic pollutants that have been identified as pollutants that are commonly present in VOC and fuel-contaminated groundwater (i.e., those pollutants for which TBELs have been established.) As these TBELs limitations are achievable dependent on the proper design and operation of treatment systems, there is reasonable potential for excursions above applicable water quality criteria for these pollutants if the system is not designed or operated correctly.

Total residual chlorine is also identified as a pollutant with Reasonable Potential to exceed the Basin Plan narrative toxicity objective, as determined by Trigger 3. The Regional Water Board has identified that chlorine may be used in conjunction with air stripping and/or activated carbon treatment systems to control biological growth, and therefore reasonable potential exists for total residual chlorine for those facilities that use it.

Table F-5. Summary of RPA Results

CTR #	Priority Pollutants	MEC or Minimum DL ^{[1][2]} (µg/L)	Governing Applicable Criteria (µg/L)				RPA Results ^[3]
			Aquatic Life	Human Health			
			(Most stringent of salt and fresh water)	CTR Water + Organisms	Basin Plan Title 22 MCLs	CTR Organisms Only	
1	Antimony	21	---	14	6	4300	Ud
2	Arsenic	140	36	---	10	---	Ud
3	Beryllium	0.00053	---	---	4	---	Ud
4	Cadmium	0.36	1.1	---	5	---	Ud
5a	Chromium (III)	NA	207	---	50	---	Ud
5b	Chromium (VI)	14	11	---	---	---	Ud
6	Copper	24	4.7 ^[4]	---	1000	---	Ud

CTR #	Priority Pollutants	MEC or Minimum DL ^{[1][2]} (µg/L)	Governing Applicable Criteria (µg/L)				RPA Results ^[3]
			Aquatic Life	Human Health			
			(Most stringent of salt and fresh water)	CTR Water + Organisms	Basin Plan Title 22 MCLs	CTR Organisms Only	
	Copper	24	3.4 ^[5]	---	1000	---	Ud
	Copper	24	5.9 ^[6]	---	1000	---	Ud
7	Lead	0.048	3.2	---	---	---	Ud
8	Mercury (303d listed)	0.00082	0.025	0.050	2	0.051	Ud
9	Nickel	49	19 ^[7]	610	100	4600	Ud
	Nickel	49	13 ^[8]	610	100	4600	Ud
	Nickel	49	30 ^[9]	610	100	4600	Ud
10	Selenium (303d listed)	25	5.0	---	---	---	Ud
11	Silver	<0.25	2.2	---	---	---	Ud
12	Thallium	7.3	---	1.7	2.0	6.3	Ud
13	Zinc	150	86	---	5000	---	Ud
14	Cyanide	30	2.9 ^[10]	700	150	220,000	Ud
19	Benzene	1.2	---	1.2	1	71	Yes
20	Bromoform	5.2	---	4.3	---	360	Yes
23	Chlorodibromomethane	2.8	---	0.401	---	34	Yes
26	Chloroform	7.1	---	No Criteria			Yes
28	1,1-Dichloroethane	4.1	---	---	5	---	Yes
29	1,2-Dichloroethane	0.6	---	0.38	0.5	99	Yes
30	1,1-Dichloroethylene	5.7	---	0.057	6	3.2	Yes
33	Ethylbenzene	<0.5	---	3100	300	29,000	Yes
36	Methylene Chloride	23	---	4.7	5	1600	Yes
38	Tetrachloroethylene	25	---	0.8	5	8.85	Yes
39	Toluene	3.07	---	6800	150	200,000	Yes
---	1,2-Cis-Dichloroethylene	20	---	---	6	---	Yes
40	1,2-Trans-Dichloroethylene	4.2	---	700	10	140,000	Yes
41	1,1,1-Trichloroethane	15	---	---	200	---	Yes
42	1,1,2-Trichloroethane	0.5	---	0.60	5	42	Yes
43	Trichloroethylene	460	---	2.7	5	81	Yes
44	Vinyl Chloride	2.1	---	2	0.5	525	Yes
68	Bis-2(ethylhexyl)phthalate	100	---	1.8	4	5.9	Yes
70	Butylbenzyl Phthalate	22	---	3000	---	5200	No
---	Total Xylenes	3	---	---	1750	---	Yes
---	Methyl Tertiary Butyl Ether (MTBE)	2.7	---	---	13	---	Yes
---	Total Petroleum Hydrocarbons (TPH)	1600	No Criteria				Ud
---	Ethylene Dibromide	<0.05	---	---	0.05	---	Yes
---	Trichlorotrifluoroethane	5.4	---	---	1200	---	Yes
---	Total Residual Chlorine ^[11]	NA	---	---	---	---	Yes

Footnotes for Table F-5:

- [1] The Maximum Effluent Concentration (MEC) and maximum background concentration are the actual detected concentrations unless preceded by a “<” sign, in which case the value shown is the minimum detection level (DL).
- [2] The MEC or maximum background concentration is “Not Available” (NA) when there are no monitoring data for the constituent.
- [3] RPA Results = Yes, if MEC > WQO/WQC, B > WQO/WQC and MEC is detected, or Trigger 3;
= No, if MEC and B are < WQO/WQC or all effluent data are undetected;
= Undetermined (Ud), if no criteria have been promulgated or there are insufficient data. For metals and cyanide, Ud was determined because as noted previously the reported discharge data were excluded for use in RPA pursuant to SIP 1.2. Though the detected levels are high as shown in

the MECs above, these were in just a few samples. Metals and cyanide were detected only occasionally and generally at low levels likely from natural background in the groundwater extracted for cleanup. Because this Order would exclude coverage for sites where there is persistent metals contamination, and the relative small load of background metals to the Bay from all the discharges, a finding of undetermined is appropriate.

- [4] Criterion based on the Basin Plan marine SSO for copper, and the site-specific translators (0.53 acute and chronic) for the Lower and South Bay.
- [5] Criterion based on the Basin Plan marine SSO for copper, and the site-specific translators (0.87 acute, 0.73 chronic) for the Central Bay.
- [6] Criterion based on the Basin Plan marine SSO for copper, and the site-specific translators (0.66 acute, 0.38 chronic) for Suisun and San Pablo Bay.
- [7] Criterion based on the Basin Plan marine SSO for nickel and the site-specific translators (0.44 acute and chronic) for the Lower and South Bay.
- [8] Criterion based on the Basin Plan marine WQO for nickel, and the site-specific translators (0.85 acute, 0.65 chronic) for the Central Bay.
- [9] Criterion based on the Basin Plan marine WQO for nickel, and the site-specific translators (0.57 acute, 0.27 chronic) for Suisun and San Pablo Bay.
- [10] Criterion based on the Basin Plan marine SSO for cyanide.
- [11] Total Residual Chlorine: The water quality objective applicable to total residual chlorine is the Basin Plan narrative objective for toxicity which states “[a]ll waters shall be maintained free of toxic substances in concentrations that are lethal to or that produce other detrimental responses in aquatic organisms.”

e. Constituents with limited data

In some cases, Reasonable Potential cannot be determined because effluent data are limited, or ambient background concentrations are unavailable. When additional data become available, further RPA will be conducted to determine whether numeric effluent limitations are necessary.

f. Pollutants with No Reasonable Potential

WQBELs are not included in this Order for constituents that do not demonstrate Reasonable Potential; however, monitoring for those pollutants is still required. If concentrations of these constituents are found to have increased significantly, the Discharger will be required to investigate the sources of the increases. Remedial measures are required if the increases pose a threat to receiving water quality.

g. RPA Determination for Sediment Quality Objectives

To date there is no evidence directly linking compromised sediment conditions to the discharges subject to this Order; therefore the Regional Water Board cannot draw a conclusion about Reasonable Potential for the discharges to cause or contribute to exceedances of the sediment quality objectives. However, due to the relatively small discharge volumes and the type and level of treatment, it is unlikely that these discharges would contribute to exceedance of sediment objectives.

4. WQBEL Calculations

a. Pollutants with Reasonable Potential. WQBELs were developed for the toxic and priority pollutants that were determined to have Reasonable Potential to cause or contribute to exceedances of the WQOs or WQC. The WQBELs were calculated based on WQOs and the appropriate procedures specified in Section 1.4 of the SIP. The WQOs used for each pollutant with reasonable potential are discussed below.

b. Shallow/Deep Water Discharge. The Basin Plan defines a deep water discharge as a discharge through an outfall equipped with a diffuser that achieves a minimum initial

dilution of 10:1. Because the General Permit authorizes discharges to many types of receiving waters, Dischargers covered under the General Permit are classified by the Regional Water Board as shallow water discharges, so that the General Permit is protective under all circumstances.

- c. **Dilution Credit.** The General Permit assumes minimal dilution is available for discharges which it authorizes and therefore no dilution credit is granted in calculating WQBELs.
- d. **Development of WQBELs for Specific Pollutants.** To develop WQBELs for pollutants that demonstrate reasonable potential based on CTR human health criteria (benzene, bromoform, chlorodibromomethane, 1,2dichloroethane, and bis(2-ethylhexyl)phthalate) , the average monthly effluent limitation (AMEL) is established as the most stringent WQC because the WQC are based on applicable human health criteria. To calculate the maximum daily effluent limitation (MDEL), the AMEL is multiplied by a MDEL/AMEL multiplier of 2.01, which assumes a coefficient of variation (CV) of effluent data of 0.60, because not enough data were available to calculate a CV.

For pollutants with criteria based on Title 22 MCLs (benzene, vinyl chloride), where the MUN designation is applicable to the receiving water, MDELs are set equal to the MCL, because the MCLs are levels that shall not be exceeded in the receiving water, and no credit for dilution is granted.

WQBELs for total residual chlorine are based in Table 4-2 of the Basin Plan.

For the CTR metals and cyanide, WQBELs are not being established at this time. Instead, trigger values will be set for these inorganic pollutants as a backstop to ensuring that sites with metals or cyanide contamination are appropriately identified and addressed. Exceedance of these trigger values in the discharge would trigger actions specified Provision VI.C.6, which if warranted may also lead to termination of discharge authorization under this Order.

Table F-6. Summary of WQBELs

No.	Compound	Discharge to Receiving Waters used as Drinking Water Source ^[1]		Discharge to Other Receiving Waters	
		AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)
1	Benzene	---	1	71	142
2	Carbon Tetrachloride	0.25	0.5	4.4	8.8
3	Chloroform	---	---	---	---
4	1,1-Dichloroethane	---	5	---	---
5	1,2-Dichloroethane	0.38	0.5	99	199
6	1,1-Dichloroethylene	0.057	0.11	3.2	6.4
7	Ethylbenzene	---	300	29,000	58,000
8	Methylene Chloride	4.7	9.4	1600	3200

No.	Compound	Discharge to Receiving Waters used as Drinking Water Source ^[1]		Discharge to Other Receiving Waters	
		AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)
9	Tetrachloroethylene	0.8	1.6	8.85	17.8
10	Toluene	---	150	200,000	400,000
11	Cis-1,2-Dichloroethylene	---	6	---	---
12	Trans-1,2-Dichloroethylene	---	10	140,000	280,000
13	1,1,1-Trichloroethane	---	200	---	---
14	1,1,2-Trichloroethane	0.60	1.2	42	84
15	Trichloroethylene	2.7	5.4	81	160
16	Vinyl Chloride	---	0.5	525	1060
17	Total Xylenes	---	1750	---	---
18	Methyl Tertiary Butyl Ether (MTBE)	---	13	---	---
19	Total Petroleum Hydrocarbons (TPH)	---	---	---	---
20	Ethylene Dibromide (1,2-Dibromoethane)	---	0.05	---	---
21	Trichlorotrifluoroethane	---	1200	---	---
22	Total Residual Chlorine ^[2]	---	0.0	---	0.0

Footnotes for Table F-6:

- [1] Receiving waters which are sources of drinking water are surface waters with the existing or potential beneficial use of Municipal and Domestic Supply, and/or Groundwater Recharge.
- [2] The total residual chlorine requirement is defined as below the limit of detection in standard test methods defined in the latest USEPA approved edition of *Standard Methods for the Examination of Waste and Wastewater*.

5. Whole Effluent Toxicity (WET)

The Basin Plan requires dischargers to either conduct flow-through effluent toxicity tests or perform static renewal bioassays (Chapter 4, Acute Toxicity) to measure the toxicity of wastewaters and to assess negative impacts upon water quality and beneficial uses caused by the aggregate toxic effect of the discharge of pollutants. This Order retains the effluent limitation for whole effluent acute toxicity. Compliance evaluation with these limitations is based on 96-hour static-renewal bioassays. All bioassays shall be performed according to the USEPA-approved method in 40 CFR Part 136, currently *“Methods for Measuring the Acute Toxicity of Effluents and Receiving Water, 5th Edition.”*

6. Final Effluent Limitations

The following table presents a summary of final effluent limitations for toxic pollutants established by this Order. The most stringent of the technology-based and water quality-based effluent limitations are established by the Order as final effluent limitations. For pollutants where the WQBEL is more stringent than the TBEL, average monthly and maximum daily effluent limitations have been established, which is consistent with the SIP. When the TBEL is

limiting, only an MDEL is established. For pollutants where the analytical detection limit is higher than the effluent limitation, the Regional Water Board shall deem a discharge out of compliance if the sample result is greater than the detection limit.

In summary, the effluent limitation contained in the previous Fuel and VOC General Permits (Regional Water Board Order Nos. R2-2006-0075 and R2-2009-0059) were the same except the residual chlorine effluent limit in the VOC General NPDES permit, which has been continued into this Order as summarized in Table F-7.

Table F-7. Summary of Final Effluent Limitations

No.	Compound	Discharge to Receiving Waters used as Drinking Water Source ^[1]		Discharge to Other Receiving Waters	
		AMEL (µg/L)	MDEL (µg/L)	AMEL (µg/L)	MDEL (µg/L)
1	Benzene	---	1	---	5
2	Carbon Tetrachloride	0.25	0.5	4.4	5
3	Chloroform	---	5	---	5
4	1,1-Dichloroethane	---	5	---	5
5	1,2-Dichloroethane	0.38	0.5	---	5
6	1,1-Dichloroethylene	0.057	0.11	3.2	5
7	Ethylbenzene	---	5	---	5
8	Methylene Chloride	4.7	5	---	5
9	Tetrachloroethylene	0.8	1.6	---	5
10	Toluene	---	5	---	5
11	Cis-1,2-Dichloroethylene	---	5	---	5
12	Trans-1,2-Dichloroethylene	---	5	---	5
13	1,1,1-Trichloroethane	---	5	---	5
14	1,1,2-Trichloroethane	0.60	1.2	---	5
15	Trichloroethylene	2.7	5	---	5
16	Vinyl Chloride	---	0.5	---	1
17	Total Xylenes	---	5	---	5
18	Methyl Tertiary Butyl Ether (MTBE)	---	5	---	5
19	Total Petroleum Hydrocarbons (TPH)	---	50	---	50
20	Ethylene Dibromide (1,2-Dibromoethane)	---	0.05	---	5
21	Trichlorotrifluoroethane	---	5	---	5
22	Total Residual Chlorine ^[3]	---	0.0	---	0.0

[1] Receiving waters which are sources of drinking water are surface waters with the existing or potential beneficial use of Municipal and Domestic Supply, and/or Groundwater Recharge.

[2] Limitation defined as below the limit of detection using standard test methods defined in the latest USEPA approved edition of *Standard Methods for the Examination of Waste and Wastewater*.

7. Anti-backsliding and Antidegradation

Effluent limitations in this Order comply with anti-backsliding and antidegradation requirements because all effluent limitations are as least as stringent as the limitations contained in the previous General Permit.

E. Reclamation Specifications

Reclamation Specifications are retained from the previous General Permit. Reclamation specifications are required because reuse of treated groundwater is a preferred method of disposal. The basis for these requirements is Resolution No. 88-160.

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Receiving water limitations V.A.1 and V.A.2 are based on narrative and numeric WQOs in Basin Plan Chapter 3.

Receiving water limitation V.A.3 is a more general requirement intended to protect receiving water quality based on water quality standards not expressly addressed in this Order and Fact Sheet. It is retained from the previous permit and requires compliance with all federal and State water quality standards established pursuant to the CWA.

B. Groundwater Limitations

Groundwater limitations are on section 3.4 of the Basin Plan.

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

The principal purposes of a monitoring program are to:

- Document compliance with waste discharge requirements and prohibitions established by the Regional Water Board,
- Facilitate self-policing by the Discharger in the prevention and abatement of pollution arising from waste discharge,
- Develop or assist in the development of limitations, discharge prohibitions, national standards of performance, pretreatment and toxicity standards, and other standards, and
- Prepare water and wastewater quality inventories.

The Monitoring and Reporting Program is a standard requirement in almost all NPDES permits issued by the Regional Water Board, including this Order. It contains definitions of terms and sets out

requirements for reporting of routine monitoring data in accordance with NPDES regulations, the CWC, and State and Regional Water Board policies. The Monitoring and Reporting Program also defines the sampling stations and frequency, the pollutants to be monitored, and additional reporting requirements. Pollutants to be monitored include all parameters for which effluent limitations are specified. Monitoring for additional constituents, for which no effluent limitations are established, is also required to provide data for future completion of RPAs.

The following provides the rationale for the monitoring and reporting requirements contained in the Monitoring and Reporting Program for this facility.

A. Influent Monitoring

The purpose of influent monitoring is to provide documentation that pollutant loadings are below the level that the treatment system was designed for and to provide a warning if one or more new pollutants are being extracted that the as-built treatment system was not designed to remove. All influent monitoring requirements are retained from the previous Fuel General Permit and the VOC General Permit (Regional Water Board Order No. R2-2009-0059). If there is a discrepancy in monitoring frequency between the two General Permits, the more frequent requirement was retained.

B. Effluent Monitoring

The purpose of effluent monitoring is to provide documentation that the treatment system adequately removed all pollutants of concern in compliance with the limitations contained in the Order. Effluent monitoring data can also indicate if one or more pollutants are detected at levels less than effluent limits, but greater than trigger levels, which may indicate poor maintenance or other unexpected problems. All effluent monitoring requirements are retained from the previous Fuel General Permit and the VOC General Permit (Regional Water Board Order No. R2-2009-0059). If there is a discrepancy in monitoring frequency between the two General Permits, the more frequent requirement was retained.

C. Whole Effluent Toxicity Testing Requirements

The selected test species and frequency of testing are the same as previous permit and appropriately cost effective for the Dischargers covered under this Order.

D. Receiving Water Monitoring

The purpose of receiving water monitoring is to provide documentation about the condition of the receiving water should any effluent limit violations occur that may harm the life in the receiving water. The receiving water monitoring frequency is the same as previous Fuel General Permit.

E. Other Monitoring Requirements

The purpose of additional monitoring requirements is to investigate complaints, identify the discharges that should be regulated by individual NPDES permits, coordinate storm water monitoring with municipalities, and quantify potential impacts of extracted and treated groundwater discharge on the receiving water and the ambient conditions of the receiving waters.

D. Reporting Requirements

Reporting requirements are included in the Monitoring and Reporting Program. The reporting requirements establish requirements for report submittal format.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions (Provision VI.A)

Standard Provisions, which in accordance with 40 CFR 122.41 and 122.42 apply to all NPDES discharges and must be included in every NPDES permit, are provided in Attachments D of this Order. 40 CFR 122.41(a)(1) and (b) through (n) establish conditions that apply to all state-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. 40 CFR 123.25(a)(12) allows the state to omit or modify conditions to impose more stringent requirements. The Regional Standard Provisions (Attachment G) supplement the Federal Standard Provisions. In accordance with 40 CFR 123.25, this Order omits federal conditions that address enforcement authority specified in 40 CFR 122.41(j)(5) and (k)(2) because the CWC enforcement authority is more stringent. In lieu of these conditions, this Order incorporates by reference CWC Section 13387(e).

B. Monitoring and Reporting Program Requirements (Provision VI.B)

The Discharger is required to monitor the permitted discharge in order to evaluate compliance with permit conditions. Monitoring requirements are contained in the Monitoring and Reporting Program (Attachment E), Standard Provisions (Attachment D), and Regional Standard Provisions (Attachment G). This provision requires compliance with these documents and is authorized by 40 CFR 122.41(h) and (j), and CWC sections 13267 and 13383.

C. Special Provisions (Provision VI.C)

- 1. Reopener Provisions.** These reopener provisions are based on 40 CFR 122.63 and allow modification of this Order and its effluent limitations as necessary in response to updated WQOs, regulations, or other new relevant information that may be established in the future and other circumstances allowed by law.
- 2. Notice of Intent (NOI) Application.** Provision VI.C.2, Notice of Intent (NOI) Application, is based on 40 CFR 122.28(b).

3. **NOI Review.** Provision VI.C.3, NOI Review, is based on 40 CFR 122.28(b).
4. **Discharge Authorization.** Provision VI.C.4, Discharge Authorization, is based on 40 CFR 122.28(b).
5. **Non-Compliance is a Violation.** Provision VI.C.5, Non-Compliance is a Violation, is based on 40 CFR 122.41(a).
6. **Triggers.** Dischargers authorized under this Order are expected to use BAT and treat their fuel component or VOC pollutants to non-detectable levels. Some compounds other than pollutants with effluent limitations may be detected in the effluent of some of the treatment systems, however. These pollutants include both organic and inorganic compounds. The purpose of these provisions is to require Dischargers to do additional activities should any pollutants exceed the triggers in Table F-8. These triggers are not effluent limitations, and must not be construed as such. Instead, they are levels at which additional investigation is warranted to determine whether a numeric limit for a particular constituent is necessary. Unless explained in a footnote, the concentration-based triggers in Table F-8 are set at the minimum applicable criterion, as determined from State MCLs, Federal MCLs, CTR criteria, or Basin Plan WQOs. The reason for this approach is explained in section IV of this Fact Sheet, and further explained below.
 - a. **Triggers for Inorganic Compounds.** Antimony, arsenic, beryllium, cadmium, chromium, copper, lead, mercury, nickel, selenium, silver, thallium, and zinc (hereinafter called inorganic compounds) are present in fuel- or VOC-cleanup discharges, primarily due to background concentrations in the shallow groundwater being remediated. The discharge volume and concentrations of inorganic compounds concentrations in the effluent are relatively low. The Regional Water Board has concluded that Bay-wide inorganic compounds loading from fuel- or VOC-cleanup discharges represent a very small portion of total inorganic compounds loadings from sources within the Region (including municipal and industrial point-source discharges and stormwater discharges), and therefore, shall cause no impairment of beneficial uses or potential exceedances of inorganic compounds objectives in receiving waters.

Facilities where inorganic compounds have adversely impacted groundwater are not eligible for coverage under this Order. Each Discharger shall submit, as part of the NOI application for proposed discharge, analytical results including inorganic compounds concentrations in the influent and effluent, if available, or maximum concentrations in any individual extraction wells, if not operating yet. Based on these data, the Discharger may receive a discharge authorization letter. In some cases after starting up an extraction and treatment system, the effluent concentration of some inorganic compounds may exceed the triggers listed in Table F-8. In this case, the Discharger shall take three additional samples and have them analyzed for the inorganic compound of concern and comply with the Provisions VI.C.7, VI.C.8, or VI.C.9.

Triggers for copper and nickel have been updated in the General Permit from the previous Order to reflect the recently adopted SSOs and SSTs for copper throughout San Francisco Bay, and the SSOs and SSTs for nickel in the South Bay.

- b. Triggers for Organic Compounds.** Dischargers authorized under this Order are expected to use BAT and treat their VOC pollutants to non-detectable levels. Sites where pesticides or other conservative pollutants have adversely impacted groundwater are not eligible for coverage under this Order. Each Discharger shall submit, as part of the NOI application for proposed discharge, analytical results including volatile and semi-volatile organic compounds concentrations in the influent and effluent if available or maximum concentrations in any individual extraction wells, if not operating yet. In addition, each Discharger shall submit a report, to the satisfaction of Executive Officer, certifying the adequacy of the proposed treatment system in removal of all organic pollutants of concern. Based on these data and information, the Discharger may receive a discharge authorization letter. However, some organic compounds, other than pollutants with effluent limitations, may be detected in the effluent of some of the treatment systems. This could be due to the movement of the contaminated groundwater from a neighboring site into the capture zone of the treatment facility authorized under this permit. Table F-8 contains concentration-based triggers for conducting additional activities for a list of pollutants reported by Dischargers or listed in the CTR. This provision would allow Dischargers to continue groundwater cleanup while investigating the ability to treat any detected volatile or semi volatile organic compounds, in excess of Table F-8 triggers.

Table F-8. Basis for Table 3 Trigger Compounds

Pollutant	CAS Number	Minimum State/Federal MCL (µg/L)	Minimum Basin Plan Criteria ^[1] (µg/L)	Minimum CTR Criteria ^[1] (µg/L)	Trigger ^{[1][7]} (µg/L)
Antimony	7440360	6	---	14	6
Arsenic	7440382	10	36	36	10
Beryllium	7440417	4	---	---	4
Cadmium	7440439	5	1.1	2.5	1.1
Chromium (VI)	18540299	---	11	11	11 ^[2]
Copper ^[3]	7440508	1000	5.9	---	5.9
Copper ^[4]	7440508	1000	3.4	---	3.4
Copper ^[5]	7440508	1000	4.7	---	4.7
Lead	7439921	15	3.2	3.2	3.2
Mercury	7439976	2	0.025	0.050	0.025
Nickel ^[3]	7440020	100	30	30	30
Nickel ^[4]	7440020	100	13	13	13
Nickel ^[5]	7440020	100	19	19	19
Selenium	7782492	50	---	5	5
Silver	7440224	100	2.2	2.2	2.2
Thallium	7440280	2	---	1.7	1.7
Zinc	7440666	5000	86	86	86
Cyanide	57125	150	2.9	5.2	2.9
2,3,7,8-TCDD	1746016	0.00003	---	1.3E-08	1.3E-08
Acrylonitrile	107131	---	---	0.059	0.059
Bromoform	75252	80	---	4.3	4.3

Pollutant	CAS Number	Minimum State/Federal MCL (µg/L)	Minimum Basin Plan Criteria ^[1] (µg/L)	Minimum CTR Criteria ^[1] (µg/L)	Trigger ^{[1][7]} (µg/L)
Chlorodibromomethane	124481	80	---	0.401	0.401
Dichlorobromomethane	75274	80	---	0.56	0.56
1,2-Dichloropropane	78875	5	---	0.52	0.52
1,3-Dichloropropylene	542756	0.5	---	10	0.5
1,1,2,2-Tetrachloroethane	79345	1	---	0.17	0.17
Pentachlorophenol	87865	1	---	0.28	0.28
2,4,6-Trichlorophenol	88062	---	---	2.1	2.1
Benzidine	92875	---	---	0.00012	0.00012
Benzo(a)anthracene	56553	---	---	0.0044	0.0044
Benzo(a)pyrene	50328	0.2	---	0.0044	0.0044
Benzo(b)fluoranthene	205992	---	---	0.0044	0.0044
Benzo(k)fluoranthene	207089	---	---	0.0044	0.0044
Bis(2-chloroethyl)ether	111444	---	---	0.031	0.031
Bis(2-ethylhexyl)phthalate	117817	---	---	1.8	1.8
Chrysene	218019	---	---	0.0044	0.044
Dibenzo(a,h)anthracene	53703	---	---	0.0044	0.0044
3,3'-Dichlorobenzidine	91941	---	---	0.04	0.04
2,4-Dinitrotoluene	121142	---	---	0.11	0.11
1,2-Diphenylhydrazine	122667	---	---	0.040	0.040
Hexachlorobenzene	118741	1	---	0.00075	0.00075
Hexachlorobutadiene	87683	---	---	0.44	0.44
Hexachloroethane	67721	---	---	1.9	1.9
Indeno(1,2,3-c,d)pyrene	193395	---	---	0.0044	0.0044
N-nitrosodimethylamine	62759	---	---	0.00069	0.00069
N-nitrosodi-n-propylamine	621647	---	---	0.005	0.005
Aldrin	309002	---	---	0.00013	0.00013
alpha-BHC	319846	---	---	0.0039	0.0039
beta-BHC	319857	---	---	0.014	0.014
gamma-BHC	58899	0.2	---	0.019	0.019
Chlordane	57749	0.1	---	0.00057	0.00057
4,4-DDT	50393	---	---	0.00059	0.00059
4,4-DDE	72559	---	---	0.00059	0.00059
4,4-DDD	72548	---	---	0.00083	0.00083
Dieldrin	60571	---	---	0.00014	0.00014
alpha-Endosulfan	959988	---	---	0.0087	0.0087
beta-Endosulfan	33213659	---	---	0.0087	0.0087
Endrin	72208	2	---	0.0023	0.0023
Endrin aldehyde	7421934	---	---	0.76	0.76
Heptachlor	76448	0.01	---	0.00021	0.00021
Heptachlor epoxide	1024573	0.01	---	0.00010	0.00010
PCBs, sum	1336363	0.5	---	0.00017	0.00017
Toxaphene	8001352	3	---	0.0002	0.0002
1,4-dioxane	123911	3	---	---	3
Turbidity (NTU)	---	5	---	---	5
Odor-Threshold (Units)	---	3	---	---	3
TPHs (other than gasoline and diesel)	---	---	---	---	50 ^[6]
Sulfate	---	250,000	---	---	250,000
Foaming agents	---	500	---	---	500
Color (units)	---	15	---	---	15

Pollutant	CAS Number	Minimum State/Federal MCL (µg/L)	Minimum Basin Plan Criteria ^[1] (µg/L)	Minimum CTR Criteria ^[1] (µg/L)	Trigger ^{[1][7]} (µg/L)
Footnotes for Table F-8: [1] Unit is µg/L unless noted otherwise right after the name of pollutant [2] If total chromium concentration exceeds 11 µg/L, then analysis for chromium(VI) shall also be conducted [3] Applicable to Suisun Bay and San Pablo Bay segments of San Francisco Bay. [4] Applicable to Central Bay and Lower Bay segments of San Francisco Bay. [5] Applicable to South San Francisco Bay, south of Hayward Shoals. [6] Trigger value based on Regional Water Board staff BPJ. If a discharger is reporting monitoring data with a detection level higher than 50 µg/L, the reason for the higher detection level shall be fully explained within the monitoring report. [7] If a discharger is reporting non-detect monitoring data with a reporting level higher than the trigger, the reason for the higher detection level shall be consistent with the SIP Appendix 4 required minimum levels (please refer to our web site for the latest version of SIP) and must be explained within the monitoring report.					

8. **Individual NPDES Permit May Be Required.** Provision VI.C.11 is retained from the previous permit and is based on 40 CFR 122.28(b)(3).
9. **Treatment Reliability Requirement.** Provision VI.C.12, Treatment Reliability, is mostly based on 40 CFR 122.41. The basis for the requirement for a certified engineer to oversee the treatment and operation of the treatment system is to ensure that qualified professionals perform this work. Service stations operators are generally not qualified for this technical level of oversight.

VIII. PUBLIC PARTICIPATION

The California Regional Water Quality Control Board, San Francisco Bay Region (Regional Water Board) is considering the reissuance of general waste discharge requirements (GWDRs) that will serve as a General NPDES Permit. As a step in the GWDRs adoption process, the Regional Water Board has developed tentative GWDRs. The Regional Water Board encourages public participation in the GWDR adoption process.

A. Notification of Interested Parties

The Regional Water Board has notified the Dischargers and interested agencies and persons of its intent to prescribe GWDRs for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Notification was provided through the Recorder on December 12, 2011.

B. Written Comments

Staff determinations are tentative. Interested persons are invited to submit written comments concerning this Order. Comments should be submitted either in person or by mail to the Executive Officer at the Regional Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Regional Water Board, written comments should be received at the Regional Water Board offices by 5:00 p.m. on January 12, 2012.

C. Public Hearing

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: February 8, 2012
Time: 9:00 a.m.
Location: Elihu Harris State Building (1st Floor auditorium)
1515 Clay Street
(Walking distance from City Center 12th Street BART station)
Oakland, CA 94612

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, GWDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our web address is <http://www.waterboards.ca.gov/sanfranciscobay> where you can access the current agenda for changes in dates and locations.

D. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Regional Water Board regarding the final GWDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

E. Information and Copying

Report of Waste Discharges, related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above during regular office hours, which are generally weekdays from 8:00 a.m. to 5:00 p.m., excluding 12:00 p.m. to 1:00 p.m. lunch hours and holidays. Copying of documents may be arranged through the Regional Water Board by calling (510) 622-2300.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the GWDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this order should be directed to **Farhad Azimzadeh at (510) 622-2310 or by e-mail at fazimzadeh@waterboards.ca.gov.**