

San Francisco Bay Regional Water Quality Control Board

TENTATIVE ORDER No. R2-2013-00XX
NPDES No. CA0038318

The following discharger and discharge points are subject to waste discharge requirements set forth in this Order.

Table 1. Discharger Information

Discharger	City and County of San Francisco and North Bayside System Unit
Facility Name	San Francisco International Airport, Mel Leong Treatment Plants (Sanitary and Industrial Plants) and wastewater collection systems
CIWQS Place Number	256507
Facility Address	Bldg. 924 Clearwater Drive, San Francisco, San Mateo County, California 94128
The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a major discharge.	

Table 2. Discharge Location

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
001-San	Secondary treated sanitary wastewater	37° 39' 55" N	122° 21' 41" W	Lower San Francisco Bay
001-Ind	Treated industrial wastewater and stormwater runoff	37° 39' 55" N	122° 21' 41" W	Lower San Francisco Bay
001	Combined treated sanitary and industrial wastewater and stormwater runoff	37° 39' 55" N	122° 21' 41" W	Lower San Francisco Bay
002	Dechlorinated treated sanitary and industrial wastewater and stormwater runoff	37° 39' 55" N	122° 21' 41" W	Lower San Francisco Bay
003	Stormwater runoff	37° 36' 18" N	122° 22' 40" W	Lower San Francisco Bay
004	Stormwater runoff	37° 36' 44" N	122° 23' 19" W	Lower San Francisco Bay
005	Stormwater runoff	37° 36' 18" N	122° 21' 58" W	Lower San Francisco Bay
006	Stormwater runoff	37° 37' 05" N	122° 21' 44" W	Lower San Francisco Bay
007	Stormwater runoff	37° 37' 42" N	122° 22' 17" W	Lower San Francisco Bay
008	Stormwater runoff	37° 37' 40" N	122° 22' 25" W	Lower San Francisco Bay
009	Stormwater runoff	37° 37' 44" N	122° 23' 19" W	Lower San Francisco Bay
010	Stormwater runoff	37° 38' 20" N	122° 23' 25" W	Lower San Francisco Bay
013	Stormwater runoff	37° 38' 11" N	122° 23' 10" W	Lower San Francisco Bay

Table 3. Administrative Information

This Order was adopted by the Regional Water Quality Control Board on:	
This Order shall become effective on:	June 1, 2013
This Order shall expire on:	May 31, 2018
CIWQS Regulatory Measure Number	
The Discharger shall file a Report of Waste Discharge in accordance with Title 23, California Code of Regulations, as application for re-issuance of waste discharge requirements no later than:	December 1, 2017

I, Bruce H. Wolfe, Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, San Francisco Bay Region, on the date indicated above.

Bruce H. Wolfe, Executive Officer

Contents

I. Facility Information.....	4
II. Findings.....	4
III. Discharge Prohibitions	12
IV. Effluent Limitations and Discharge Specifications.....	12
A. Conventional and Non-Conventional Pollutant Effluent Limitations	12
B. Toxic Substances Effluent Limitations	13
C. Whole Effluent Toxicity.....	14
V. Receiving Water Limitations.....	15
VI. Provisions	16
A. Standard Provisions.....	16
B. Monitoring and Reporting Program (MRP) Requirements	16
C. Special Provisions	16
1. Reopener Provisions.....	16
2. Effluent Characterization Study and Report	17
3. Best Management Practices and Pollutant Minimization Program.....	18
4. Special Provisions for POTWs.....	22
5. Other Special Provisions	23
VII. Compliance Determination.....	25

Tables

Table 1. Discharger Information.....	1
Table 2. Discharge Location	1
Table 3. Administrative Information	2
Table 4. Facility Information	4
Table 5. Basin Plan Beneficial Uses.....	9
Table 6. Conventional and Non-Conventional Pollutant Effluent Limitations	12
Table 7. Toxic Pollutant Effluent Limitations	14
Table 8. Copper Action Plan.....	23
Table 9. Cyanide Action Plan	24

Attachments

Attachment A – Definitions	A-1
Attachment B – Facility Map.....	B-1
Attachment C – Process Flow Diagram.....	C-1
Attachment D – Federal Standard Provisions.....	D-1
Attachment E – Monitoring and Reporting Program (MRP).....	E-1
Attachment F – Fact Sheet.....	F-1
Attachment G – Regional Standard Provisions and Monitoring and Reporting Requirements	G-1

I. FACILITY INFORMATION

The following facility is subject to the waste discharge requirements set forth in this Order:

Table 4. Facility Information

Discharger	City and County of San Francisco and North Bayside System Unit
Facility Name	San Francisco International Airport, Mel Leong Sanitary and Industrial Treatment Plants and wastewater collection systems
Facility Address	Bldg. 924 Clearwater Drive, San Francisco, California 94128
CIWQS Place Numbers	256506 (Industrial) 256507 (Sanitary)
CIWQS Discharger Party Number	39685
Facility Contact, Title, Phone, and Email	Peter Acton, Maintenance Director, 650 821-5400, Peter.Acton@flysf.com
Mailing Address	P.O. Box 8097, 682 North McDonnell Road, San Francisco, CA 94128
Facility Type	A Sanitary Wastewater Treatment Plant and an Industrial Wastewater Treatment Plant
Facility Design Flow	Sanitary Plant: 2.2 million gallons per day (MGD) Industrial Plant: 1.2 MGD Combined Flow: 3.4 MGD
Service Area	San Francisco International Airport
Service Population	Airport and airline employees and travelers estimated at 10,000

II. FINDINGS

The California Regional Water Quality Control Board, San Francisco Bay Region (hereinafter Regional Water Board), finds:

A. Background. The City and County of San Francisco, San Francisco International Airport, Mel Leong Treatment Plant, Sanitary Plant (hereinafter Sanitary Plant) is currently discharging under Order No. R2-2007-0058 (CIWQS Regulatory Measure No. 256507) and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0038318. The City and County of San Francisco, San Francisco International Airport, Mel Leong Treatment Plant, Industrial Plant (hereinafter Industrial Plant) is currently discharging under Order No. R2-2007-0060 (CIWQS Regulatory Measure No. 256506) and NPDES Permit No. CA0028070. Both orders have been amended by Order Nos. R2-2010-0054 and R2-2012-0096.

Both the Sanitary Plant and Industrial Plant discharge wastewater to a single pipeline for dechlorination and discharge into Lower San Francisco Bay by the North Bayside System Unit (NBSU) facility in South San Francisco. This Order combines the previous Sanitary Plant and Industrial Plant permits into one permit. The Sanitary Plant, Industrial Plant, and their wastewater collection systems are hereinafter collectively referred to as the Facility.

The NBSU, a Joint Powers Authority, operates the dechlorination plant and discharges the treated effluent. The NBSU’s members include the cities of Millbrae, Burlingame, South San Francisco, and San Bruno, and San Francisco. San Francisco and the NBSU are hereinafter referred to as the Discharger. For the purposes of this Order, references to the “discharger” or “permittee” in

applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

On March 30, 2012, the Discharger submitted a Report of Waste Discharge and applied for an NPDES permit to discharge up to 2.2 million gallons per day (MGD) of treated sanitary wastewater from the Sanitary Plant and up to 1.2 MGD of treated industrial wastewater from the Industrial Plant. The Discharger also applied for coverage of its stormwater discharges from industrial and runway areas.

These discharges are also regulated under Order No. R2-2012-0096 (NPDES Permit CA0038849), which specifies all requirements on mercury and PCBs from wastewater discharges in the region. This Order does not affect the mercury and PCBs permit.

B. Facility Description and Discharge Location

- 1. Facility Description.** The City and County of San Francisco owns and operates the Sanitary Plant and Industrial Plant. The Industrial Plant treats industrial wastewater from maintenance shops and vehicle washing, as well as first-flush stormwater runoff from industrial areas. The Sanitary Plant includes a collection system and treats sanitary wastewater from airplanes and airport facilities, including terminal restrooms, hangars, restaurants, and shops. The Discharger may, in emergency situations, use either plant to store or treat flows, spills, or overflows that would normally flow to the other plant to ensure that all wastewater is adequately treated. Every two months, approximately 16,000 gallons of secondary treated industrial wastewater is routed to the sanitary plant to allow maintenance of the industrial plant's chlorine disinfection system. The service population for these treatment plants is estimated at 10,000. In 2011, the Sanitary Plant discharged an average daily flow of 0.63 MGD; the highest recorded daily flow was 1.4 MGD, well below the design flow of 2.2 MGD. In 2011, the Industrial Plant discharged an average daily flow of 0.63 MGD; the highest recorded daily flow was 1.22 MGD, roughly equal to the design flow of 1.2 MGD.
- 2. Collection Systems.** Sanitary wastewaters from airport facilities are collected and conveyed to the Sanitary Plant through a system consisting of over 20 miles of sewer piping, 7 lift stations, and 18 pump stations. Industrial wastewaters from airport facilities are collected in a separate industrial collection system that has 20 pump stations directing wastewater to a single force main leading to the Industrial Plant.

The first flush of stormwater runoff from terminals, taxiways, tarmacs, and aircraft and vehicle parking is collected in four detention ponds (the North Oxidation Pond, the South Detention Pond, the West Field Detention Basin, and the East Pond). Stormwater runoff collected in these ponds and basins is pumped to the Industrial Plant. The detention ponds have a total capacity of 9.6 million gallons. When these detention basins are full, excess runoff is discharged directly to San Francisco Bay through one of nine stormwater outfalls. From a few active airport areas, the runoff is not collected in basins but is either pumped directly to the Industrial Plant or discharged to San Francisco Bay. Runoff from runways and some portions of taxi ways is discharged directly to the Bay after flowing through grassy runway medians. Deicing fluids could be used at any gate depending on the destination of the departing aircraft, but in practice are rarely, if ever, used. Any deicing fluid wastewater would be routed to the detention basins with the first flush of stormwater runoff and treated at the

Industrial Plant. The nine stormwater outfalls are monitored by the Discharger pursuant to the requirements of this Order.

- 3. Treatment Description.** The Sanitary Plant treatment operations consist of punched plate bar screens, grit removal, flow equalization, biological treatment using sequencing batch reactors, effluent flow equalization, and chlorination. Solids from the Sanitary Plant are treated by gravity belt thickening and anaerobic digestion before dewatering by belt filter presses or air drying using sludge drying beds.

Influent from the industrial wastewater collection system is initially stored in an equalization tank. The first treatment stage at the Industrial Plant flocculates the combined industrial wastewater and any incoming first flush of stormwater, followed by dissolved air floatation, pH adjustment (as needed), aerobic biological treatment via trickling filter, secondary clarification, and chlorination. The Discharger can divert up to 0.72 MGD of the effluent from the chlorination tank to tertiary filters. This reclaimed water is used, when required, for irrigation or utility water make-up. The clarifiers collect sludge and scum, which are pumped to sludge beds for dewatering. Filtrate drained from the sludge is pumped back to the trickling filter for treatment. The existing industrial treatment plant equipment is reaching design life and may be replaced during the term of the permit with new equipment that will meet, or exceed, the performance of the existing plant.

Chlorinated wastewater from both plants is combined at a pumping station and discharged to the NBSU pipeline for dechlorination in South San Francisco Wastewater Treatment Facility, along with treated effluent from South San Francisco, San Bruno, Millbrae, and Burlingame, prior to discharge through a deep water outfall.

Attachment B provides maps of the area around the Facility. Attachment C provides a flow schematic of the Facility.

- 4. Discharge Point.** Effluent from the NBSU force main discharges into Lower San Francisco Bay, northeast of Point San Bruno, through a submerged diffuser approximately 5,300 feet offshore at a depth of 20 feet below mean lower low water (latitude 37° 39' 55" North, and longitude 122° 21' 41" West). The diffuser is 654 feet long and consists of 66 three-inch openings spaced 7 feet apart. This outfall is Discharge Point No. 002. Monitoring Location EFF-002 is a point in the outfall pipeline after dechlorination.

This Order defines internal discharge points. Discharge Point No. 001 (Monitoring Location EFF-001) represents the combined treated effluent from the Sanitary Plant and Industrial Plant. Discharge Point No. 001-San (Monitoring Location EFF-001-San) represents the treated effluent from the Sanitary Plant. Discharge Point No. 001-Ind (Monitoring Location EFF-001-Ind) represents the treated effluent from the Industrial Plant.

- 5. Biosolids Management.** The dewatering and disposal of biosolids from the Sanitary Plant and Industrial Plant are separate. Biosolids from the Sanitary Plant are treated by gravity belt thickening and anaerobic digestion, then dewatered by belt filter presses or air dried using sludge drying beds. Final sludge cake and air-dried sludge transported to SYNAGRO composting facility. Sludge and scum from the Industrial Plant are pumped to separate sludge

beds for dewatering. The dried industrial waste sludge is trucked off-site and used as daily cover at a landfill.

- 6. Stormwater Discharge.** In addition to the Sanitary Plant and Industrial Plant discharges, this Order also covers stormwater discharges of surface runoff from different areas of the airport. Stormwater from tarmac areas in excess of the available storage capacity in the detention basins is discharged directly to San Francisco Bay. Several airport areas are occupied by tenants, including but not limited to the United Maintenance Facility and the Fuel Tank Farm. These tenants cover their own stormwater discharges under the statewide industrial stormwater NPDES permit (NPDES General Permit No. CAS000001) and thus are not covered by this Order. Airport tenants are prohibited by the Airport's Rules and Regulations from generating any unauthorized discharges to the stormwater runoff collection system. Only rainfall runoff is allowed to be discharged to the airport's stormwater collection system. The airport's four stormwater runoff detention basins store only the first flush of rainfall runoff generated at the developed portions of the airport. Once these basins are filled to capacity, the inflow gates are closed and each basin is isolated from the stormwater conveyance pipelines. Any additional runoff is then discharged directly from the storm drain system to the Bay. The runoff stored in the detention basins is pumped to the Industrial Plant for treatment. A separate State Water Board General Permit, CAS000002, covers stormwater discharges associated with construction activities taking place east of Highway 101.
 - a. Discharge Point No. 003.** Discharge Point 003 discharges stormwater from areas that drain into the South Detention Pond. When the South Detention Pond has reached capacity, stormwater is discharged directly to the Bay through Discharge Point 003. The South Detention Pond receives runoff from the United Airlines cargo and surface facilities, Boarding Areas A through F, and Singapore Airlines and Philippine Airlines service areas in the south-west part of the airport (known as Plot 3). Over these tarmac areas, various industrial activities take place that include aircraft, vehicle, and equipment fueling, maintenance, and washing, and, when rarely required, aircraft de-icing. This Discharge Point also discharges, directly to the Bay, runoff from runway areas along the southeast corner of the airport property where there are no industrial or other activities involving the use of fuel or chemicals.
 - b. Discharge Point No. 004.** Discharge Point No. 004 discharges stormwater runoff from areas that drain into the 6.0-million-gallon West Field Detention Basin, the 0.3-million-gallon East Detention Basin, which includes runoff from the northwest side of Terminal 3, and the 0.77-million-gallon United Airlines Detention Basin. When these detention ponds have reached full capacity that stormwater is discharged direct to the Bay through Discharge Point 004. Runoff from the United States Coast Guard Facility is also directly discharged through Discharge Point No. 004 to the Seaplane Harbor, which opens to San Francisco Bay.
 - c. Discharge Point No. 005.** Discharge Point No. 005 discharges stormwater runoff, and any infiltrated Bay water, from runway and taxiway areas south of Runway 28L, directly to the Bay. There is no aircraft, vehicle, or equipment fueling, maintenance, or washing in this area.

- d. Discharge Point No. 006.** Discharge Point 006 discharges stormwater runoff, and any infiltrated Bay water, from the area north of Runway 28R, directly to the Bay. There is no aircraft, vehicle, or equipment fueling, maintenance, or washing in this area.
 - e. Discharge Point No. 007.** Discharge Point No. 007 discharges stormwater runoff, and any infiltrated Bay water, from the area northwest of Runway 19R, directly to the Bay. There is no aircraft, vehicle, or equipment fueling, maintenance, or washing in this area.
 - f. Discharge Point No. 008.** Discharge Point No. 008 discharges stormwater runoff, and any infiltrated Bay water, from the taxiway, ramp, and roof areas of the eastern section of the Superbay Hangar areas directly to the Bay. If there is a spill incident and this affects the quality of runoff water, the runoff is pumped to the Industrial Plant for treatment.
 - g. Discharge Point No. 009.** Discharge Point No. 009 discharges stormwater runoff, and any infiltrated Bay water, from the taxiway, ramp, and roof areas under the western section of Superbay Hangar area directly to the Bay.
 - h. Discharge Point No. 010.** Discharge Point No. 010 discharges stormwater runoff, from the western area of the North Cargo Facility and areas around the North Access Road, directly to the Bay. There is no aircraft, vehicle, or equipment fueling, maintenance, or washing in this area.
 - i. Discharge Point No. 013.** Discharge Point No. 013 discharges stormwater runoff from taxiways and ramps around the North Cargo Facility that drain into the 0.43-million-gallon North Field Detention Basin. When the detention pond has reached its capacity, stormwater is discharged directly to the Bay through Discharge Point 013.
- C. Legal Authorities.** This Order is issued pursuant to Clean Water Act (CWA) section 402 and implementing regulations adopted by USEPA, and California Water Code (CWC) chapter 5.5, division 7, commencing with section 13370. It serves as an NPDES permit for point source discharges from the Facility to surface waters. This Order also serves as Waste Discharge Requirements pursuant to CWC article 4, chapter 4, division 7, commencing with section 13260.
- D. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for the requirements of this Order, is hereby incorporated into this Order and constitutes part of the findings for this Order. Attachments A through E, and G are also incorporated into this Order.
- E. California Environmental Quality Act (CEQA).** Under CWC section 13389, this action to adopt an NPDES permit is exempt from Chapter 3 of CEQA.
- F. Technology-Based Effluent Limitations.** CWA section 301(b) and NPDES regulations at Title 40 of the Code of Federal Regulations section 122.44 (40 CFR 122.44) require that permits include conditions meeting applicable technology-based requirements at minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order from the Sanitary Plant must meet minimum federal technology-based requirements

based on Secondary Treatment Standards at 40 CFR 133. The discharge authorized by this Order from the Industrial Plant meet minimum federal technology-based requirements based on best professional judgment, consistent with the requirements of 40 CFR 125.3(c) and (d). Further discussion of the technology-based effluent limitations is included in the Fact Sheet.

G. Water Quality-Based Effluent Limitations (WQBELs). CWA section 301(b) and 40 CFR 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. NPDES regulations at 40 CFR 122.44(d)(1)(i) mandate that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, WQBELs must be established using (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion (WQC), such as a proposed state criterion or policy interpreting the state’s narrative criterion, supplemented with other relevant information, as provided in 40 CFR 122.44(d)(1)(vi).

H. Water Quality Control Plans. *The Water Quality Control Plan for the San Francisco Bay Basin* (hereinafter Basin Plan) is the Regional Water Board’s master water quality control planning document. It designates beneficial uses and water quality objectives (WQOs) for waters of the State and United States, including surface and groundwater. It also includes implementation programs to achieve WQOs. The Basin Plan was duly adopted by the Regional Water Board and approved by the State Water Board, the Office of Administrative Law, and USEPA. Requirements of this Order implement the Basin Plan. Basin Plan beneficial uses for Lower San Francisco Bay are listed in the table below.

Table 5. Basin Plan Beneficial Uses

Discharge Point	Receiving Water Name	Beneficial Use(s)
002 to 010 and 013	Lower San Francisco Bay	Industrial Service Supply (IND) Navigation (NAV) Water Contact Recreation (REC1) Non-Contact Water Recreation (REC2) Ocean Commercial and Sport Fishing (COMM) Wildlife Habitat (WILD) Preservation of Rare and Endangered Species (RARE) Fish Spawning (SPWN) Fish Migration (MIGR) Shellfish Harvesting (SHELL) Estuarine Habitat (EST)

The State Water Board’s *Water Quality Control Plan for Enclosed Bays and Estuaries—Part 1, Sediment Quality* became effective on August 25, 2009. This plan supersedes other narrative sediment quality objectives and establishes new sediment quality objectives and related implementation provisions for specifically defined sediments in most bays and estuaries.

- I. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995, and November 9, 1999. About 40 criteria in the NTR apply in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that applied in the State. The CTR was amended on February 13, 2001. These rules contain WQC for priority pollutants.
- J. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (hereinafter State Implementation Policy [SIP]). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria promulgated through the NTR and to the priority pollutant objectives established in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria USEPA promulgated through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- K. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards become effective for CWA purposes (65 Fed. Reg. 24641 [April 27, 2000], codified at 40 CFR 131.21). Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- L. Stringency of Requirements for Individual Pollutants.** This Order contains both technology-based and water quality based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on carbonaceous biochemical oxygen demand (CBOD), biochemical oxygen demand (BOD), total suspended solids (TSS), and pH. Further, this Order prohibits the discharge of deicing fluid containing urea based on effluent limitation guidelines established in 40 CFR 449.10. These technology-based limitations are discussed further in the Fact Sheet. This Order's technology-based pollutant restrictions on CBOD, BOD, TSS, and pH implement the minimum applicable federal technology-based requirements.

WQBELs have been derived to implement WQOs that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that WQBELs were derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR 131.38. On May 18, 2000, USEPA approved the procedures for calculating individual WQBELs for priority pollutants based on the SIP. Most beneficial uses and WQOs contained in the Basin Plan were approved under State law and submitted to USEPA. Any WQOs and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless "applicable water quality standards for the purposes of the CWA" pursuant to 40 CFR 131.21(c)(1).

- M. Antidegradation Policy.** NPDES regulations at 40 CFR 131.12 require that state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16,

which incorporates the federal antidegradation policy where the federal policy applies under federal law and requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies.

- N. Anti-Backsliding Requirements.** CWA sections 402(o)(2) and 303(d)(4) and NPDES regulations at 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous order, with some exceptions where limitations may be relaxed.
- O. Endangered Species Act.** This Order does not authorize any act that results in the taking of a threatened or endangered species or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered Species Act (Fish and Game Code sections 2050 to 2097) or the federal Endangered Species Act (16 U.S.C.A. sections 1531 to 1544). This Order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the State. The Discharger is responsible for meeting all requirements of applicable State and federal law pertaining to threatened and endangered species.
- P. Monitoring and Reporting.** NPDES regulations at 40 CFR 122.48 require that all NPDES permits specify requirements for recording and reporting monitoring results. CWC sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP, Attachment E) establishes monitoring and reporting requirements to implement federal and State requirements.
- Q. Standard and Special Provisions.** Attachment D contains Federal Standard Provisions that apply to all NPDES permits in accordance with 40 CFR 122.41 and additional conditions applicable to specified categories of permits in accordance with 40 CFR 122.42. The Discharger must comply with all standard provisions and with those additional conditions that apply under 40 CFR 122.42. The Discharger must also comply with the Regional Standard Provisions provided in Attachment G. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. The Fact Sheet provides rationales for the special provisions.
- R. Provisions and Requirements Implementing State Law.** None of the requirements in this Order are included to implement State law only.
- S. Notification of Interested Parties.** The Regional Water Board notified the Discharger and interested agencies and persons of its intent to prescribe WDRs for the discharge and provided them with an opportunity to submit written comments and recommendations. The Fact Sheet provides details of the notification.
- T. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. The Fact Sheet provides details of the public hearing.

IT IS HEREBY ORDERED, that this Order supersedes Order Nos. R2-2007-0058 and R2-2007-0060 (CIWQS Regulatory Measure Nos. 337341 and 337297), as amended by Order Nos. R2-2010-0054 and R2-2012-0096, except for enforcement purposes, and, in order to meet the provisions contained in CWC Division 7 (commencing with section 13000) and regulations adopted thereunder, and the provisions of

the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order. This Order also rescinds Cease and Desist Order Nos. R2-2007-0059 and R2-2007-0061, except for enforcement purposes.

III. DISCHARGE PROHIBITIONS

- A. Discharge of treated wastewater at a location or in a manner different from that described in this Order is prohibited.
- B. Discharge at any point at which the treated wastewater does not receive an initial dilution of at least 74:1 (nominal) is prohibited. Compliance shall be achieved by proper operation and maintenance of the discharge outfall to ensure that it (or its replacement, in whole or in part) is in good working order, and is consistent with or can achieve better mixing than that described in the Fact Sheet. The Discharger shall address measures taken to ensure this in its application for permit reissuance.
- C. The bypass of untreated or partially treated wastewater to waters of the United States is prohibited, except as provided for in the conditions stated in Attachment D, section I.G, of this Order.
- D. The average dry weather effluent flow, measured at Monitoring Location EFF-001-San and EFF-001-Ind, as described in the MRP, shall not exceed 2.2 MGD and 1.2 MGD, respectively. Actual average dry weather flows shall be determined for compliance with this prohibition over three consecutive dry weather months each year.
- E. Any sanitary sewer overflow that results in a discharge of untreated or partially treated wastewater to waters of the United States is prohibited.
- F. The discharge of deicing fluid that contains urea is prohibited

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Conventional and Non-Conventional Pollutant Effluent Limitations

- 1. Discharges at Discharge Point Nos. 001-San and 001-Ind (as determined at Monitoring Locations EFF-001-San and EFF-001-Ind, as described in the MRP) shall comply with the following effluent limitations:

Table 6. Conventional and Non-Conventional Pollutant Effluent Limitations

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Carbonaceous Biochemical Oxygen Demand (5-day at 20°C) (CBOD ₅) (Sanitary Plant) ^[1]	mg/L	25	40	--	--	--
Biochemical Oxygen Demand (5-day at 20°C) (BOD ₅) (Industrial Plant) ^[2]	mg/L	30	45	--	--	--

Parameter	Units	Effluent Limitations				
		Average Monthly	Average Weekly	Maximum Daily	Instantaneous Minimum	Instantaneous Maximum
Total Suspended Solids (TSS)	mg/L	30	45	--	--	--
CBOD ₅ , BOD ₅ , and TSS percent removal ^[3]	%	85 minimum	--	--	--	--
Oil and Grease	mg/L	10	--	20	--	--
pH ^[4]	Standard units.	--	--	--	6.0	9.0

Footnotes

- ^[1] The CBOD₅ limit applies at Discharge Point 001-San.
- ^[2] The BOD₅ limit applies only at Discharge Point 001-Ind.
- ^[3] The 85 percent removal requirements apply at Discharge Point 001-San (except BOD₅). The requirements would also apply at Discharge Point 001-Ind (except CBOD₅) or if the Industrial Plant is modified to treat sanitary wastewater and, or, the inflow BOD₅ is greater than 45 mg/L. If the sanitary waste is routed through the industrial plant, compliance with effluent limitations will be based on flow weighted averages.
- ^[4] If the Discharger monitors pH continuously, pursuant to 40 CFR 401.17, the Discharger shall be in compliance with the pH limitation specified herein provided that both of the following conditions are satisfied: (i) the total time during which the pH values are outside the required range of pH values shall not exceed 7 hours and 26 minutes in any calendar month; and (ii) no individual excursion from the range of pH values shall exceed 60 minutes.

2. Discharges at Discharge Point No. 001 (as determined at Monitoring Locations EFF-001 as described in the MRP) shall comply with the following limitations.
 - a. **Enterococcus Bacteria:** The geometric mean of the enterococcus densities of all discharge samples collected within a calendar month shall not exceed 35 colony forming units/100 mL (CFU/100 mL.)
 - b. **Fecal Coliform Bacteria:** The geometric mean fecal coliform density in all effluent samples collected within a calendar month shall not exceed 200 colony forming units per 100 mL (CFU/100 mL); and the 90th percentile value of the last eleven samples shall not exceed 400 CFU/100 mL.
 - c. **Chlorine Residual:** Total chlorine residual at Discharge Point No. 002 (as determined at Monitoring Location EFF-002 as described in the MRP) shall not exceed 0.0 mg/L. The Discharger may elect to use continuous on-line monitoring systems for measuring flows, chlorine residual and sodium bisulfate (or other dechlorinating chemical) dosage (including a safety factor) and concentration to prove that chlorine residual exceedances are false positives. If convincing evidence is provided, Regional Water Board staff may conclude that these false positive chlorine residual exceedances are not violations of this limitation.

B. Toxic Substances Effluent Limitations

Discharges at Discharge Point No. 001 (as determined at Monitoring Location EFF-001 as described in the MRP) shall comply with the following limitations. The total recoverable cyanide limitation may apply at Discharge Point No. 002 (as determined at Monitoring Location EFF-002 as described in the MRP) instead of Discharge Point No. 001.

Table 7. Toxic Pollutant Effluent Limitations

Parameter	Units	Effluent Limitations ^[1]	
		Average Monthly	Maximum Daily
Copper	µg/L	42	84
Selenium	µg/L	2.9	8.8
Zinc	µg/L	350	910
Dioxin-TEQ	µg/L	1.4 x 10 ⁻⁸	2.8 x 10 ⁻⁸
Total Ammonia	mg/L	120	310
Cyanide, Total Recoverable	µg/L	20	44

Footnote

^[1] All limitations for metals are expressed as total recoverable metals.

C. Whole Effluent Toxicity

1. Whole Effluent Acute Toxicity

a. Discharges at Discharge Point No. 001 shall meet the following limits for acute toxicity (bioassays shall be conducted in compliance with MRP section V.A)

- (1) An eleven (11) – sample median value of not less than 90 percent survival; and
- (2) An eleven (11) – sample 90th percentile value of not less than 70 percent survival.

b. These acute toxicity limitations are further defined as follows:

- (1) **11-sample median.** A bioassay test showing survival of less than 90 percent represents a violation of this effluent limit, if five or more of the past ten or less bioassay tests show less than 90 percent survival.
- (2) **11-sample 90th percentile.** A bioassay test showing survival of less than 70 percent represents a violation of this effluent limit, if one or more of the past ten or less bioassay tests show less than 70 percent survival.

c. Bioassays shall be performed using the most up-to-date USEPA protocols and species as specified in MRP section V.A. Bioassays shall be conducted in compliance with Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms, currently 5th Edition (EPA-821-R-02-012). If these protocols prove unworkable, the Executive Officer and the Environmental Laboratory Accreditation Program may grant exceptions in writing upon the Discharger’s request with justification.

d. If the Discharger can demonstrate that ammonia causes acute toxicity in excess of the acute toxicity limitations in this Order and that the ammonia in the discharge complies with the ammonia effluent limitations in this Order, then such toxicity will not constitute a violation of the effluent limitations for whole effluent acute toxicity.

2. Whole Effluent Chronic Toxicity

The discharge shall not contain chronic toxicity at a level that would cause or contribute to toxicity in the receiving water. Chronic toxicity is a detrimental biological effect of growth rate, reproduction, fertilization success, larval development, or any other relevant measure of the health of an organism population or community. Compliance with this limit shall be measured at Monitoring Location EFF-001 as described in the MRP using indicator organisms and toxicity tests.

V. RECEIVING WATER LIMITATIONS

A. The discharge of waste shall not cause the following conditions to exist in waters of the State:

1. Floating, suspended, or deposited macroscopic particulate matter or foams;
2. Bottom deposits or aquatic growths to the extent that such deposits or growths cause nuisance or adversely affect beneficial uses;
3. Alteration of temperature, turbidity, or apparent color beyond present natural background levels;
4. Visible, floating, suspended, or deposited oil or other products of petroleum origin; and
5. Toxic or other deleterious substances to be present in concentrations or quantities that cause deleterious effects on wildlife, waterfowl, or other aquatic biota, or that render any of these unfit for human consumption, either at levels created in the receiving waters or as a result of biological concentration.

B. The discharge of waste shall not cause the following limits to be exceeded in waters of the State within 1 foot of the water surface:

1. Dissolved Oxygen 5.0 mg/L, minimum

Furthermore, the median dissolved oxygen concentration for any three consecutive months shall not be less than 80% of the dissolved oxygen content at saturation. When natural factors cause concentrations less than that specified above, the discharge shall not cause further reduction in ambient dissolved oxygen concentrations.

2. Dissolved Sulfide Natural background levels

3. pH The pH shall not be depressed below 6.5 or raised above 8.5. The discharge shall not cause changes greater than 0.5 pH units in normal ambient pH levels.

4. Nutrients Waters shall not contain biostimulatory substances in concentrations that promote aquatic growths to the extent that

such growths cause nuisance or adversely affect beneficial uses.

- C. The discharge shall not cause a violation of any particular water quality standard for receiving waters adopted by the Regional Water Board or the State Water Board as required by the CWA and regulations adopted thereunder. If more stringent applicable water quality standards are promulgated or approved pursuant to CWA section 303, or amendments thereto, the Regional Water Board may revise and modify this Order in accordance with such more stringent standards.

VI. PROVISIONS

A. Standard Provisions

1. **Federal Standard Provisions.** The Discharger shall comply with the Federal Standard Provisions in Attachment D.
2. **Regional Standard Provisions.** The Discharger shall comply with all applicable items of the Regional Standard Provisions, and Monitoring and Reporting Requirements (Supplement to Attachment D) for NPDES Wastewater Discharge Permits (Attachment G), including amendments thereto.

B. Monitoring and Reporting Program (MRP) Requirements

The Discharger shall comply with the MRP and future revisions thereto, including applicable sampling and reporting requirements in the standard provisions listed in Provision VI.A above.

C. Special Provisions

1. Reopener Provisions

The Regional Water Board may modify or reopen this Order prior to its expiration date in any of the following circumstances as allowed by law:

- a. If present or future investigations demonstrate that the discharges governed by this Order have or will have a reasonable potential to cause or contribute to, or will cease to have, adverse impacts on water quality or beneficial uses of the receiving waters.
- b. If new or revised WQOs or total maximum daily loads (TMDLs) come into effect for the San Francisco Bay Estuary and contiguous water bodies (whether Statewide, regional, or site-specific). In such cases, effluent limitations in this Order will be modified as necessary to reflect updated WQOs and waste load allocations in TMDLs. Adoption of effluent limitations contained in this Order is not intended to restrict in any way future modifications based on legally adopted WQOs or TMDLs, or as otherwise permitted under federal regulations governing NPDES permit modifications.
- c. If translator, dilution, or other water quality studies provide a basis for determining that a permit condition should be modified.

- d. If State Water Board precedential decisions, new policies, new laws, or new regulations on chronic toxicity or total chlorine residual become available.
- e. If an administrative or judicial decision on a separate NPDES permit or WDRs addresses requirements similar to this discharge.
- f. If the Discharger requests adjustments in effluent limitations due to the implementation of stormwater diversion pursuant to the Municipal Regional Stormwater Permit (CAS612008) for redirection dry weather and first flush discharges from the storm drain system to the sanitary sewer system as a stormwater pollutant control strategy.
- g. Or as otherwise authorized by law.

The Discharger may request permit modification based on any of the circumstances described above. With any such request, the Discharger shall include antidegradation and anti-backsliding analyses. The Discharger may request permit modification based on any of the circumstances described above. With any such request, the Discharger shall include antidegradation and anti-backsliding analyses. With the consent of the Discharger, the Executive Officer may make minor modifications to this Order for the purposes set forth in 40 CFR 122.63.

2. Effluent Characterization Study and Report

a. Study Elements

The Discharger shall continue to characterize and evaluate discharge from the following discharge points to verify that the “no” or “cannot determine” reasonable potential analysis conclusions of this Order remain valid and to inform the next permit reissuance. The Discharger shall collect representative samples of the discharges as set forth below, with locations as defined in the MRP:

<u>Discharge Point</u>	<u>Monitoring Station</u>	<u>Minimum Frequency</u>
001	EFF-001	Once per calendar year

The samples shall be analyzed for the priority pollutants listed in Attachment G, Table C, except for those priority pollutants with effluent limitations where the MRP already requires monitoring. Compliance with this requirement shall be achieved in accordance with the specifications of Attachment G sections III.A.1 and III.A.2.

The Discharger shall evaluate on an annual basis if concentrations of any of these priority pollutants significantly increase over past performance. The Discharger shall investigate the cause of such increase. The investigation may include, but need not be limited to, an increase in monitoring frequency, monitoring of internal process streams, and monitoring of influent sources. The Discharger shall establish remedial measures addressing any increase resulting in Reasonable Potential to cause or contribute to an excursion above applicable water quality objectives. This requirement may be satisfied through

identification of the constituent as a “pollutant of concern” in the Discharger’s Pollutant Minimization Program, described in Provision VI.C.3.

b. Reporting Requirements

(1) Routine Reporting

The Discharger shall, within 30 days of receipt of analytical results, report in the transmittal letter for the appropriate monthly self-monitoring report the following:

- (a) Indication that a sample or samples for this characterization study was or were collected; and
- (c) Identity of priority pollutants detected at or above applicable water quality criteria (see Fact Sheet Table F-10 for the criteria), together with the detected concentrations of those pollutants.

(2) Annual Reporting

The Discharger shall provide a summary of the annual data evaluation and source investigation in the annual self-monitoring report.

(3) Final Report

The Discharger shall submit a final report that presents all these data to the Regional Water Board with the application for permit reissuance (no later than 180 days prior to the Order expiration date.)

3. Best Management Practices and Pollutant Minimization Program

- a.** The Discharger shall continue to improve, in a manner acceptable to the Executive Officer, its existing Pollutant Minimization Program to promote minimization of pollutant loadings to the treatment plant and therefore to the receiving waters.
- b.** The Discharger shall submit an annual report, acceptable to the Executive Officer, no later than February 28 of each calendar year. Each annual report shall include at least the following information:
 - (1) *A brief description of the treatment plant, treatment plant processes and service area.*
 - (2) *A discussion of the current pollutants of concern.* Periodically, the Discharger shall analyze its own situation to determine which pollutants are currently a problem and which pollutants may be potential future problems. This discussion shall include the reasons for choosing the pollutants.

- (3) *Identification of sources for the pollutants of concern.* This discussion shall include how the Discharger intends to estimate and identify sources of the pollutants. The Discharger shall also identify sources or potential sources not directly within the ability or authority of the Discharger to control, such as pollutants in the potable water supply and air deposition.
- (4) *Identification of tasks to reduce the sources of the pollutants of concern.* This discussion shall identify and prioritize tasks to address the Discharger's pollutants of concern. The Discharger may implement the tasks by itself or participate in group, regional, or national tasks that will address its pollutants of concern. The Discharger is strongly encouraged to participate in group, regional, or national tasks that will address its pollutants of concern whenever it is efficient and appropriate to do so. A time line shall be included for the implementation of each task.
- (5) *Outreach to employees.* The Discharger shall inform employees about the pollutants of concern, potential sources, and how they might be able to help reduce the discharge of these pollutants of concern into the treatment facilities. The Discharger may provide a forum for employees to provide input.
- (6) *Continuation of Airport User Outreach Program.* The Discharger shall prepare an airport user outreach program to communicate pollution prevention to its service area. Outreach may include participation in existing airport events. The Discharger shall coordinate with other agencies as appropriate.
- (7) *Discussion of criteria used to measure Pollutant Minimization Program and task effectiveness.* The Discharger shall establish criteria to evaluate the effectiveness of its Pollutant Minimization Program. This section shall discuss the specific criteria used to measure the effectiveness of each of the tasks in sections VI.C.3.b(3), (4), (5), and (6).
- (8) *Documentation of efforts and progress.* This discussion shall detail all of the Discharger's Pollutant Minimization Program activities during the reporting year.
- (9) *Evaluation of Pollutant Minimization Program and task effectiveness.* This Discharger shall use the criteria established in section VI.C.3.b.(7) to evaluate the Program's and tasks' effectiveness.
- (10) *Identification of specific tasks and time schedules for future efforts.* Based on the evaluation, the Discharger shall detail how it intends to continue or change its tasks in order to more effectively reduce the

amount of pollutants to the treatment plant, and subsequently in its effluent.

c. Pollutant Minimization Program for Pollutants with Effluent Limitations

The Discharger shall develop and conduct a Pollutant Minimization Program as further described below when there is evidence that a priority pollutant is present in the effluent above an effluent limitation (e.g., sample results reported as DNQ when the effluent limitation is less than the MDL, sample results from analytical methods more sensitive than those methods required by this Order, presence of whole effluent toxicity, health advisories for fish consumption, results of benthic or aquatic organism tissue sampling) and either:

- (1) A sample result is reported as DNQ and the effluent limitation is less than the RL; or
- (2) A sample result is reported as ND and the effluent limitation is less than the MDL, using SIP definitions.

d. Pollutant Minimization Program Submittals for Pollutants with Effluent Limitations

If triggered by the reasons in section VI.C.3.c, above, the Discharger's Pollutant Minimization Program shall include, but not be limited to, the following actions and submittals acceptable to the Regional Water Board:

- (1) Annual review and semi-annual monitoring of potential sources of the reportable priority pollutants, which may include fish tissue monitoring and other bio-uptake sampling, or alternative measures approved by the Executive Officer when it is demonstrated that source monitoring is unlikely to produce useful analytical data;
- (2) Quarterly monitoring for the reportable priority pollutants in the influent to the wastewater treatment system, or an alternative measures approved by the Executive Officer, when it is demonstrated that influent monitoring is unlikely to produce useful analytical data;
- (3) Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable priority pollutants in the effluent at or below the effluent limitation;
- (4) Implementation of appropriate cost-effective control measures for the reportable priority pollutants, consistent with the control strategy; and
- (5) Annual report required by section VI.C.3.b above, shall specifically address the following items:
 - (a) All Pollutant Minimization Program monitoring results for the previous year;

- (b) List of potential sources of the reportable priority pollutants;
- (c) Summary of all actions undertaken pursuant to the control strategy; and
- (d) Description of actions to be taken in the following year.

e. Stormwater Pollution Prevention Plan

- (1) The Discharger shall implement control measures and best management practices (BMPs) to reduce pollutants in stormwater discharges to the maximum extent practicable. Stormwater Pollution Prevention Plans (SWPPPs) serve as the framework for identification, assignment and implementation of BMPs. The Discharger shall review and update its SWPPP to include any appropriate revisions, modifications, and improvements to reduce pollutants in stormwater discharges to the maximum extent practicable. The Discharger shall incorporate newly developed or updated BMPs into the SWPPP, and adhere to implementation of the revised control measures.

The Discharger shall submit an updated SWPPP within 90 days of the effective date of this Order, and annually thereafter along with the Pollution Prevention Plan due February 28 each year. Within 30 days of a change in operation that could substantially affect the quality of the stormwater discharged, the Discharger shall submit an updated SWPPP. In any update of the SWPPP, the Discharger shall (a) include a current map for the Facility that address the requirements of 40 CFR 122.26 (c)(1)(i)(A); (b) identify on a map the areas that contribute runoff to the permitted discharge points; (c) describe the activities in each area and the potential for contamination of stormwater runoff and discharge of hazardous material; and (d) address the feasibility for containment and/or treatment of the stormwater.

BMPs define the level of implementation necessary to demonstrate the reduction of pollutants in stormwater to the maximum extent practicable.

The SWPPP shall identify site-specific BMPs for minimizing contamination of stormwater runoff, and for preventing contaminated stormwater discharging directly to San Francisco Bay. Further, the SWPPP shall include site-specific plans and procedures to prevent hazardous material from being discharged. The updated SWPPPs shall be consistent with the requirements of 40 CFR 125, Subpart K The Discharger shall perform a risk assessment of each area it identifies to determine the potential for hazardous material discharge to surface waters.

- (2) The Discharger shall update its SWPPPs to implement the requirements specified in Attachment G, section J. In addition, the Discharger shall continue to update and maintain its SWPPPs to include the following seven minimum control measures and measurable goals that address the following program elements:
 - (a) Tenant and construction contractor education and outreach,
 - (b) Tenant and construction contractor participation and involvement,

- (c) Illicit discharge detection and elimination,
- (d) Construction site runoff control,
- (e) Post-construction runoff control,
- (f) Pollution prevention and good housekeeping, and
- (g) Maintenance of Airport facilities (including street and lot sweeping and storm drain inlet inspection and cleanup).

The Discharger will continue to implement the seven minimum control measures listed above and develop new or improved BMPs to achieve the reduction of pollutants in stormwater discharges to the maximum extent practicable. This Order authorizes the discharge of industrial or construction stormwater prior to update of the SWPPPs if they are in accordance with the Discharger's current SWPPPs. After the SWPPPs are updated, industrial and construction stormwater shall be discharged in accordance with the updated SWPPPs.

4. Special Provisions for POTWs

a. Biosolids Management Practices

- (1) All biosolids shall be managed, reused, or disposed of through recognized and approved methods, in accordance with 40 CFR Part 503.
- (2) Biosolids treatment, storage, and disposal or reuse shall not create a nuisance, such as objectionable odors or flies, or result in groundwater contamination.
- (3) The biosolids treatment and storage site shall have facilities adequate to divert surface runoff from adjacent areas, to protect site boundaries from erosion, and to prevent any conditions that would cause drainage from the materials in temporary storage. Adequate protection is defined as protection from at least a 100-year storm and protection from the highest possible tidal stage that may occur.
- (4) Biosolids disposed of in a municipal solid waste landfill shall meet the requirements of 40 CFR Part 258. In the annual self-monitoring report, the Discharger shall include the amount of biosolids disposed and the landfill to which it was sent.
- (5) This Order does not authorize permanent on-site biosolids storage or disposal. A Report of Waste Discharge shall be filed and the site brought into compliance with all applicable regulations prior to commencement of any such activity.

b. Sanitary Sewer Overflows and Sewer System Management Plan

The Discharger's collection system, including force mains, is part of the facility subject to this Order. As such, the Discharger shall properly operate and maintain its collection

system (Attachment D, section I.D). The Discharger shall report any noncompliance (Attachment D, sections V.E.1 and V.E.2) and mitigate any discharge from the Discharger's force mains in violation of this Order (Attachment D, section I.C).

The General Waste Discharge Requirements for Collection System Agencies (General Collection System WDRs), Order No. 2006-0003 DWQ, has requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. While the Discharger must comply with both the General Collection System WDRs and this Order, the General Collection System WDRs more clearly and specifically stipulate requirements for operation and maintenance, and for reporting and mitigating sanitary sewer overflows.

Implementation of the General Collection System WDRs requirements for proper operation and maintenance and mitigation of sanitary sewer overflows will satisfy the corresponding federal NPDES requirements specified in Attachment D (as supplemented by Attachment G) of this Order. Following notification and reporting requirements in the General Collection System WDRs will satisfy NPDES reporting requirements specified in Attachment D (as supplemented by Attachment G) of the Order for sanitary sewer overflows from the collection system upstream of the Plant boundaries. Attachments D and G of this Order specify reporting requirements for unauthorized discharges from anywhere within the Plant downstream of the Plant boundaries.

5. Other Special Provisions

a. Copper Action Plan

The Discharger shall implement pretreatment, source control, and pollution prevention for copper in accordance with the following tasks and time schedule.

Table 8. Copper Action Plan

Task	Compliance Date
<p>1. Review Potential Copper Sources The Discharger shall submit an inventory of potential copper sources to the plant.</p>	<p><i>Completed June 4, 2009</i></p>
<p>2. Implement Copper Control Program The Discharger shall submit a plan for and begin implementation of a program to reduce copper sources identified in Task 1. The plan shall consist, at a minimum, of the following elements:</p> <ul style="list-style-type: none"> a. Provide education to maintenance staff on roles in reducing corrosion. b. If corrosion is determined to be a significant copper source, work cooperatively with local water purveyors to reduce and control water corrosivity, as appropriate, and ensure that plumbing contractors implement best management practices to reduce corrosion in pipes. c. Educate plumbers, designers, and maintenance contractors to encourage best management practices that minimize copper discharges. 	<p>With annual pollution prevention report due February 28, 2014</p>

<p>3. Implement Additional Measures If the Regional Water Board notifies the Discharger that the three-year rolling mean dissolved copper concentration of the receiving water exceeds 2.2 µg/L, then within 90 days of the notification, the Discharger shall evaluate its effluent copper concentration trend, and if it is increasing, develop and begin implementation of additional measures to control copper discharges. The Discharger shall report on the progress and effectiveness of actions taken, together with a schedule for actions to be taken in the next 12 months.</p>	<p>With annual pollution prevention report due February 28 following 90 days after notification</p>
<p>4. Undertake Studies to Reduce Copper Pollutant Impact Uncertainties The Discharger shall submit an updated study plan and schedule to conduct, or cause to be conducted, technical studies to investigate possible copper sediment toxicity and technical studies to investigate sublethal effects on salmonids. Specifically, the Discharger shall include the manner in which the above will be accomplished and describe the studies to be performed with an implementation schedule. To satisfy this requirement, dischargers may collaborate and conduct these studies as a group.</p>	<p><i>Completed January 6, 2011</i></p>
<p>5. Report Status of Copper Control Program The Discharger shall submit an annual report documenting copper control program implementation and addressing the effectiveness of the actions taken, including any additional copper controls required by Task 3, above, together with a schedule for actions to be taken in the next 12 months. Additionally, the Discharger shall report the findings and results of the studies completed, planned, or in progress under Task 4. Regarding the Task 4 studies, dischargers may collaborate and provide this information in a single report to satisfy this requirement for an entire group.</p>	<p>With annual pollution prevention report due February 28 each year</p>

b. Cyanide Action Plan

The Discharger shall implement monitoring and surveillance, pretreatment, source control and pollution prevention for cyanide in accordance with the following tasks and time schedule.

Table 9. Cyanide Action Plan

Task	Compliance Date
<p>1. Review Potential Cyanide Sources The Discharger shall submit an inventory of potential cyanide sources to the treatment plant. If no cyanide sources are identified, Tasks 2 and 3 are not required, unless the Discharger receives a request to discharge detectable levels of cyanide to the sewer. If so, the Discharger shall notify the Executive Officer and implement Tasks 2 and 3.</p>	<p><i>Completed November 3, 2008</i></p>
<p>2. Implement Cyanide Control Program The Discharger shall submit a plan and begin implementation of a program to minimize cyanide discharges to its treatment plant consisting, at a minimum, of the following elements:</p> <ul style="list-style-type: none"> a. Inspect each potential source to assess the need to include that contributing source in the control program. b. Inspect contributing sources included in the control program annually. Inspection elements may be based on USEPA guidance, such as Industrial User Inspection and Sampling Manual for POTWs (EPA 831-B-94-01). c. Develop and distribute educational materials to contributing sources and potential contributing sources regarding the need to prevent cyanide discharges. d. Prepare an emergency monitoring and response plan to be implemented if a significant cyanide discharge occurs. <p>For purposes of this Order, a “significant cyanide discharge” is occurring if cyanide is</p>	<p>With annual pollution prevention report due February 28, 2014</p>

Task	Compliance Date
found in the plant’s influent above 10 µg/L	
<p>3. Implement Additional Cyanide Control Measures If the Regional Water Board notifies the Discharger that ambient monitoring shows cyanide concentrations are 1.0 µg/L or higher in the main body of San Francisco Bay, then within 90 days of the notification, the Discharger shall commence actions to identify and abate cyanide sources responsible for the elevated ambient concentrations, and shall report on the progress and effectiveness of actions taken, together with a schedule for actions to be taken in the next 12 months.</p>	<p>With next annual pollution prevention report due February 28 (at least 90 days following notification)</p>
<p>4. Report Status of Cyanide Control Program The Discharger shall submit an annual report documenting cyanide control program implementation and addressing the effectiveness of actions taken, including any additional cyanide controls required by Task 3, above, together with a schedule for actions to be taken in the next 12 months.</p>	<p>With annual pollution prevention report due February 28 each year</p>

c. De-icing Operations

Consistent with the requirements of 40 CFR 449.10, the Discharger shall certify annually that it does not use airfield deicing products containing urea. This certification will be due February 1 each year as part of the annual self-monitoring report required in Attachment E.

VII.COMPLIANCE DETERMINATION

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in Attachment A—Definitions, the MRP, Fact Sheet section VI, and the Regional Standard Provisions. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ)

Also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n \quad \text{where: } \Sigma x \text{ is the sum of the measured ambient water concentrations, and } n \text{ is the number of samples.}$$

Average Monthly Effluent Limitation (AMEL)

The highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL)

The highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Bioaccumulative

Those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic

Carcinogenic pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV)

CV is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge

Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in this Order), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ)

DNQ are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA)

ECA is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in USEPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of San Francisco Bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration

The estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters include, but are not limited to, the Sacramento-San Joaquin Delta, as defined in California Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters

All surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation

The highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation

The lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL)

The highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median

The middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL)

MDL is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations (40 CFR), Part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML)

ML is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND)

Sample results less than the laboratory's MDL.

Ocean Waters

The territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Persistent Pollutants

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP)

PMP means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative

priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to California Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in California Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Regional Water Board.

Reporting Level (RL)

RL is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Satellite Collection System

The portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water

Any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ)

Standard Deviation is a measure of variability that is calculated as follows:

$$\sigma = (\sum[(x - \mu)^2]/(n - 1))^{0.5}$$

where:

x is the observed value;

μ is the arithmetic mean of the observed values; and

n is the number of samples.

Toxicity Reduction Evaluation (TRE)

TRE is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and

maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

ATTACHMENT B – FACILITY MAP

Figure B-1. Facility Location Drawing




Figure B-2. Facility Location Map




Figure B-3. Facility and Discharge Location Map



Figure B-4. Stormwater Drainage Map




Figure B-5. Stormwater Outfall Locations

Stormwater Outfall Locations




Figure B-6. Sanitary Process Map





Figure B-7. Industrial Process Map



Figure B-8. Influent and Effluent Locations



ATTACHMENT C – PROCESS FLOW DIAGRAM

Figure C-1. Sanitary Plant Process Flow Diagram





Figure C-2. Industrial Plant Process Flow Diagram



ATTACHMENT D –STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 CFR 122.41(a)).
2. The Discharger shall comply with effluent standards or prohibitions established under section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 CFR 122.41(a)(1)).

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 CFR 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 CFR 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order (40 CFR 122.41(e)).

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 CFR 122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 CFR 122.5(c).)

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative), upon the presentation of credentials and other documents, as may be required by law, to (40 CFR 122.41(i); Water Code, § 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 CFR 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 CFR 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 CFR 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (40 CFR 122.41(i)(4).)

G. Bypass

1. Definitions
 - a. “Bypass” means the intentional diversion of waste streams from any portion of a treatment facility. (40 CFR 122.41(m)(1)(i).)
 - b. “Severe property damage” means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 CFR 122.41(m)(1)(ii).)
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 CFR 122.41(m)(2).)
3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 CFR 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 CFR 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment

should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 CFR 122.41(m)(4)(i)(B)); and

- c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 CFR 122.41(m)(4)(i)(C).)
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 CFR 122.41(m)(4)(ii).)
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 CFR 122.41(m)(3)(i).)
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 CFR 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 CFR 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 CFR 122.41(n)(2).)
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 CFR 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 CFR 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 CFR 122.41(n)(3)(ii));
 - c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 CFR 122.41(n)(3)(iii)); and

- d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 CFR 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 CFR 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 CFR 122.41(f).)

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 CFR 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of this Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code. (40 CFR 122.41(l)(3); 122.61.)

III. STANDARD PROVISIONS – MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 CFR 122.41(j)(1).)
- B. Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order. (40 CFR 122.41(j)(4); 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A. Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 CFR 122.41(j)(2).)
- B. Records of monitoring information shall include:

1. The date, exact place, and time of sampling or measurements (40 CFR 122.41(j)(3)(i));
 2. The individual(s) who performed the sampling or measurements (40 CFR 122.41(j)(3)(ii));
 3. The date(s) analyses were performed (40 CFR 122.41(j)(3)(iii));
 4. The individual(s) who performed the analyses (40 CFR 122.41(j)(3)(iv));
 5. The analytical techniques or methods used (40 CFR 122.41(j)(3)(v)); and
 6. The results of such analyses. (40 CFR 122.41(j)(3)(vi).)
- C. Claims of confidentiality for the following information will be denied (40 CFR 122.7(b)):
1. The name and address of any permit applicant or Discharger (40 CFR 122.7(b)(1)); and
 2. Permit applications and attachments, permits and effluent data. (40 CFR 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 CFR 122.41(h); Water Code, § 13267.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 CFR 122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 CFR 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 CFR 122.22(b)(1));

- b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 CFR 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 CFR 122.22(b)(3).)
4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 CFR 122.22(c).)
 5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 CFR 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 CFR 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 CFR 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board. (40 CFR 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 CFR 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 CFR 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 CFR 122.41(l)(6)(i).)
2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 CFR 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 CFR 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 CFR 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 CFR 122.41(l)(6)(iii).)

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 CFR 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 CFR 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 CFR 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 CFR 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements. (40 CFR 122.41(1)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 CFR 122.41(1)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 CFR 122.41(1)(8).)

VI. STANDARD PROVISIONS – ENFORCEMENT

- A. The Regional Water Board is authorized to enforce the terms of this Order under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 CFR 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 CFR 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of this Order. (40 CFR 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 CFR 122.42(b)(3).)

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Contents

I. General Monitoring Provisions	E-2
II. Monitoring Locations	E-2
III. Influent Monitoring Requirements	E-3
IV. Effluent Monitoring Requirements	E-4
V. Whole Effluent Toxicity Testing Requirements	E-5
A. Whole Effluent Acute Toxicity	E-5
B. Whole Effluent Chronic Toxicity	E-6
VI. STORMWATER monitoring requirements	E-9
VII. Receiving Water Monitoring Requirements.....	E-10
VIII. Reporting Requirements	E-10
A. General Monitoring and Reporting Requirements	E-10
B. Self Monitoring Reports (SMRs)	E-10
C. Discharge Monitoring Reports	E-12
D. Modifications to Attachment G	E-13

Tables

Table E-1. Monitoring Station Locations	E-2
Table E-2. Influent Monitoring at INF-001-San and INF-001-Ind.....	E-3
Table E-3. Effluent Monitoring at EFF-001-San and EFF-001-Ind.....	E-4
Table E-4. Effluent Monitoring at EFF-001	E-4
Table E-5. Effluent Monitoring at EFF-002.....	E-5
Table E-6. Stormwater Monitoring at EFF-003 through EFF-010, and EFF-013	E-9
Table E-7. SMR Reporting for CIWQS.....	E-11
Table E-8. Monitoring Periods and Reporting Schedule	E-12

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

National Pollutant Discharge Elimination System (NPDES) regulations at 40 CFR 122.48 require that all NPDES permits specify monitoring and reporting requirements. California Water Code (CWC) sections 13267 and 13383 also authorize the Regional Water Quality Control Board (hereinafter Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements that implement the federal and State regulations.

I. GENERAL MONITORING PROVISIONS

- A. The Discharger shall comply with this MRP. The Executive Officer may amend this MRP pursuant to 40 CFR 122.62, 122.63, and 124.5. If any discrepancies exist between this MRP and the Regional Standard Provisions (Attachment G), this MRP prevails.
- B. The Discharger shall conduct all monitoring in accordance with Attachment D, section III, as supplemented by Attachment G of this Order. Equivalent test methods must be more sensitive than those specified in 40 CFR 136 and must be specified in the permit.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order.

Table E-1. Monitoring Station Locations

Type of Sampling Location	Monitoring Location Name	Monitoring Location Description
Sanitary Plant Influent Station	INF-001-San	At any point in the Sanitary Plant upstream of the primary sedimentation basins at which all waste tributary to the treatment system is present, and preceding any phase of treatment.
Industrial Plant Influent Station	INF-001-Ind	At any point in the Industrial Plant upstream of the flocculation tank at which as waste tributary to the treatment system is present, and preceding any phase of treatment.
Sanitary Plant Effluent Station	EFF-001-San	At any point in the Sanitary Plant after disinfection and prior to combining with effluent from the Industrial Plant.
Industrial Plant Effluent Station	EFF-001-Ind	At any point in the Industrial Plant after disinfection and prior to combining with effluent from the Sanitary Plant.
Combined Plant Effluent Station	EFF-001	At any point after treated effluent from the Sanitary Plant and Industrial Plant are prior to discharge to the North Bayside System Unit pipeline.
North Bayside Plant Effluent Station	EFF-002	At any point in the North Bayside System Unit combined outfall after.

Type of Sampling Location	Monitoring Location Name	Monitoring Location Description
Stormwater	EFF-003	At the point of discharge from Pump Station No. 1.
Stormwater	EFF-004	At the point of discharge from Pump Station No. 2.
Stormwater	EFF-005	At the point of discharge from Pump Station No. 1-A.
Stormwater	EFF-006	At the point of discharge from Pump Station No. 1-B.
Stormwater	EFF-007	At the point of discharge from Pump Station No. 1-C.
Stormwater	EFF-008	At the point of discharge from Pump Station No. 17.
Stormwater	EFF-009	At the point of discharge from Pump Station No. 18.
Stormwater	EFF-010	At the point of discharge from the western area of the North Cargo Facility.
Stormwater	EFF-013	At the point of discharge from Pump Station No. 6.

III. INFLUENT MONITORING REQUIREMENTS

The Discharger shall monitor influent to the Sanitary Plant at Monitoring Location INF-001-San and influent to the Industrial Plant at Monitoring Location INF-001-Ind as follows:

Table E-2. Influent Monitoring at INF-001-San and INF-001-Ind

Parameter	Units ^[1]	Sample Type ^[1]	Minimum Sampling Frequency ^[2]
Flow ^[3]	Million Gallons / Day (MGD)	Continuous	Continuous/D
Carbonaceous Biochemical Oxygen Demand 5-day at 20°C (CBOD ₅) (<i>Sanitary Plant</i>) ^[4]	mg/L	24-hour composite (C-24)	3/Week
Biochemical Oxygen Demand 5-day at 20°C (BOD ₅) (<i>Industrial Plant</i>) ^[5]	Mg/L	24-hour composite (C-24)	3/Week
Total Suspended Solids (TSS)	mg/L	C-24	3/Week
Cyanide	µg/L	Grab	2/Year

Footnotes

^[1] Sampling Type Abbreviations:

- Continuous/D = measured continuously, and recorded and reported daily
- C-24 = 24-hour composite
- Flow through = continuously pumped sample during duration of toxicity test

^[2] Sampling Frequency:

- Continuous/D = measured continuously, and recorded and reported daily
- 1/Week = Once per week
- 2/Week = Twice per week
- 3/Week = Three times per week
- 5/Week = Five times per week
- 1/Day = Once per day
- 2/Year = Twice per year

^[3] Flows shall be monitored continuously and the following shall be reported in monthly self-monitoring reports:

- a. Daily average flow rate (MGD).
- b. Daily total flow volume (MG).
- c. Monthly average flow rate (MGD).
- d. Monthly total flow volume (MG).
- e. Average daily maximum and average daily minimum flow rates (MGD) in a month.

^[4] CBOD₅ monitoring is required only at Monitoring Location INF-001-San.

^[5] BOD₅ monitoring is required only at Monitoring Location INF-001-Ind.

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Locations EFF-001-San and EFF-001-Ind

The Discharger shall monitor effluent at Monitoring Location EFF-001-San and effluent at Monitoring Location EFF-001-Ind as follows:

Table E-3. Effluent Monitoring at EFF-001-San and EFF-001-Ind

Parameter	Units	Sample Type ^[1]	Minimum Sampling Frequency ^[2]
Flow ^[3]	MGD	Continuous	Continuous/D
CBOD ₅ (<i>Sanitary Plant</i>) ^[4, 6]	mg/L	C-24	3/Week
BOD ₅ (<i>Industrial Plant</i>) ^[5]	mg/L	C-24	3/Week
TSS ^[6]	mg/L	C-24	3/Week
Oil and Grease ^[7]	mg/L	Grab	2/Month
pH ^[8]	Standard Units	Grab	3/Week
Standard Observations ^[9]	--	Visual Observation	1/Day

Footnotes

- ^[1-3] See Table E-2 footnotes
- ^[4] CBOD₅ monitoring is required only at Monitoring Location EFF-001-San.
- ^[5] BOD₅ monitoring is required only at Monitoring Location EFF-001-Ind.
- ^[6] The percent removal for CBOD and TSS shall be reported for each calendar month. The percent removal shall be reported for Monitoring Location EFF-001-Ind only when the Discharger treats sanitary wastewater at the Industrial Plant, in which case the percent removal calculation shall involve only those data collected while sanitary wastewater is treated.
- ^[7] Each oil & grease sampling event shall consist of a composite sample comprised of three grab samples taken at equal intervals during the sampling date, with each grab sample being collected in a glass container. Each glass container used for sample collection or mixing shall be thoroughly rinsed with solvent rinsings as soon as possible after use, and the solvent rinsings shall be added to the composite sample for extraction and analysis.
- ^[8] If pH is monitored continuously, the minimum and maximum pH values for each day shall be reported in monthly self-monitoring reports.
- ^[9] Observe wastewater effluent as described in Attachment G, section III.C.2.

B. Monitoring Location EFF-001

The Discharger shall monitor effluent at Monitoring Location EFF-001 as follows:

Table E-4. Effluent Monitoring at EFF-001

Parameter	Units	Sample Type ^[1]	Minimum Sampling Frequency ^[2]
Flow ^[3]	MGD	Continuous	Continuous/D
Total Ammonia as N	mg/L	Grab	1/Month
Fecal Coliform Bacteria	CFU ^[6] /100 mL	Grab	2/Week
Enterococcus Bacteria	Colonies/100 mL	Grab	1/Month
Acute Toxicity ^[4]	% Survival	Flow through	1/Month
Chronic Toxicity ^[4]	TUc	C-24	2/Year
Copper ^[5]	µg/L	C-24	1/Month
Selenium ^[5]	µg/L	C-24	1/Month

Parameter	Units	Sample Type ^[1]	Minimum Sampling Frequency ^[2]
Zinc ^[5]	µg/L	C-24	1/Month
Dioxin-TEQ ^[7]	µg/L	Grab	2/Year

Footnotes

^[1 to 3] See Tables E-2 footnotes

^[4] Bioassay tests shall be performed in accordance with sections V.A and V.B of this MRP. A combination of prechlorinated effluent flows from EFF-001-San and EFF-001-Ind may be mixed in proportion to the flows from the two plants.

^[5] As total recoverable metal.

^[6] Colony Forming Units.

C. Monitoring Location EFF-002

The Discharger shall monitor effluent at Monitoring Location EFF-002 as follows.

Table E-5. Effluent Monitoring at EFF-002

Parameter	Units	Sample Type ^[1]	Minimum Sampling Frequency ^[2]
Total Residual Chlorine ^[3]	mg/L	Continuous	Continuous/D
Cyanide, Total Recoverable ^[4]	µg/L	Grab	1/Month
Standard Observations ^[5]	--	Visual Observation	1/Day

Footnotes:

^[1 & 2] See Table E-2 footnotes

^[3] Effluent chlorine residual concentrations shall be monitored continuously or, at a minimum, every 2 hours. The Discharger shall report for each day the maximum residual chlorine concentration observed following dechlorination. However, if monitoring continuously, the Discharger shall report for each day the maximum residual chlorine concentration based on discrete readings from the continuous monitoring taken every 2 hours on the hour. The Discharger shall retain continuous monitoring readings for at least three years. The Regional Water Board reserves the right to use all other continuous monitoring data for discretionary enforcement. Total chlorine dosage (kg/day) shall be recorded daily.

^[4] Compliance may be demonstrated by measuring weak acid dissociable cyanide.

^[5] As practicable and as described in Attachment G, section III.C.2.

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

The Discharger shall monitor whole effluent acute and chronic toxicity as follows.

A. Whole Effluent Acute Toxicity

1. Compliance with the acute toxicity effluent limitations of this Order shall be evaluated by measuring survival of test organisms exposed to 96-hour continuous flow-through bioassays at Monitoring Location EFF-001 (prior to chlorination) or flow proportioned flows from Monitoring Locations EFF-001-San and EFF-001-Ind .
2. Test organisms shall be fathead minnow (*Pimephales promelas*). The Executive Officer may specify a more sensitive organism, or, if testing oa particular organism proves unworkable, the most sensitive organism available.
3. Bioassays shall be performed according to the most up-to-date protocols in 40 CFR 136, currently *Methods for Measuring the Acute Toxicity of Effluents and Receiving Water to Freshwater and Marine Organisms*, 5th Edition.

4. If the Discharger demonstrates that specific identifiable substances in the discharge are rapidly rendered harmless upon discharge to the receiving water, compliance with the acute toxicity limit may be determined after the test samples are adjusted to remove the influence of those substances. Written acknowledgement that the Executive Officer concurs with the Discharger's demonstration and that the adjustment will not remove the influence of other substances must be obtained prior to any other such adjustment.
5. Bioassay water monitoring shall include, on a daily basis, the following parameters: pH, dissolved oxygen, ammonia (if toxicity is observed), temperature, hardness, and alkalinity. These results shall be reported. If a violation of acute toxicity limitations occurs, the bioassay test shall be repeated with new fish as soon as practical and shall be repeated until a test fish survival rate of 90 percent or greater is observed. If the control fish survival rate is less than 90 percent, the bioassay test shall be restarted with new fish and shall continue as soon as practical until an acceptable test is completed (i.e., control fish survival rate is 90 percent or greater).

B. Whole Effluent Chronic Toxicity

1. Chronic Toxicity Monitoring Requirements

- a. **Sampling.** The Discharger shall collect 24-hour composite samples of the effluent for critical life stage toxicity testing as indicated below. For toxicity tests requiring renewals, 24-hour composite samples collected on consecutive days are required.
- b. **Test Species.** The test species shall be *Storngylocentrotus purpuratus* (purple sea urchin). or *Dendraster excentricus*(sand dollar) depending on the spawning season. The Discharger shall conduct a screening chronic toxicity test as described in Appendix E-1 following any significant change in the nature of the effluent. If there is no significant change, the Discharger shall conduct a screening test prior to application for permit reissuance. The most sensitive species shall be used thereafter for routine chronic toxicity monitoring. The Executive Officer may authorize a change to another test species if the Discharger's chronic toxicity screening data suggest that another test species is more sensitive to the discharge.
- c. **Frequency.** The frequency of routine and accelerated chronic toxicity monitoring shall be as specified below.
 - (1) Monitor routinely twice per year; once in the dry season, once in the wet season.
 - (2) Accelerate monitoring to *monthly* after exceeding a three-sample median of 10 TU_c¹ or a single sample maximum of 20 TU_c. Based on the TU_c results, the Executive Officer may specify a different frequency for accelerated monitoring to ensure that accelerated monitoring provides useful information..

¹ A TU_c equals 100 divided by the no observable effect level (NOEL). The NOEL is determined from IC₂₅, EC₂₅, or NOEC values. These terms, their usage, and other chronic toxicity monitoring program requirements are defined in the MRP (Attachment E).

- (3) Return to routine monitoring if accelerated monitoring does not exceed either trigger in (2), above.
- (4) If accelerated monitoring confirms consistent toxicity in excess of either trigger in (2), above, continue accelerated monitoring and initiate toxicity reduction evaluation (TRE) procedures in accordance with section V.B.3, below.
- (5) Return to routine monitoring after implementing appropriate elements of the TRE, and either the toxicity drops below both triggers in (2), above, or, based on the TRE results, the Executive Officer determines that accelerated monitoring would no longer provide useful information.

Monitoring conducted pursuant to a TRE shall satisfy the requirements for routine and accelerated monitoring while the TRE investigation is underway.

- d. Methodology.** Sample collection, handling, and preservation shall be in accordance with USEPA protocols. In addition, bioassays shall be conducted in compliance with the most recently promulgated test methods, as shown in Appendix E-1. These are *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Marine and Estuarine Organisms*, currently third Edition (EPA-821-R-02-014.) If these protocols prove unworkable the Executive Officer and the Environmental Laboratory Accreditation Program may grant exceptions in writing upon the Discharger's request with justification. If the Discharger demonstrates that specific identifiable substances in the discharge are rapidly rendered harmless upon discharge to the receiving water, compliance with the chronic toxicity limit may be determined after the test samples are adjusted to remove the influence of those substances. Written acknowledgement that the Executive Officer concurs with the Discharger's demonstration and that the adjustment will not remove the influence of other substances must be obtained prior to any other such adjustment.
- e. Dilution Series.** The Discharger shall conduct tests at, 20%, 10%, 5%, and 2.5%. The “%” represents percent effluent as discharged. The Discharger may use Zeolite to strip the ammonia or the biological buffer MOPS (3-(N-morpholino) propanesulfonic acid) to control pH drift and ammonia toxicity caused by increasing pH during the test.

2. Chronic Toxicity Reporting Requirements

- a.** Toxicity test results for the current reporting period shall be provided in the self monitoring report and shall include the following, at a minimum, for each test.
 - (1) Sample date
 - (2) Test initiation date
 - (3) Test species
 - (4) End point values for each dilution (e.g., number of young, growth rate, percent survival)
 - (5) The No Observable Effect Level (NOEL) shall equal the IC₂₅ or EC₂₅ (See MRP Appendix E-1). If the IC₂₅ or EC₂₅ cannot be statistically determined, the NOEL

shall equal the No Observable Effect Concentration (NOEC) derived using hypothesis testing. The NOEC is the maximum percent effluent concentration that causes no observable effect on test organisms, based on a critical life stage toxicity test.

- (6) IC₁₅, IC₂₅, IC₄₀, and IC₅₀ values (or EC₁₅, EC₂₅ ... etc.) as percent effluent
 - (7) TU_c values (100/NOEL, where NOEL = IC₂₅, EC₂₅, or NOEC as discussed in Appendix E-1
 - (8) Mean percent mortality (\pm s.d.) after 96 hours in 100% effluent (if applicable)
 - (9) IC₅₀ or EC₅₀ values for reference toxicant tests
 - (10) Available water quality measurements for each test (pH, dissolved oxygen, temperature, conductivity, hardness, salinity, ammonia)
- b. The results of the most recent three chronic toxicity test and the 3-sample median shall be provided in the self-monitoring report as TUc's.

3. Chronic Toxicity Reduction Evaluation (TRE)

- a. The Discharger shall prepare a generic TRE work plan within 90 days of the effective date of this Order to be ready to respond to toxicity events. The Discharger shall review and update the work plan as necessary so that it remains current and applicable to the discharge and discharge facilities.
- b. Within 30 days of exceeding either chronic toxicity trigger, the Discharger shall submit to the Regional Water Board a TRE work plan, which shall be the generic work plan revised as appropriate for this toxicity event after consideration of available discharge data.
- c. Within 30 days of the date of completion of the accelerated monitoring tests observed to exceed either trigger, the Discharger shall initiate a TRE in accordance with a TRE work plan that incorporates any and all comments from the Executive Officer.
- d. The TRE shall be specific to the discharge and be in accordance with current technical guidance and reference materials, including USEPA guidance materials. The TRE shall be conducted as a tiered evaluation process, such as summarized below:
 - (1) Tier 1 consists of basic data collection (routine and accelerated monitoring).
 - (2) Tier 2 consists of evaluation of optimization of the treatment process, including operation practices and in-plant process chemicals.
 - (3) Tier 3 consists of a toxicity identification evaluation (TIE).
 - (4) Tier 4 consists of evaluation of options for additional effluent treatment processes.
 - (5) Tier 5 consists of evaluation of options for modifications of in-plant treatment processes.

- (6) Tier 6 consists of implementation of selected toxicity control measures, and follow-up monitoring and confirmation of implementation success.
- e. The TRE may be ended at any stage if monitoring finds there is no longer consistent toxicity (complying with requirements of Provision IV.C.2 of the Order).
- f. The objective of the TIE shall be to identify the substance or combination of substances causing the observed toxicity. All reasonable efforts using currently available TIE methodologies shall be employed.
- g. As toxic substances are identified or characterized, the Discharger shall continue the TRE by determining the sources and evaluating alternative strategies for reducing or eliminating the substances from the discharge. The Discharger shall take all reasonable steps to reduce toxicity to levels consistent with chronic toxicity evaluation parameters.
- h. Many recommended TRE elements parallel required or recommended efforts of source control, pollution prevention, and stormwater control programs. TRE efforts should be coordinated with such efforts. To prevent duplication of efforts, evidence of complying with requirements or recommended efforts of such programs may be acceptable to comply with TRE requirements.
- i. The Regional Water Board recognizes that chronic toxicity may be episodic and identification of causes of and reduction of sources of chronic toxicity may not be successful in all cases. Consideration of enforcement action by the Regional Water Board will be based in part on the Discharger’s actions and efforts to identify and control or reduce sources of consistent toxicity.

VI. STORMWATER MONITORING REQUIREMENTS

The Discharger shall monitor stormwater discharges at Monitoring Locations EFF-003 through EFF-010, and EFF-013 as follows.

Table E-6. Stormwater Monitoring at EFF-003 through EFF-010, and EFF-013

Parameter	Units	Sample Type ^[1]	Minimum Sampling Frequency ^[2]
Flow	MGD	Estimate	2/Year
BOD ₅	mg/L	Grab	2/Year
TSS	mg/L	Grab	2/Year
Oil and Grease	mg/L	Grab	2/Year
pH	Standard units	Grab	2/Year
Fecal Coliform Bacteria	CFU/100ml	Grab	2/Year
Specific Conductance	µmhos/cm	Grab	2/Year
Total Organic Carbon	mg/L	Grab	2/Year
Cadmium ^[3]	µg/L	Grab	2/Year
Copper ^[3]	µg/L	Grab	2/Year
Lead ^[3]	µg/L	Grab	2/Year

Parameter	Units	Sample Type ^[1]	Minimum Sampling Frequency ^[2]
Mercury ^{[3][4]}	µg/L	Grab	2/Year
Nickel ^[3]	µg/L	Grab	2/Year
Zinc ^[3]	µg/L	Grab	2/Year
Visual Observations ^[5]	--	Grab	2/Year

Footnotes

^[1 to 2] See Tables E-2 footnotes. Samples are first collected during the first major storm in the rainy season and once again later in the rainy season.

^[3] Total recoverable metal.

^[4] The Discharger shall use ultra-clean sampling (USEPA 1669) to the maximum extent practicable and ultra-clean analytical methods (USEPA 1631) for mercury monitoring. The Discharger may only use alternative methods if the method has an ML of 0.5 ng/L or less, and approval is obtained from the Executive Officer prior to conducting the monitoring.

^[5] As described in Attachment G, section III.C.2.

VII. RECEIVING WATER MONITORING REQUIREMENTS

The Discharger shall continue to participate in the San Francisco Estuary Institute’s Regional Monitoring Program (RMP).

VIII. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

The Discharger shall comply with all Federal Standard Provisions (Attachment D) and Regional Standard Provisions related to monitoring, reporting, and recordkeeping, with modifications shown in section VIII.D below.

B. Self Monitoring Reports (SMRs)

1. **SMR Format.** The Discharger shall electronically submit SMRs using the State Water Board’s California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). The CIWQS website will provide directions for SMR submittals in the event of a service interruption for electronic submittal.
2. **SMR Due Dates and Contents.** The Discharger shall submit SMRs by the due dates, and with the contents, specified below:
 - a. **Monthly SMRs** — Monthly SMRs shall be due 30 days after the end of each calendar month, covering that calendar month. The monthly SMR shall contain the applicable items described in sections V.B and V.C of both Attachments D and G of this Order. See Provision VI.C.2.a (Effluent Characterization Study and Report) of this Order for information that must also be reported with the monthly SMR.
 - b. **Annual SMR** — Annual SMRs shall be due February 1 each year, covering the previous calendar year. The annual SMR shall contain the items described in Attachment G section V.C.1.f. See also Provision VI.C.2 of the Order (Effluent Characterization Study and Report) for requirements to submit reports with the annual SMR.

- c. **Additional Specifications for Submitting SMRs to CIWQS** — The Discharger shall submit analytical results and other information using one of the following methods:

Table E-7. SMR Reporting for CIWQS

Parameter	Method of Reporting	
	EDF/CDF data upload or manual entry	Attached File
All parameters identified in influent, effluent, and receiving water monitoring tables (except Dissolved Oxygen and Temperature)	Required for All Results	
Dissolved Oxygen Temperature	Required for Monthly Maximum and Minimum Results Only ^[1]	Discharger may use this method for all results or keep records
Cyanide Arsenic Cadmium Chromium Copper Lead Mercury Nickel Selenium Silver Zinc Dioxins and Furans (by U.S. EPA Method 1613)	Required for All Results ^[2]	
Antimony Beryllium Thallium Pollutants by U.S. EPA Methods 601, 602, 608, 610, 614, 624, and 625	Not Required (unless identified in influent, effluent, or receiving water monitoring tables), but encouraged ^[1]	Discharger may use this method and submit results with application for permit reissuance, unless data submitted by CDF / EDF upload
Analytical Method	Not Required (Discharger may select “data unavailable”) ^[1]	
Collection Time Analysis Time	Not Required (Discharger may select “0:00”) ^[1]	

Footnotes

^[1] The Discharger shall continue to monitor at the minimum frequency specified in the monitoring tables, keep records of the measurements, and make the records available upon request.

^[2] These parameters require EDF/CDF data upload or manual entry regardless of whether monitoring is required by this MRP or other provisions of this Order (except for biosolids, sludge, or ash provisions).

3. **Monitoring Periods.** Monitoring periods for all required monitoring shall be completed as set forth in the table below:

Table E-8. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period
Continuous	Permit effective date	All
1/Day	Permit effective date	(Midnight through 11:59 PM) or any 24-hour period that reasonably represents a calendar day for purposes of sampling.
1/Week 2/Week 3/Week	Permit effective date	Sunday through Saturday
1/Month 2/Month	Permit effective date	First day of calendar month through last day of calendar month
1/Year	Permit effective date	January 1 through December 31
2/Year	Permit effective date	Once during the wet season (typically November 1 – April 30) and once during the dry season (typically May 1 through October 31)
1/5 Years	Permit effective date	Once during the permit term within 12 months prior to applying for permit reissuance.

- 4. RL and MDL Reporting.** The Discharger shall report with each sample result the Reporting Level (RL) and Method Detection Limit (MDL) as determined by the procedure in 40 CFR 136. The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:
- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
 - b. Sample results less than the RL, but greater than or equal to the laboratory’s MDL, shall be reported as “Detected, but Not Quantified,” or DNQ. The estimated chemical concentration of the sample shall also be reported. For purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ. The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (+/- a percentage of the reported value), numerical ranges (low to high), or any other means the laboratory considers appropriate.
 - c. Sample results less than the laboratory’s MDL shall be reported as “Not Detected” or ND.
 - d. The Discharger shall instruct laboratories to establish calibration standards so that the minimum level (ML) value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from extrapolation beyond the lowest point of the calibration curve.

C. Discharge Monitoring Reports

1. As described in section VIII.B.1 above, at any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit SMRs that will

satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.

2. Once notified by the State or Regional Water Board, the Discharger shall submit hard copy DMRs. DMRs must be signed and certified as required by the Standard Provisions. The Discharger shall submit the original DMR and one copy of the DMR to one of the addresses listed below:

Standard Mail	FedEx/UPS/Other Private Carriers
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 th Floor Sacramento, CA 95814

3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated will not be accepted unless they follow the exact same format of EPA Form 3320-1.

D. Modifications to Attachment G

1. **Attachment G sections V.C.1.f and V.C.1.g are revised as follows, and section V.C.1.h (Reporting data in electronic format) is deleted.**

f. Annual self monitoring report requirements

By the date specified in the MRP, the Discharger shall submit an annual report to the Regional Water Board covering the previous calendar year. The report shall contain the following:

- 1) Annual compliance summary table of treatment plant performance, including documentation of any blending events (this summary table is not required if the Discharger has submitted the year’s monitoring results to CIWQS in electronic reporting format by EDF/CDF upload or manual entry);
- 2) Comprehensive discussion of treatment plant performance and compliance with the permit (This discussion shall include any corrective actions taken or planned, such as changes to facility equipment or operation practices that may be needed to achieve compliance, and any other actions taken or planned that are intended to improve performance and reliability of the Discharger’s wastewater collection, treatment, or disposal practices.);
- 3) Both tabular and graphical summaries of the monitoring data for the previous year if parameters are monitored at a frequency of monthly or greater (this item is not

required if the Discharger has submitted the year’s monitoring results to CIWQS in electronic reporting format by EDF/CDF upload or manual entry);

- 4) List of approved analyses, including the following:
 - (i) List of analyses for which the Discharger is certified;
 - (ii) List of analyses performed for the Discharger by a separate certified laboratory (copies of reports signed by the laboratory director of that laboratory shall not be submitted but be retained onsite); and
 - (iii) List of “waived” analyses, as approved;
- 5) Plan view drawing or map showing the Discharger’s facility, flow routing, and sampling and observation station locations;
- 6) Results of annual facility inspection to verify that all elements of the SWPP Plan are accurate and up to date (only required if the Discharger does not route all stormwater to the headworks of its wastewater treatment plant); and
- 7) Results of facility report reviews (The Discharger shall regularly review, revise, and update, as necessary, the O&M Manual, the Contingency Plan, the Spill Prevention Plan, and Wastewater Facilities Status Report so that these documents remain useful and relevant to current practices. At a minimum, reviews shall be conducted annually. The Discharger shall include, in each Annual Report, a description or summary of review and evaluation procedures, recommended or planned actions, and an estimated time schedule for implementing these actions. The Discharger shall complete changes to these documents to ensure they are up-to-date.).

g. Report submittal

The Discharger shall submit SMRs addressed as follows, unless the Discharger submits SMRs electronically to CIWQS:

California Regional Water Quality Control Board
San Francisco Bay Region
1515 Clay Street, Suite 1400
Oakland, CA 94612
Attn: NPDES Wastewater Division

h. Reporting data in electronic format – Deleted

2. Attachment G sections V.E.2, V.E.2.a, and V.E.2.c are revised as follows, and sections V.E.2.b (24-hour Certification) and V.E.2.d (Communication Protocol) are deleted.

2. Unauthorized Discharges from Municipal Wastewater Treatment Plants²

² California Code of Regulations, Title 23, Section 2250(b), defines an unauthorized discharge to be a discharge, not regulated by waste discharge requirements, of treated, partially treated, or untreated wastewater resulting from the intentional or unintentional diversion of wastewater from a collection, treatment or disposal system.

The following requirements apply to municipal wastewater treatment plants that experience an unauthorized discharge at their treatment facilities and supersede requirements imposed on the Discharger by the Executive Officer by letter of May 1, 2008.

a. Two (2)-Hour Notification

For any unauthorized discharges that enter a drainage channel or a surface water, the Discharger shall, as soon as possible, but not later than two (2) hours after becoming aware of the discharge, notify the California Emergency Management Agency (CalEMA, currently 800-852-7550), the local health officers or directors of environmental health with jurisdiction over the affected water bodies, and the Regional Water Board. Timely notification by the Discharger to CalEMA also satisfies notification to the Regional Water Board. Notification shall include the following:

- 1) Incident description and cause;
- 2) Location of threatened or involved waterway(s) or storm drains;
- 3) Date and time the unauthorized discharge started;
- 4) Estimated quantity and duration of the unauthorized discharge (to the extent known), and the estimated amount recovered;
- 5) Level of treatment prior to discharge (e.g., raw wastewater, primary treated, undisinfected secondary treated, and so on); and
- 6) Identity of the person reporting the unauthorized discharge.

b. 24-hour Certification – Deleted

c. 5-day Written Report

Within five business days, the Discharger shall submit a written report that includes, in addition to the information required above, the following:

- 1) Methods used to delineate the geographical extent of the unauthorized discharge within receiving waters;
- 2) Efforts implemented to minimize public exposure to the unauthorized discharge;
- 3) Visual observations of the impacts (if any) noted in the receiving waters (e.g., fish kill, discoloration of water) and the extent of sampling if conducted;
- 4) Corrective measures taken to minimize the impact of the unauthorized discharge;

- 5) Measures to be taken to minimize the chances of a similar unauthorized discharge occurring in the future;
 - 6) Summary of Spill Prevention Plan or O&M Manual modifications to be made, if necessary, to minimize the chances of future unauthorized discharges; and
 - 7) Quantity and duration of the unauthorized discharge, and the amount recovered.
- d. Communication Protocol – *Deleted*

APPENDIX E-1
CHRONIC TOXICITY
DEFINITION OF TERMS AND SCREENING PHASE REQUIREMENTS

I. Definition of Terms

- A. No observed effect level (NOEL) for compliance determination is equal to IC₂₅ or EC₂₅. If the IC₂₅ or EC₂₅ cannot be statistically determined, the NOEL shall be equal to the NOEC derived using hypothesis testing.
- B. Effective concentration (EC) is a point estimate of the toxicant concentration that would cause an adverse effect on a quantal, “all or nothing,” response (such as death, immobilization, or serious incapacitation) in a given percent of the test organisms. If the effect is death or immobility, the term lethal concentration (LC) may be used. EC values may be calculated using point estimation techniques such as probit, logit, and Spearman-Kärber. EC₂₅ is the concentration of toxicant (in percent effluent) that causes a response in 25 percent of the test organisms.
- C. Inhibition concentration (IC) is a point estimate of the toxicant concentration that would cause a given percent reduction in a nonlethal, nonquantal biological measurement, such as growth. For example, an IC₂₅ is the estimated concentration of toxicant that would cause a 25 percent reduction in average young per female or growth. IC values may be calculated using a linear interpolation method such as USEPA's Bootstrap Procedure.
- D. No observed effect concentration (NOEC) is the highest tested concentration of an effluent or a toxicant at which no adverse effects are observed on the aquatic test organisms at a specific time of observation. It is determined using hypothesis testing.

II. Chronic Toxicity Screening Phase Requirements

- A. The Discharger shall perform screening phase monitoring:
 - 1. Subsequent to any significant change in the nature of the effluent discharged through changes in sources or treatment, except those changes resulting from reductions in pollutant concentrations attributable to source control efforts, or
 - 2. Prior to permit reissuance. Screening phase monitoring data shall be included in the NPDES permit application for reissuance. The information shall be as recent as possible, but may be based on screening phase monitoring conducted within 5 years before the permit expiration date.
- B. Design of the screening phase shall, at a minimum, consist of the following elements:
 - 1. Use of test species specified in Appendix E-2, attached, and use of the protocols referenced in those tables.

2. Two stages:
 - a. Stage 1 shall consist of a minimum of one battery of tests conducted concurrently. Selection of the type of test species and minimum number of tests shall be based on Appendix E-2 (attached).
 - b. Stage 2 shall consist of a minimum of two test batteries conducted at a monthly frequency using the three most sensitive species based on the Stage 1 test results.
 3. Appropriate controls.
 4. Concurrent reference toxicant tests.
 5. Dilution series of 100%, 50%, 25%, 12.5%, 6.25%, and 0 %, where “%” is percent effluent as discharged, or as otherwise approved the Executive Officer if different dilution ratios are needed to reflect discharge conditions.
- C. The Discharger shall submit a screening phase proposal. The proposal shall address each of the elements listed above. If within 30 days, the Executive Officer does not comment, the Discharger shall commence with screening phase monitoring.

**APPENDIX E-2
 SUMMARY OF TOXICITY TEST SPECIES REQUIREMENTS**

Table AE-1. Critical Life Stage Toxicity Tests for Estuarine Waters

Species	(Scientific Name)	Effect	Test Duration	Reference
Alga	<i>(Skeletonema costatum)</i> <i>(Thalassiosira pseudonana)</i>	Growth rate	4 days	1
Red alga	<i>(Champia parvula)</i>	Number of cystocarps	7–9 days	3
Giant kelp	<i>(Macrocystis pyrifera)</i>	Percent germination; germ tube length	48 hours	2
Abalone	<i>(Haliotis rufescens)</i>	Abnormal shell development	48 hours	2
Oyster Mussel	<i>(Crassostrea gigas)</i> <i>(Mytilus edulis)</i>	Abnormal shell development; percent survival	48 hours	2
Echinoderms - Urchins Sand dollar	<i>(Strongylocentrotus purpuratus, S. franciscanus)</i> <i>(Dendraster excentricus)</i>	Percent normal larval development	1 hour	2
Shrimp	<i>(Americamysis bahia)</i>	Percent survival; growth	7 days	3
Shrimp	<i>(Holmesimysis costata)</i>	Percent survival; growth	7 days	2
Topsmelt	<i>(Atherinops affinis)</i>	Percent survival; growth	7 days	2
Silversides	<i>(Menidia beryllina)</i>	Larval growth rate; percent survival	7 days	3

Toxicity Test References:

1. American Society for Testing Materials (ASTM). 1990. Standard Guide for Conducting Static 96-Hour Toxicity Tests with Microalgae. Procedure E 1218-90. ASTM, Philadelphia, PA.
2. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to West Coast Marine and Estuarine Organisms. EPA/600/R-95/136. August 1995.
3. Short-term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Waters to Marine and Estuarine Organisms. EPA/821/R-02/014. October 2002.

Table AE-2. Critical Life Stage Toxicity Tests for Fresh Waters

Species	(Scientific Name)	Effect	Test Duration	Reference
Fathead minnow	<i>(Pimephales promelas)</i>	Survival; growth rate	4 days	4
Water flea	<i>(Ceriodaphnia dubia)</i>	Survival; number of young	7 days	4
Alga	<i>(Selenastrum capricornutum)</i>	Final cell density	4 days	4

Toxicity Test Reference:

4. Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, fourth Edition Chronic manual (EPA-821-R-02-013, October 2002).

Table AE-3. Toxicity Test Requirements for Stage One Screening Phase

Requirements	Receiving Water Characteristics		
	Discharges to Coast	Discharges to San Francisco Bay ^[1]	
	Ocean	Marine/Estuarine	Freshwater
Taxonomic diversity	1 plant 1 invertebrate 1 fish	1 plant 1 invertebrate 1 fish	1 plant 1 invertebrate 1 fish
Number of tests of each salinity type: Freshwater ^[2]	0	1 or 2	3
Marine/Estuarine	4	3 or 4	0
Total number of tests	4	5	3

^[1] (a) Marine refers to receiving water salinities greater than 1 part per thousand (ppt) at least 95 percent of the time during a normal water year.

(b) Freshwater refers to receiving water with salinities less than 1 ppt at least 95 percent of the time during a normal water year.

(c) Estuarine refers to receiving water salinities that fall between those of marine and freshwater, as described above.

^[2] The freshwater species may be substituted with marine species if:

(a) The salinity of the effluent is above 1 ppt greater than 95 percent of the time, or

(b) The ionic strength (TDS or conductivity) of the effluent at the test concentration used to determine compliance is documented to be toxic to the test species.

ATTACHMENT F - FACT SHEET

Contents

I. Permit Information	F-3
II. Facility Description	F-4
B. Discharge Points and Receiving Waters	F-7
C. Summary of Existing Requirements and Self-Monitoring Report Data	F-8
D. Compliance Summary	F-10
Failures to achieve 85% removal of TSS were due to the very low levels TSS concentrations in the influent making an 85% reduction difficult. In this Order, 85% reduction is only required if and when the Industrial Plant is used to treat sanitary waste.	F-10
E. Planned Changes	F-10
III. Applicable Plans, Policies, and Regulations	F-11
A. Legal Authorities	F-11
B. California Environmental Quality Act (CEQA).....	F-11
C. State and Federal Regulations, Policies, and Plans	F-11
D. Impaired Water Bodies on CWA 303(d) List	F-13
IV. Rationale For Effluent Limitations and Discharge Specifications	F-13
A. Discharge Prohibitions	F-13
B. Effluent Limitations for Conventional and Non-Conventional Pollutants.....	F-14
1. Technology-Based Effluent Limitations	F-14
2. Applicable Technology-Based Effluent Limitations.....	F-17
C. Water Quality-Based Effluent Limitations (WQBELs) for Toxic Substances	F-19
1. Scope and Authority	F-19
2. Beneficial Uses and Water Quality Objectives	F-20
3. Determining the Need for WQBELs	F-21
4. WQBEL Calculations.....	F-26
5. Whole Effluent Acute Toxicity – Discharge Point No. 001.....	F-35
6. Whole Effluent Chronic Toxicity – Discharge Point No. 001	F-36
D. Anti-backsliding and Antidegradation	F-37
V. Rationale for Receiving Water Limitations.....	F-38
VI. Rationale for Monitoring and Reporting Requirements.....	F-38
A. Influent Monitoring	F-38
B. Effluent Monitoring.....	F-38
C. Receiving Water Monitoring.....	F-39
VII. Rationale for Provisions	F-39
A. Standard Provisions (Provision VI.A).....	F-39
B. Monitoring and Reporting Requirements (Provision VI.B).....	F-39
C. Special Provisions	F-40
1. Reopener Provisions.....	F-40
2. Effluent Characterization Study and Report	F-40
3. Best Management Practices and Pollutant Minimization Program.....	F-41
VIII. Public Participation.....	F-42
A. Notification of Interested Parties.....	F-42
B. Written Comments	F-42

C. Public Hearing.....	F-42
D. Waste Discharge Requirements Petitions.....	F-43
E. Information and Copying	F-43
F. Register of Interested Persons	F-43
G. Additional Information.....	F-43

Tables

Table F-1. Facility Information.....	F-3
Table F-2. Outfall Locations.....	F-8
Table F-3. Previous Effluent Limitations and Monitoring Data from Discharge Point No. 001-San	F-8
Table F-4. Previous Effluent Limitations and Monitoring Data from Discharge Point No. 001-Ind.....	F-9
Table F-5. Previous Effluent Limitations and Monitoring Data from Discharge Point No. 001	F-9
Table F-7. Basin Plan Beneficial Uses	F-12
Table F-8. Secondary Treatment Requirements	F-15
Table F-9. Factors Considered Pursuant to 40 CFR 125.3(d).....	F-17
Table F-10. Summary of RPA Results	F-23
Table F-11. WQBEL Calculations.....	F-34
Table F-12. Monitoring Requirements Summary.....	F-39

ATTACHMENT F – FACT SHEET

As described in section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order.

This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for dischargers in California. Only those sections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections of this Order not specifically identified as “not applicable” fully apply to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the San Francisco International Airport, Mel Leong Treatment Plants (Sanitary Plant and Industrial Plant) and associated sewage collection systems.

Table F-1. Facility Information

WDID	2 417033001
CIWQS Place ID	256506 (Industrial) 256507 (Sanitary)
Dischargers	City and County of San Francisco, North Bayside System Unit
Facility Name	San Francisco International Airport, Mel Leong Sanitary and Industrial Treatment Plants and wastewater collection systems
Facility Address	Bldg. 924 Clearwater Drive, San Francisco, San Mateo County, CA 94128
Facility Contact, Title, Phone, and Email	Peter Acton, Maintenance Director, (650) 821-5400, Peter.Acton@flysfo.com
CIWQS Contact Party No.	527070
Authorized Person to Sign and Submit Reports	Peter Acton, Maintenance Director, (650) 821-5400
Mailing Address	P.O. Box 8097, 682 North McDonnell Road, San Francisco, CA 94128
Billing Address	Same as Mailing Address
Facility Type	Sanitary and Industrial Wastewater Treatment Plants
Major or Minor Facility	Major
Threat to Water Quality	1
Complexity	A
Pretreatment Program	No
Reclamation Requirements	Producer and user
Facility Permitted & Design Flow	Combined 3.3 million gallons per day (MGD) - Sanitary Plant: 2.2 MGD - Industrial Plant: 1.2 MGD
Watershed	Lower San Francisco Bay
Receiving Water	Lower San Francisco Bay
Receiving Water Type	Marine
Service Area	San Francisco International Airport
Service Population	Estimated at 10,000

- A. The City and County of San Francisco owns and operates the San Francisco International Airport, Mel Leong Treatment Plant, Sanitary Plant (hereinafter Sanitary Plant); the Mel Leong Treatment Plant, Industrial Plant (hereinafter Industrial Plant); and their associated collection systems.

- B.** The City and County of San Francisco, San Francisco International Airport, Mel Leong Treatment Plant, Sanitary Plant (hereinafter Sanitary Plant) is currently discharging under Order No. R2-2007-0058 (CIWQS Regulatory Measure No. 256507) and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0038318. The City and County of San Francisco, San Francisco International Airport, Mel Leong Treatment Plant, Industrial Plant (hereinafter Industrial Plant) is currently discharging under Order No. R2-2007-0060 (CIWQS Regulatory Measure No. 256506) and NPDES Permit No. CA0028070. Both orders were amended by Order Nos. R2-2010-0054 and R2-2012-0096.

Both the Sanitary Plant and Industrial Plant discharge wastewater to a single pipeline for dechlorination and discharge into Lower San Francisco Bay by the North Bayside System Unit (NBSU) facility in South San Francisco. This Order combines the previous Sanitary Plant and Industrial Plant permits into one permit. The Sanitary Plant, Industrial Plant, and their collection systems are hereinafter collectively referred to as the Facility.

The NBSU, a Joint Powers Authority, operates the dechlorination plant and discharges the treated effluent. The NBSU's members include the cities of Millbrae, Burlingame, South San Francisco, and San Bruno, and San Francisco. San Francisco and the NBSU are hereinafter referred to as the Discharger. For the purposes of this Order, references to the "discharger" or "permittee" in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

These discharges are also regulated under Order No. R2-2012-0096 (NPDES Permit CA0038849), which supersedes all requirements on mercury and PCBs from wastewater discharges in the region. This Order does not affect the mercury and PCBs permit.

- C.** The Discharger filed a Report of Waste Discharge and applied for reissuance of its waste discharge requirements and NPDES permit on March 30, 2012.

II. FACILITY DESCRIPTION

A. Description of Wastewater and Biosolids Treatment

- 1. Facility Description.** The City and County of San Francisco owns and operates the Sanitary Plant and Industrial Plant. The Industrial Plant treats industrial wastewater from maintenance shops and vehicle washing, as well as first-flush stormwater runoff from industrial areas. The Sanitary Plant includes a collection system and treats sanitary wastewater from airplanes and airport facilities, including terminal restrooms, hangars, restaurants, and shops. The Discharger may, in emergency situations, use either plant to store or treat flows, spills, or overflows that would normally flow to the other plant to ensure that all wastewater is adequately treated. Every two months, approximately 16,000 gallons of secondary treated industrial wastewater is routed to the sanitary plant to allow maintenance of the industrial plant's chlorine disinfection system. The service population for these treatment plants is estimated at 10,000. In 2011, the Sanitary Plant discharged an average daily flow of 0.63 MGD; the highest recorded daily flow was 1.4 MGD, well below the design flow of 2.2 MGD. In 2011, the Industrial Plant discharged an average daily flow of 0.63 MGD; the highest recorded daily flow was 1.22 MGD, roughly equal to the design flow of 1.2 MGD.

- 2. Collection System.** Sanitary wastewaters from airport facilities are collected and conveyed to the Sanitary Plant through a system consisting of over 20 miles of sewer piping, seven 7 lift stations, and 18 pump stations. Industrial wastewaters from airport facilities are collected in a separate industrial collection system that has 20 pump stations directing wastewater to a single force main leading to the Industrial Plant.

The first flush of stormwater runoff from terminals, taxiways, tarmacs, and aircraft and vehicle parking is collected in four detention ponds (the North Oxidation Pond, the South Detention Pond, the West Field Detention Basin, and the East Pond). Stormwater runoff collected in these ponds and basins is pumped to the Industrial Plant. The detention ponds have a total capacity of 9.6 million gallons. When these detention basins are full, the excess runoff is discharged directly to San Francisco Bay through one of nine stormwater outfalls. From a few active airport areas, the runoff is not collected in basins but is either pumped directly to the Industrial Plant or discharged to San Francisco Bay. Runoff from runways and some portions of taxi ways is discharged directly to the Bay after flowing through the grassy runway medians. Deicing fluids could be used at any gate depending on the destination of the departing aircraft, but in practice are rarely, if ever, used. Any deicing fluid wastewater would be routed to the detention basins with the first flush of stormwater runoff and treated at the

- 3. Treatment Description.** The Sanitary Plant treatment operations consist of punched plate bar screens, grit removal, flow equalization, biological treatment using sequencing batch reactors, effluent flow equalization, and chlorination. Solids from the Sanitary Plant are treated by gravity belt thickening and anaerobic digestion before dewatering by belt filter presses or air drying using sludge drying beds.

Influent from the industrial wastewater collection system is initially stored in an equalization tank. The first treatment stage at the Industrial Plant flocculates the combined industrial wastewater and any incoming first flush of stormwater, followed by dissolved air floatation, pH adjustment (as needed), aerobic biological treatment via trickling filter, secondary clarification, and chlorination. The Discharger can divert up to 0.72 MGD of the effluent from the chlorination tank to tertiary filters. This reclaimed water is used, when required, for irrigation or utility water make-up. The clarifiers collect sludge and scum, which are pumped to sludge beds for dewatering. Filtrate drained from the sludge is pumped back to the trickling filter for treatment. The existing industrial treatment plant equipment is reaching design life and may be replaced during the term of the permit with new equipment that will meet, or exceed, the performance of the existing plant.

Chlorinated wastewater from both plants is combined at a pumping station and discharged to the NBSU pipeline for dechlorination in South San Francisco Wastewater Treatment Facility, along with treated effluent from South San Francisco, San Bruno, Millbrae, and Burlingame, prior to discharge through a deep water outfall.

Attachment B provides a map of the area around the Facility. Attachment C provides a flow schematic of the Facility.

- 4. Discharge Point.** Effluent from the NBSU force main discharges into Lower San Francisco Bay, northeast of Point San Bruno, through a submerged diffuser approximately 5,300 feet offshore at a depth of 20 feet below mean lower low water (latitude 37° 39' 55" North, and

longitude 122° 21' 41" West). The diffuser is 654 feet long and consists of 66 three-inch openings spaced 7 feet apart. This outfall is Discharge Point No. 002. Monitoring Location EFF-002 is a point in the outfall pipeline after dechlorination.

This Order defines internal discharge points. Discharge Point No. 001 (Monitoring Location EFF-001) represents the combined treated effluent from the Sanitary Plant and Industrial Plant. Discharge Point No. 001-San (Monitoring Location EFF-001-San) represents the treated effluent from the Sanitary Plant. Discharge Point No. 001-Ind (Monitoring Location EFF-001-Ind) represents the treated effluent from the Industrial Plant.

- 5. Biosolids Management.** The dewatering and disposal of biosolids from the Sanitary Plant and Industrial Plant are separate. Biosolids from the Sanitary Plant are treated by gravity belt thickening and anaerobic digestion, then dewatered by belt filter presses or air dried using sludge drying beds. Final sludge cake and air-dried sludge transported to SYNAGRO composting facility. Sludge and scum from the Industrial Plant are pumped to separate sludge beds for dewatering. The dried industrial waste sludge is trucked off-site and used as daily cover at a landfill.
- 6. Stormwater Discharge.** In addition to the Sanitary Plant and Industrial Plant discharges, this Order also covers stormwater discharges of surface runoff from different areas of the airport. Stormwater from tarmac areas in excess of the available storage capacity in the detention basins is discharged directly to San Francisco Bay. Several airport areas are occupied by tenants, including but not limited to the United Maintenance Facility and the Fuel Tank Farm. These tenants cover their own stormwater discharges under the statewide industrial stormwater NPDES permit (NPDES General Permit No. CAS000001) and thus are not covered by this Order. Airport tenants are prohibited by the Airport's Rules and Regulations from generating any unauthorized discharges to the stormwater runoff collection system. Only rainfall runoff is allowed to be discharged to the airport's stormwater collection system. The airport's four stormwater runoff detention basins store only the first flush of rainfall runoff generated at the developed portions of the airport. Once these basins are filled to capacity, the inflow gates are closed and each basin is isolated from the stormwater conveyance pipelines. Any additional runoff is then discharged directly from the storm drain system to the Bay. The runoff stored in the detention basins is pumped to the Industrial Plant for treatment. A separate State Water Board General Permit, CAS000002, covers stormwater discharges associated with construction activities taking place east of Highway 101.

 - a. Discharge Point No. 003.** Discharge Point 003 discharges stormwater from areas that drain into the South Detention Pond. When the South Detention Pond has reached capacity, stormwater is discharged directly to the Bay through Discharge Point 003. The South Detention Pond receives runoff from the United Airlines cargo and surface facilities, Boarding Areas A through F, and Singapore Airlines and Philippine Airlines service areas in the south-west part of the airport (known as Plot 3). Over these tarmac areas, various industrial activities take place that include aircraft, vehicle, and equipment fueling, maintenance, and washing, and, when rarely required, aircraft de-icing. This Discharge Point also discharges, directly to the Bay, runoff from runway areas along the southeast corner of the airport property where there are no industrial or other activities involving the use of fuel or chemicals.

- b. Discharge Point No. 004.** Discharge Point No. 004 discharges stormwater runoff from areas that drain into the 6.0-million-gallon West Field Detention Basin, the 0.3-million-gallon East Detention Basin, which includes runoff from the northwest side of Terminal 3, and the 0.77-million-gallon United Airlines Detention Basin. When these detention ponds have reached full capacity that stormwater is discharged direct to the Bay through Discharge Point 004. Runoff from the United States Coast Guard Facility is also directly discharged through Discharge Point No. 004 to the Seaplane Harbor, which opens to San Francisco Bay.
- c. Discharge Point No. 005.** Discharge Point No. 005 discharges stormwater runoff, and any infiltrated Bay water, from runway and taxiway areas south of Runway 28L, directly to the Bay. There is no aircraft, vehicle, or equipment fueling, maintenance, or washing in this area.
- d. Discharge Point No. 006.** Discharge Point 006 discharges stormwater runoff, and any infiltrated Bay water, from the area north of Runway 28R, directly to the Bay. There is no aircraft, vehicle, or equipment fueling, maintenance, or washing in this area.
- e. Discharge Point No. 007.** Discharge Point No. 007 discharges stormwater runoff, and any infiltrated Bay water, from the area northwest of Runway 19R, directly to the Bay. There is no aircraft, vehicle, or equipment fueling, maintenance, or washing in this area.
- f. Discharge Point No. 008.** Discharge Point No. 008 discharges stormwater runoff, and any infiltrated Bay water, from the taxiway, ramp, and roof areas of the eastern section of the Superbay Hangar areas directly to the Bay. If there is a spill incident and this affects the quality of runoff water, the runoff is pumped to the Industrial Plant for treatment.
- g. Discharge Point No. 009.** Discharge Point No. 009 discharges stormwater runoff, and any infiltrated Bay water, from the taxiway, ramp, and roof areas under the western section of Superbay Hangar area directly to the Bay.
- h. Discharge Point No. 010.** Discharge Point No. 010 discharges stormwater runoff, from the western area of the North Cargo Facility and areas around the North Access Road, directly to the Bay. There is no aircraft, vehicle, or equipment fueling, maintenance, or washing in this area.
- i. Discharge Point No. 013.** Discharge Point No. 013 discharges stormwater runoff from taxiways and ramps around the North Cargo Facility that drain into the 0.43-million-gallon North Field Detention Basin. When the detention pond has reached capacity, stormwater is discharged directly to the Bay through Discharge Point 013.

B. Discharge Points and Receiving Waters

The location of the discharge points and the receiving waters are indicated below.

Table F-2. Outfall Locations

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
001-San	Secondary treated sanitary wastewater	37° 39' 55" N	122° 21' 41" W	Lower San Francisco Bay
001-Ind	Treated industrial wastewater and stormwater runoff	37° 39' 55" N	122° 21' 41" W	Lower San Francisco Bay
001	Combined treated sanitary and industrial wastewater and stormwater runoff	37° 39' 55" N	122° 21' 41" W	Lower San Francisco Bay
002	Dechlorinated treated sanitary & industrial wastewater & stormwater runoff	37° 39' 55" N	122° 21' 41" W	Lower San Francisco Bay
003	Stormwater runoff	37° 36' 18" N	122° 22' 40" W	Lower San Francisco Bay
004	Stormwater runoff	37° 37' 46" N	122° 23' 19" W	Lower San Francisco Bay
005	Stormwater runoff	37° 36' 44" N	122° 21' 58" W	Lower San Francisco Bay
006	Stormwater runoff	37° 37' 05" N	122° 21' 44" W	Lower San Francisco Bay
007	Stormwater runoff	37° 37' 42" N	122° 22' 17" W	Lower San Francisco Bay
008	Stormwater runoff	37° 37' 40" N	122° 22' 25" W	Lower San Francisco Bay
009	Stormwater runoff	37° 37' 44" N	122° 23' 19" W	Lower San Francisco Bay
010	Stormwater runoff	37° 38' 20" N	122° 23' 25" W	Lower San Francisco Bay
013	Stormwater runoff	37° 38' 21" N	122° 23' 10" W	Lower San Francisco Bay

C. Summary of Existing Requirements and Self-Monitoring Report Data

Effluent limitations contained in Order Nos. R2-2007-0058 and R2-2007-0060, and representative monitoring data collected from May 2007 to November 2011, are presented in the tables below.

Table F-3. Previous Effluent Limitations and Monitoring Data from Discharge Point No. 001-San

Parameter	Units	Effluent Limitations			Monitoring Data (October 2007 - November 2011)		
		Monthly Average	Weekly Average	Daily Maximum	Highest Monthly Average	Highest Weekly Average	Highest Daily Discharge
Carbonaceous Biochemical Oxygen Demand (5-day at 20°C)(CBOD)	mg/L	25	40	--	19	26	27
CBOD	% Removal	85	--	--	96 ^[1]	--	--
Total Suspended Solids (TSS)	mg/L	30	45	--	24	25	48
TSS	% Removal	85	--	--	95 ^[1]	--	--
pH	Standard units	6.0 – 9.0			6.2 - 8.1		
Oil and Grease	mg/L	10	--	20	5.4	--	5.6

Footnote

^[1] Lowest monthly percent removal.

Table F-4. Previous Effluent Limitations and Monitoring Data from Discharge Point No. 001-Ind

Parameter	Units	Effluent Limitations			Monitoring Data (October 2007-November 2011)		
		Monthly Average	Weekly Average	Daily Maximum	Highest Monthly Average	Highest Weekly Average	Highest Daily Discharge
Biochemical Oxygen Demand (5-day at 20°C) (BOD)	mg/L	30	45	--	5.0	7.7	10
BOD	% Removal	85 ^[1]	--	--	80 ^[2]	--	--
Total Suspended Solids (TSS)	mg/L	30	45	--	9.2	13	20
TSS	% Removal	85	--	--	83 ^[1]	--	--
pH	Standard units	6.0 – 9.0			6.6 - 8.8		
Oil and Grease	mg/L	10	--	20	1.5	--	1.5

Footnotes

- ^[1] If concentration in influent is > 45 mg/L.
^[2] Concentration in the influent was <45 mg/L thus limits did not apply.

Table F-5. Previous Effluent Limitations and Monitoring Data from Discharge Point No. 001

Parameter	Units	Effluent Limitations		Monitoring Data (October 2007 – December 2011)
		Monthly Average	Daily Maximum	Highest Daily Discharge
Copper, Total Recoverable	µg/L	42	84	11.0
Lead, Total Recoverable	µg/L	64	110	2.7 ^[1]
Mercury, Total Recoverable	µg/L	0.020	0.041	0.019
Nickel, Total Recoverable	µg/L	76	150	5.9
Dioxin-TEQ	µg/L	1.4 x 10 ⁻⁸	2.8 x 10 ⁻⁸	9.2 x 10 ⁻⁷ ^[1]
Aldrin	µg/L	0.00014	0.00028	<0.0014 ^[2]
Alpha-BHC	µg/L	0.13	0.26	<0.012
Beta-BHC	µg/L	0.46	0.92	<0.0007
4,4-DDT	µg/L	0.00059	0.0012	<0.0015 ^[2]
4,4-DDE	µg/L	0.00059	0.0012	<0.0015 ^[2]
Dieldrin	µg/L	0.00014	0.00028	<0.008 ^[2]
Endrin	µg/L	0.19	0.037	<0.0016
Heptachlor	µg/L	0.020	0.0041	<0.0013 ^[2]
Heptachlor Epoxide	µg/L	0.00089	0.0018	<0.00075
Ammonia	µg/L	120	310	90
Tributyltin	µg/L	0.061	0.12	<0.0026
Fecal Coliform	CFU ^[9] /100mL	200 ^[3]	400 ^[4]	24
Enterococci	Colonies/100mL	35	--	12 ^[5]
Acute Toxicity	% Survival	^[6]	^[6]	90/95 ^[7]
Chronic Toxicity	TUc	--	^[8]	6.7

Footnotes

- ^[1] Detected but not quantifiable. This value was not used for compliance purposes.
^[2] Although the minimum levels were not low enough to determine compliance with the applicable effluent limitations, they were equal to or less than those specified in the previous orders and SIP.
^[3] The 5-day geometric mean for fecal coliform density limit was 200 MPN/100mL.

- [4] The 90th percentile value of the last ten fecal coliform density values was not to exceed 400 MPN/100mL.
- [5] The highest reported monthly geometric mean.
- [6] Acute toxicity effluent limitations included an 11 sample median of not less than 90 percent survival and an 11-sample 90th percentile value of not less than 70 percent.
- [7] The lowest 11- sample median was 95 percent, and the lowest 11-sample 90th percentile was 90 percent.
- [8] The Basin Plan’s narrative effluent limitation and an accelerated monitoring trigger of 10 TUc were established for chronic toxicity.
- [9] Colony forming Units/100mL

D. Compliance Summary

The following table summarizes effluent limitation exceedances during the term of the previous orders.

Table F-6. Summary of Effluent Violations (October 2007-March 2012)

Date of Violation	Discharge Location	Pollutant	Units	Effluent Limit	Reported Value
October 2008	EFF-001 Ind	TSS Monthly Removal	% Removal	85%	83%
January 2010	EFF-001 Ind	TSS Monthly Removal	% Removal	85%	83%
June 2010	EFF-001 Ind	TSS Monthly Removal	% Removal	85%	84%
July 2010	EFF-001 Ind	TSS Monthly Removal	% Removal	85%	84%
February 2012	EFF-001 Ind	TSS Monthly Removal	% Removal	85%	84%

Failures to achieve 85% removal of TSS were due to the very low TSS concentrations in the industrial influent making an 85% reduction difficult. Because the 85% removal requirement was established for treatment of sanitary wastes, in this Order, 85% reduction is only required if the Industrial Plant would be used to treat sanitary waste, and at all times when the influent concentration is 45 mg/L or higher.

The Discharger was also subject to Cease and Desist Orders (CDOs) R2-2007-0059, for the Sanitary Plant, and R2-2007-0061, for the Industrial Plant. Both of these CDOs addressed pesticides detected in plant effluent. The CDOs required investigations, plans to identify potential sources and subsequent actions, submission of reports, and compliance with the effluent limitations in the previous orders for pesticides with effluent limits. The Discharger completed all the studies and submitted all reports required by the CDOs within the dates specified in the CDOs. These pollutants were not detected during the terms of the previous orders; thus there is no longer reasonable potential that these pesticide discharges might result in exceedances of water quality standards. The CDOs can therefore be rescinded.

E. Planned Changes

The Discharger is currently in the design phase for new equipment for the industrial treatment plant to replace the current equipment which, after 40 years of operation, is reaching design life. The Discharger anticipates completing replacement in approximately 3 to 5 years. The Discharger will evaluate the feasibility of renovating the existing trickling filter and secondary clarification units. During the renovation period, the effluent from the industrial primary treatment unit would be diverted to the sequencing batch reactors in the sanitary unit for secondary treatment. Although the design has not yet been completed, the new treatment plant equipment is expected to increase flow capacity up to 1.7 MGD and consist of two identical treatment trains, with flow equalization, coagulant and polymer addition, settling tank, dissolved air floatation, trickling filter, and secondary

clarification. Effluent from both treatment trains would be directed to a single chlorine contact chamber and discharged to the combined outfall or sent for tertiary treatment and reuse.

If the new equipment is put into service during the term of this Order, all requirements applicable to the Industrial Plant will continue to apply, provided the new equipment meets or exceeds existing treatment standards, processes the same wastewater, is located at the same facility, and discharges at the same discharge point as the existing plant.

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in this Order are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order is issued pursuant to Clean Water Act (CWA) section 402 and implementing regulations adopted by the USEPA and California Water Code (CWC) Chapter 5.5, Division 7 (commencing with section 13370). It serves as an NPDES permit for point source discharges from the Facility to surface waters. This Order also serves as Waste Discharge Requirements pursuant to CWC Article 4, Chapter 4, Division 7 (commencing with section 13260).

B. California Environmental Quality Act (CEQA)

Under CWC section 13389, this action to adopt an NPDES permit is exempt from the provisions of Chapter 3 of CEQA.

C. State and Federal Regulations, Policies, and Plans

1. Water Quality Control Plans. The *Water Quality Control Plan for the San Francisco Bay Basin* (hereinafter Basin Plan) is the Regional Water Board's master water quality control planning document. It designates beneficial uses and water quality objectives (WQOs) for waters of the State, including surface waters and groundwater. It also includes implementation programs to achieve WQOs. The Basin Plan was adopted by the Regional Water Board and approved by the State Water Board, the Office of Administrative Law, and USEPA. Requirements of this Order implement the Basin Plan.

The Basin Plan beneficial uses for Lower San Francisco Bay are listed below. State Water Board Resolution No. 88-63 establishes State policy that all waters, with certain exceptions, are to be considered suitable or potentially suitable for municipal or domestic supply. Because of marine influence in Lower San Francisco Bay, total dissolved solids levels exceed 3,000 milligrams per liter (mg/L) and thereby meet an exception to State Water Board Resolution No. 88-63. The MUN designation, therefore, does not apply to Lower San Francisco Bay.

Table F-7. Basin Plan Beneficial Uses

Discharge Points	Receiving Water	Beneficial Uses
002 through 010 & 013	Lower San Francisco Bay	Industrial Service Supply (IND) Navigation (NAV) Water Contact Recreation (REC1) Non-Contact Water Recreation (REC2) Ocean Commercial and Sport Fishing (COMM) Wildlife Habitat (WILD) Preservation of Rare and Endangered Species (RARE) Fish Spawning (SPWN) Fish Migration (MIGR) Shellfish Harvesting (SHELL) Estuarine Habitat (EST)

The State Water Board’s *Water Quality Control Plan for Enclosed Bays and Estuaries—Part 1, Sediment Quality* became effective on August 25, 2009. This plan supersedes other narrative sediment quality objectives, and establishes new sediment quality objectives and related implementation provisions for specifically defined sediments in most bays and estuaries.

2. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and amended it on May 4, 1995, and November 9, 1999. About 40 criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that apply in the State. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority toxic pollutants.
3. **State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (hereinafter State Implementation Policy [SIP]). The SIP became effective on April 28, 2000, with respect to the priority pollutant criteria USEPA promulgated through the NTR and to the WQOs established in the Basin Plan. The SIP became effective on May 18, 2000, with respect to the priority pollutant criteria promulgated through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005, that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
4. **Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes (65 Fed. Reg. 24641 [April 27, 2000], codified at 40 CFR 131.21). Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
5. **Antidegradation Policy.** NPDES regulations at 40 CFR 131.12 requires that State WQS include an antidegradation policy consistent with the federal policy. The State Water Board established California’s antidegradation policy in State Water Board Resolution 68-16, which

incorporates the federal antidegradation policy where the federal policy applies under federal law and requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies.

- 6. Anti-Backsliding Requirements.** CWA Sections 402(o)(2) and 303(d)(4) and 40 CFR 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous order, with some exceptions where limitations may be relaxed.

D. Impaired Water Bodies on CWA 303(d) List

In October 2011, USEPA approved a revised list of impaired water bodies prepared pursuant to CWA section 303(d), which requires identification of specific water bodies where it is expected that water quality standards will not be met after implementation of technology-based effluent limitations on point sources. Where it has not done so already, the Regional Water Board plans to adopt Total Maximum Daily Loads (TMDLs) for pollutants on the 303(d) list. TMDLs establish wasteload allocations for point sources and load allocations for non-point sources, and are established to achieve the water quality standards for the impaired water bodies.

Lower San Francisco Bay is an impaired water body. The pollutants impairing Lower San Francisco Bay are chlordane, DDT, dieldrin, dioxins, furans, mercury, invasive species, PCBs and trash. Mercury and PCBs discharges are regulated under Regional Water Board Order R2-2012-0096, which implements the mercury and PCBs TMDLs. TMDLs have not yet been developed for chlordane, DDT, dieldrin, dioxins, furans, invasive species, and trash.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants discharged into waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the NPDES regulations: 40 CFR 122.44(a) requires that permits include applicable technology-based limitations and standards; and 40 CFR 122.44(d) requires that permits include water quality-based effluent limitations (WQBELs) to attain and maintain applicable numeric and narrative water quality objectives (WQOs) to protect receiving water beneficial uses. Several specific factors affecting the development of limitations and requirements in this Order are discussed below.

A. Discharge Prohibitions

- 1. Discharge Prohibition III.A** (No discharge other than that described in this Order): This prohibition is based on 40 CFR 122.21(a), duty to apply, and CWC Section 13260, which requires filing a Report of Waste Discharge before discharges can occur. Discharges not described in the Report of Waste Discharge, and subsequently in this Order, are prohibited.
- 2. Discharge Prohibition III.B** (Minimum initial dilution of 74:1): The Order allows a dilution of 74:1 in the calculation of one or more water quality based effluent limitations, based on information regarding the dilution achieved by the Discharger's current outfall. Therefore,

this prohibition is necessary to ensure that the assumptions used to derive the dilution credit remain substantially the same so the limitations are protective of water quality.

3. **Discharge Prohibition III.C** (No bypass or overflow of untreated or partially treated wastewaters to waters of the U.S. is prohibited): This prohibition is based on 40 CFR 122.41(m).
4. **Discharge Prohibition III.D** (Average dry weather flow not to exceed dry weather discharge capacity): This prohibition is based on the historic and tested reliable treatment capacity of the individual treatment plants. Exceedance of the treatment plants' average dry weather flow design capacity may result in lowering the reliability of achieving compliance with water quality requirements.
5. **Discharge Prohibition III.E** (No sanitary sewer overflows to waters of the United States): This prohibition is based on Basin Plan Table 4-1, Discharge Prohibition No. 15, and the CWA prohibit the discharge of wastewater to surface waters except as authorized under an NPDES permit. Publicly-owned treatment works must achieve secondary treatment standards, at a minimum, and any more stringent limitations necessary to achieve water quality standards (33 U.S.C. § 1311[b][1][B and C]). Therefore, a sanitary sewer overflow that results in the discharge of raw sewage, or sewage not meeting secondary treatment requirements, to surface waters is prohibited under the CWA and the Basin Plan.
6. **Discharge Prohibition III.F** (Discharge of deicing fluid that contains urea is prohibited): U.S. EPA has established technology-based limitations and standards for de-icing operations at airports at 40 CFR Part 449, *Effluent Limitations Guidelines for the Airport Deicing Point Source Category* (ELGs). The airport de-icing ELGs were published in the Federal Register on May 16, 2012, and became effective on June 15, 2012. Effluent limitations established at 40 CFR 449.10 representing Best Available Technology require that there shall be no discharge of airfield pavement deicers containing urea, and that the Discharger certify annually that it does not use airfield de-icing products that contain urea. While de-icing operations rarely occur at the airport, on those rare occasions, the de-icing fluid is collected and routed to the Industrial Plant for treatment.

B. Effluent Limitations for Conventional and Non-Conventional Pollutants

1. Technology-Based Effluent Limitations

CWA section 301(b) and 40 CFR 122.44(a) require that permits include applicable technology-based limitations based on several levels of control:

- Best practicable treatment control technology (BPT) represents the average of the best existing performance by well-operated facilities within an industrial category or subcategory. BPT standards apply to toxic, conventional, and non-conventional pollutants.
- Best available technology economically achievable (BAT) represents the best existing performance of treatment technologies that are economically achievable within an

industrial point source category or subcategory. BAT standards apply to toxic and nonconventional pollutants.

- Best conventional pollutant control technology (BCT) represents the control from existing industrial point sources of conventional pollutants including BOD, TSS, total coliform, pH, and oil and grease. The BCT standard is established after considering the relationship between the cost of attaining a reduction in effluent discharge and the benefits that would result, and also the cost effectiveness of additional industrial treatment beyond BPT.
- New source performance standards (NSPS) represent the best available demonstrated control technology standards. The intent of NSPS guidelines is to set limitations that represent state-of-the-art treatment technology for new sources. The Discharger is in the planning phase for new industrial treatment plant equipment. The new equipment will treat the same wastewater and, thus, will not be a new source subject to NSPS requirements.

The CWA requires USEPA to develop effluent limitations, guidelines, and standards (ELGs) representing application of BPT, BAT, BCT, and NSPS. CWA section 402(a)(1) and 40 CFR 125.3 authorize the use of Best Professional Judgment to derive technology-based effluent limitations on a case-by-case basis where ELGs are unavailable for certain industrial categories or pollutants of concern. Where Best Professional Judgment is used, specific factors outlined in 40 CFR 125.3 must be considered.

a. Sanitary Wastewater (Discharge Point No. 001-San)

CWA Section 301(b) and 40 CFR 122.44 require that permits include conditions meeting technology-based requirements, at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge of sanitary wastewater through EFF-001-San must meet the minimum federal technology-based requirements based on Secondary Treatment Standards at 40 CFR 133 summarized below. The 30-day average BOD₅ (or CBOD₅) and TSS percent removal is not to be less than 85 percent.

Table F-8. Secondary Treatment Requirements

Parameter	Units	30-Day Average	7-Day Average
CBOD ₅ ^[1]	mg/L	25	40
BOD ₅	mg/L	30	45
TSS	mg/L	30	45
pH	Standard units	6.0 – 9.0 ^[2]	

Footnotes

^[1] CBOD₅ requirements may be substituted in lieu of BOD requirements consistent with secondary treatment standards in 40 CFR 133.

^[2] Basin Plan Table 4-2 also specifies this pH range.

In addition to these secondary treatment standards, Basin Plan Table 4.2 requires oil and grease concentrations to be less than 10 mg/L (monthly average) and 20 mg/L (daily maximum).

b. Industrial Wastewater (Discharge Point No. 001-Ind)

Although 40 CFR 438 addresses process wastewater from machining operations associated with aircraft there are no technology based standards for industrial wastewaters from airport activities. Where U.S. EPA has not yet developed technology-based standards for a particular industry or a particular pollutant, CWA section 402(a)(1) and 40 CFR 125.3 authorize the use of best professional judgment to derive technology-based effluent limitations on a case-by-case basis. When Best Professional Judgment is used, the permit must reflect specific factors outlined at 40 CFR 125.3. Based on Best Professional Judgment, this Order retains the technology-based limitations from the previous order for BOD₅, TSS, oil and grease, and pH, with one exception related to percent removal of TSS and BOD₅ (discussed below). Although the limitations for process wastewaters from aircraft maintenance do not apply, the limitations in this permit are, in any case, more stringent than those cited in 40 CFR 438.

The previous order identified BOD₅, TSS, oil and grease, and pH as pollutants of concern for the Industrial Plant. Because the Industrial Plant may receive sanitary waste for treatment during periods of maintenance to the Sanitary Plant, secondary treatment standards for BOD₅, TSS, and pH are appropriate when sanitary waste is being directed to the Industrial Plant. In addition to these secondary treatment standards, Basin Plan Table 4.2 requires oil and grease concentrations to be less than 10 mg/L (monthly average) and 20 mg/L (daily maximum).

The Discharger's past performance demonstrates the ability to consistently meet secondary treatment standards and Basin Plan Table 4.2 effluent limitations for POTWs, with some exceptions, for industrial wastewaters. As such, effluent limitations based on secondary treatment standards and Table 4.2 of the Basin Plan, for BOD₅, TSS, oil and grease, and pH, represent the minimum treatment expected from the current treatment system when operated and maintained adequately, and have been established as technology-based effluent limitations in this Order for Discharge Point No. 001-Ind.

The percent removal requirements for TSS and BOD₅ have been removed during periods when the Industrial Plant is not receiving sanitary wastewater. Because much of the Industrial Plant influent is pretreated wastewater and stormwater, influent concentrations of BOD₅ and TSS are typically much lower than those found in sanitary wastewater. (United Airlines has installed a pretreatment facility for its industrial wastewater.) The average monthly influent TSS concentration from March 2010 through March 2011 was 59 mg/L. For comparison, the average monthly TSS influent TSS concentration for the Sanitary Plant was 650 mg/L. These data demonstrate that the Industrial Plant influent is significantly more dilute than the Sanitary Plant influent. The percent removal requirements are retained during periods when sanitary wastewater is being directed to the Industrial Plant, consistent with the secondary treatment standards for sanitary wastewater.

In accordance with CWA 402(o)(2)(A), the removal of the percent removal requirements complies with anti-backsliding requirements because substantial alterations have occurred due to the pretreatment of industrial wastewater by United Airlines, resulting in BOD₅ and TSS concentrations significantly reduced from such concentrations typically

found in sanitary wastewater. For example, wastewater to the Sanitary Plant, in a typical month, has CBOD₅ between 400 and 700 mg/L, and TSS between 450 and 950 mg/L. In contrast, the influent to the Industrial Plant now has BOD₅ between 6 and 20 mg/L and TSS between 30 and 140 mg/L.

In setting the technology-based limitations based on Best Professional Judgment, the Regional Water Board considered the factors specified in 40 CFR 125.3(d), as shown in the table below. Existing control equipment and facilities are practicable and capable of meeting the limitations. The cost of complying with these limitations is reasonable given that the Discharger can comply without modifying its existing operations. No process changes are necessary; therefore, no non-water quality impacts are foreseeable. The limitations are similar to those for secondary treatment of municipal wastewater; thus the cost is comparable to that of a comparable publicly owned treatment works.

Table F-9. Factors Considered Pursuant to 40 CFR 125.3(d)

Factors	Considerations
The reasonableness of costs relative to the benefits derived.	The cost of imposing these limitations is reasonable given that the Discharger can comply without modifying its existing process.
The comparison of the cost and level of reduction of such pollutants from the discharge from publicly owned treatment works to the cost and level of reduction of such pollutants from airport industrial wastewater.	The facility provides secondary treatment of industrial wastewater; therefore, the cost of continuing its operations is comparable to the cost of operating a comparable publicly owned treatment works that treats sanitary wastewater.
Age of equipment and facilities.	The limitations can be met with existing equipment and facilities.
Process employed.	The limitations can be met with the existing process.
Engineering aspects of various controls.	The existing controls are capable of meeting the limitations.
Process changes.	No process changes are necessary to meet the limitations.
Non-water quality environmental impacts.	Because no process changes are necessary, no non-water quality impacts are foreseeable.

2. Applicable Technology-Based Effluent Limitations

a. Sanitary Waste (Discharge Point No. 001-San)

- 1) **CBOD₅ and TSS.** The effluent limitations for CBOD₅ and TSS, including the 85 percent removal requirement, are required by the secondary treatment standards.
- 2) **pH.** Secondary treatment standards and Basin Plan Table 4-2 require effluent limitations for pH.
- 3) **Oil and Grease.** Basin Plan Table 4.2 requires effluent limitations for oil and grease.

b. Industrial Waste (Discharge Point No. 001-Ind)

- 1) **BOD₅ and TSS.** The effluent limitations for BOD₅ and TSS, including the 85 percent removal requirement, are based on Best Professional Judgment and are consistent with effluent limitations established in the previous order. Further, the Discharger occasionally diverts sanitary wastewater from the Sanitary Plant to the Industrial Plant, during which secondary treatment standards discussed above are applicable.

Because the Industrial Plant treats predominantly non-sanitary wastewaters, including at times the captured first flush of stormwater runoff, very low concentrations of BOD₅ would be expected in the influent, making compliance with an 85 percent removal impossible at times. Therefore, this Order retains the condition from the previous order that stipulates that 85 percent reduction in BOD₅ applies only when the BOD₅ influent concentration is greater than 45 mg/L. It would also apply if the Industrial Plant were to treat sanitary wastewater. Under these circumstances, influent BOD concentrations would be determined using a flow weighted average of the influent from the sanitary wastewater collection system, and the influent from the industrial wastewater collection system.

2. Bacteria Limitations (Discharge Point No. 001)

- 1) **Enterococcus Bacteria.** The enterococcus bacteria effluent limitation is based on Basin Plan Table 4-2A.
- 2) **Fecal Coliform Organisms.** Basin Plan Table 4-2A requires total coliform effluent limitations for discharges to receiving waters with the shellfish harvesting beneficial use. Basin Plan Table 4-2A, footnote c, allows substituting total coliform limitations with fecal coliform limitations provided that the substitution will not result in unacceptable adverse impacts on beneficial uses. This Order contains the following fecal coliform effluent limits: the geometric mean fecal coliform density in all samples collected within a calendar month is not to exceed 200 most probable number per 100 mL (MPN/100 mL) and the 90th percentile of the last eleven samples is not to exceed 400 MPN/100 mL.

These limits are equivalent to the Basin Plan Table 3-1 fecal coliform water quality objectives for the water contact beneficial use and will not result in unacceptable adverse impacts on the shellfish harvesting beneficial use. Shellfish beds may be present along the Foster City shoreline, approximately 6.5 miles from the NBSU outfall. The Basin Plan Table 3-1 fecal coliform objectives for shellfish harvesting are a 30-day median of 14 MPN/100 mL and a 90th percentile of 43 MPN/100 mL. This Order's limits protect the shellfish harvesting beneficial use because the effluent is discharged to deep water far from the Foster City shoreline, mixes with San Francisco Bay water at a ratio of at least 74:1, and has no effect on nearby fecal coliform densities.

Several nearby dischargers conducted receiving water impact studies, including the City of San Mateo (November 1997) and the South Bayside System Authority in Redwood City (January 1998). The studies concluded that no relationship exists between effluent and shoreline fecal coliform densities. Apparently, other fecal

coliform sources (e.g., birds, wildlife, urban runoff) more directly affect shoreline fecal coliform densities. The studies evaluated a range of effluent discharges that included fecal coliform densities considerably higher than those allowed by this Order. The San Mateo and South Bayside System Authority outfalls are about 0.75 and 2 miles from the Foster City shoreline. The NBSU outfall is much farther away, so its potential impact on Foster City shoreline fecal coliform densities is even less.

The fecal coliform limits in this Order are retained from the previous order and are consistent with the fecal coliform limits in place since 1998 (see Order No. 98-117).

3. Total Residual Chlorine (Discharge Point No. 002)

The residual chlorine effluent limitation is based on Basin Plan Table 4-2. The allowance for determining false positives using continuous devices is based on the fact that continuous instruments occasionally have anomalous spikes, and it is chemically improbable to have free chlorine present in the presence of sodium bisulfite.

C. Water Quality-Based Effluent Limitations (WQBELs) for Toxic Substances

WQBELs have been derived for toxic pollutants to implement WQOs that protect beneficial uses. Both the beneficial uses and the WQOs have been approved pursuant to federal law. The procedures for calculating individual WQBELs are based on the SIP and the Basin Plan. Most Basin Plan beneficial uses and WQOs were approved under State law and submitted to and approved by USEPA prior to May 30, 2000. Any WQOs and beneficial uses submitted to USEPA prior to May 30, 2000, but not approved by USEPA before that date, are nonetheless “applicable water quality standards for purposes of the [Clean Water] Act” pursuant to 40 CFR 131.21(c)(1). Collectively, this Order’s restrictions on individual pollutants are no more stringent than those required to implement water quality standards for CWA purposes.

1. Scope and Authority

- a. NPDES regulations at 40 CFR 122.44(d)(1)(i) mandate that permits include effluent limitations for all pollutants, , that are or may be discharged at levels that have reasonable potential to cause or contribute to an excursion of a water quality standard, including numeric and narrative objectives within a standard. As specified in 40 CFR 122.44(d)(1)(i), permits are required to include WQBELs for all pollutants “which the Director determines are or may be discharged at a level that will cause, have the reasonable potential to cause, or contribute to an excursion above any State water quality standard.”

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated beneficial uses of the receiving water as specified in the Basin Plan, and achieve applicable WQOs contained in the CTR, NTR, and other state plans and policies.

- b. NPDES regulations and the SIP provide the basis to establish Maximum Daily Effluent Limitations (MDELs) and Average Monthly Effluent Limitations (AMELs).

(1) **NPDES Regulations.** NPDES regulations at 40 CFR 122.45(d) state, “For continuous discharges all permit effluent limitations, standards, and prohibitions, including those necessary to achieve water quality standards, shall *unless impracticable* be stated as MDELs and AMELs for all discharges other than publicly owned treatment works.”

(2) **SIP.** SIP section 1.4 requires that WQBELs be expressed as MDELs and AMELs.

c. MDELs are necessary in this Order to protect against acute water quality effects. The MDELs are necessary for preventing fish kills or mortality to aquatic organisms.

2. Beneficial Uses and Water Quality Objectives

The WQOs that apply to the receiving waters for this discharge are from the Basin Plan; the CTR, established by USEPA at 40 CFR 131.38; and the NTR, established by USEPA at 40 CFR 131.36. Some pollutants have WQOs established by more than one of these sources.

a. **Basin Plan.** The Basin Plan specifies numeric WQOs for 10 priority toxic pollutants, as well as narrative WQOs for toxicity and bioaccumulation in order to protect beneficial uses. The pollutants for which the Basin Plan specifies numeric objectives are arsenic, cadmium, chromium (VI), copper in marine and freshwater, lead, mercury, nickel, silver, zinc, and cyanide. The narrative toxicity objective states, in part, “All waters shall be maintained free of toxic substances in concentrations that are lethal to or that produce other detrimental responses in aquatic organisms.” The bioaccumulation objective states, in part, “Controllable water quality factors shall not cause a detrimental increase in concentrations of toxic substances found in bottom sediments or aquatic life. Effects on aquatic organisms, wildlife, and human health will be considered.” Effluent limitations and provisions contained in this Order implement these WQOs, based on available information.

b. **CTR.** The CTR specifies numeric aquatic life criteria for 23 priority toxic pollutants and numeric human health criteria for 57 priority toxic pollutants. These criteria apply to all inland surface waters and enclosed bays and estuaries of the San Francisco Bay Region, although Basin Plan Tables 3-3 and 3-4 include numeric objectives for certain of these priority toxic pollutants that supersede the CTR criteria. Human health criteria are further identified as for “water and organisms” and “organisms only.” the CTR criteria applicable to “organisms only” apply to the receiving water because it is not a source of drinking water.

c. **NTR.** The NTR establishes numeric aquatic life criteria for selenium, numeric aquatic life and human health criteria for cyanide, and numeric human health criteria for 33 other toxic organic pollutants for waters of San Francisco Bay and upstream to, and including, Suisun Bay and the Sacramento River-San Joaquin River Delta.

d. **Sediment Quality Objectives.** The *Water Quality Control Plan for Enclosed Bays and Estuaries—Part 1, Sediment Quality* contains a narrative WQO, “Pollutants in sediments shall not be present in quantities that, alone or in combination, are toxic to benthic communities in bays and estuaries of California.” This WQO is to be implemented by

integrating three lines of evidence: sediment toxicity, benthic community condition, and sediment chemistry. The Policy requires that if the Regional Water Board determines that a discharge has reasonable potential to cause or contribute to an exceedance of this WQO, it is to impose the WQO as a receiving water limit.

- e. **Basin Plan Receiving Water Salinity Policy.** The Basin Plan (like the CTR and the NTR) states that the salinity characteristics (i.e., freshwater vs. saltwater) of the receiving water are to be considered in determining the applicable WQOs. Freshwater criteria apply to discharges to waters with salinities equal to or less than one part per thousand (ppt) at least 95 percent of the time. Saltwater criteria apply to discharges to waters with salinities equal to or greater than 10 ppt at least 95 percent of the time in a normal water year. For discharges to water with salinities in between these two categories, or tidally influenced fresh waters that support estuarine beneficial uses, the WQOs are the lower of the salt or freshwater criteria (the latter calculated based on ambient hardness) for each substance.

The receiving water for the Facility discharge is Lower San Francisco Bay, is an estuarine environment based on salinity data generated through the San Francisco Estuary Institute (SFEI) Regional Monitoring Program (RMP) at the Oyster Bay (BB30) sampling station between 1993 and 2001. During that period, the receiving water's minimum salinity was 5.4 ppt, its maximum salinity was 31 ppt, and its average salinity was 23.9 ppt. Because the salinity was greater than 10 ppt in 96 percent of receiving water samples, the saltwater objectives from the Basin Plan, NTR, and CTR apply to this discharge and were used for the reasonable potential analysis.

- f. **Site-Specific Metal Translators.** NPDES regulations at 40 CFR 122.45(c) require that effluent limitations for metals be expressed as total recoverable metal. Since applicable water quality objectives for metals are typically expressed as dissolved metal, translators must be used to convert metals concentrations from dissolved to total recoverable and vice versa. The CTR includes default translators; however, site-specific conditions, such as water temperature, pH, suspended solids, and organic carbon greatly affect the form of metal (dissolved, non-filterable, or otherwise) present in the water and therefore available to cause toxicity. In general, the dissolved form of the metal is more available and more toxic to aquatic life than non-filterable forms. Site-specific translators can be developed to account for site-specific conditions, thereby preventing exceedingly stringent or under protective water quality objectives. For deep water discharges to Lower San Francisco Bay, the Basin Plan translators for copper are 0.73 and 0.87 (AMEL and MDEL) (Basin Plan Table 7.2-2). The translators for nickel, based on recommendations of the Clean Estuary Partnership's *North of Dumbarton Bridge Copper and Nickel Development and Selection of Final Translators* (March 2005), are 0.65 and 0.85 (AMEL and MDEL).

3. Determining the Need for WQBELs

Assessing whether a pollutant has Reasonable Potential is the fundamental step in determining whether or not a WQBEL is required.

- a. **Reasonable Potential Analysis (RPA).**

For priority pollutants and most other toxic pollutants, the RPA identifies the observed maximum effluent concentration (MEC) in the effluent for each pollutant based on effluent concentration data. There are three triggers in determining Reasonable Potential according to SIP Section 1.3.

- (1) Trigger 1 is activated if the MEC is greater than or equal to the lowest applicable WQO ($MEC \geq WQO$), which has been adjusted, if appropriate, for pH, hardness, and translator data. If the MEC is greater than the adjusted WQO, then that pollutant has Reasonable Potential, and a WQBEL is required.
- (2) Trigger 2 is activated if the observed maximum ambient background concentration (B) is greater than the adjusted WQO ($B > WQO$) and the pollutant is detected in any of the effluent samples.
- (3) Trigger 3 is activated if a review of other information determines that a WQBEL is required to protect beneficial uses, even though both MEC and B are less than the WQO

b. Effluent Data

The Discharger's priority pollutant data and the nature of the discharge were analyzed to determine if the discharge has reasonable potential. The RPA is based on effluent monitoring data the Discharger collected from January 2007 to December 2011.

c. Ambient Background Data

The SIP states that for calculating WQBELs, ambient background concentrations are either the observed maximum ambient water column concentrations or, for objectives intended to protect human health from carcinogens, the arithmetic mean of observed ambient water concentrations.

On May 15, 2003, a group of several San Francisco Bay Region dischargers (known as the Bay Area Clean Water Agencies, or BACWA) submitted a collaborative receiving water study, entitled the *San Francisco Bay Ambient Water Monitoring Interim Report* (2003). This study includes monitoring results from sampling events in 2002 and 2003 for the remaining priority pollutants not monitored by the RMP. This study included the Yerba Buena Island RMP station. The BACWA provided additional data through its *Ambient Water Monitoring: Final CTR Sampling Update*, dated June 15, 2004.

For priority pollutants, the RPA was conducted and WQBELs were calculated using RMP data from 1993 through 2010 at the Yerba Buena Island RMP station (BC10), and additional data from the BACWA study. When using data from this station, the maximum dilution allowed for calculating limits is 10:1,

Receiving water data for ammonia was from the Oyster Bay Monitoring Station (BB30) from 1993 through 2001. Because the actual dilution at the outfall of 74:1 was used to calculate ammonia limits, this station, which is closer to the outfall than BC10, was used.

d. Reasonable Potential Determination.

The MECs, most stringent applicable WQOs, and background concentrations used in the RPA are presented in the table below, along with the RPA result (yes or no) for each pollutant analyzed. Reasonable Potential was not determined for all pollutants because WQOs do not exist for all pollutants and monitoring data was unavailable for others. The RPA determined that copper, cyanide, dioxin-TEQ, selenium, zinc, and ammonia demonstrate Reasonable Potential.

Table F-10. Summary of RPA Results

CTR #	Priority Pollutants	MEC or Min. DL ^{[1],[2]} (µg/L)	Governing WQO / WQC (µg/L)	Max. Background or Min. DL ^{[1],[2]} (µg/L)	RPA Results ^[3]
1	Antimony	1.6	4,300	1.8	No
2	Arsenic	9.5	36	2.5	No
3	Beryllium	0.026	No Criteria	0.22	No
4	Cadmium	4.1	9.36	0.13	No
5a	Chromium (III)	NA	No Criteria	4.4	No
5b	Chromium (VI)	4.16	50	4.4	No
6	Copper	11	8.2	2.5	Yes
7	Lead	3.3	8.5	0.8	No
9	Nickel	5.9	12.6	3.7	No
10	Selenium	5.38	5.0	0.39	Yes
11	Silver	0.63	2.2	0.052	No
12	Thallium	0.069	6.3	0.21	No
13	Zinc	340	196	5	Yes
14	Cyanide	6.5	2.9	<0.4	Yes^[4]
15	Asbestos	NA	No Criteria	Not Available	Ud
16	2,3,7,8-TCDD (303(d) listed)	<5.8E10 ⁻⁷	1.4E10 ⁻⁸	8.20E ⁻⁹	No
	Dioxin TEQ (303d listed)	9.2E10⁻⁷	1.4E10⁻⁸	5.3E10⁻⁸	Yes
17	Acrolein	<0.45	780	<0.5	No
18	Acrylonitrile	<0.17	0.66	0.03	No
19	Benzene	<0.051	71	,0.05	No
20	Bromoform	1.4	360	<0.5	No
21	Carbon Tetrachloride	<0.068	4.4	0.06	No
22	Chlorobenzene	1.5	21,000	<0.5	No
23	Chlorodibromomethane	1.4	34	<0.05	No
24	Chloroethane	<0.12	No Criteria	<0.5	Ud
25	2-Chloroethylvinyl ether	<0.093	No Criteria	<0.5	Ud
26	Chloroform	2.3	No Criteria	<0.5	Ud
27	Dichlorobromomethane	2	46	<0.05	No
28	1,1-Dichloroethane	<0.047	No Criteria	<0.05	Ud
29	1,2-Dichloroethane	<0.052	99	0.04	No
30	1,1-Dichloroethylene	<0.038	3.2	<0.5	No
31	1,2-Dichloropropane	<0.038	39	<0.05	No
32	1,3-Dichloropropylene	<0.053	1,700	<0.5	No
33	Ethylbenzene	0.059	29,000	<0.5	No
34	Methyl Bromide	<0.067	4,000	<0.5	No
35	Methyl Chloride	0.17	No Criteria	<0.5	Ud
36	Methylene Chloride	<0.032	1,600	22	No
37	1,1,2,2-Tetrachloroethane	<0.064	11	<0.05	No
38	Tetrachloroethylene	<0.087	8.9	<0.05	No

CTR #	Priority Pollutants	MEC or Min. DL ^{[1],[2]} (µg/L)	Governing WQO / WQC (µg/L)	Max. Background or Min. DL ^{[1],[2]} (µg/L)	RPA Results ^[3]
39	Toluene	<0.06	200,000	<0.3	No
40	1,2-Trans-Dichloroethylene	<0.053	140,000	<0.5	No
41	1,1,1-Trichloroethane	<0.064	No Criteria	<0.5	Ud
42	1,1,2-Trichloroethane	<0.053	42	<0.05	No
43	Trichloroethylene	<0.058	81	<0.5	No
44	Vinyl Chloride	<0.14	530	<0.5	No
45	2-Chlorophenol	<0.15	400	<1.2	No
46	2,4-Dichlorophenol	<0.23	790	<1.3	No
47	2,4-Dimethylphenol	<0.22	2,300	<1.3	No
48	2-Methyl- 4,6-Dinitrophenol	<0.33	760	<1.2	No
49	2,4-Dinitrophenol	<0.23	14,000	<0.7	No
50	2-Nitrophenol	<0.2	No Criteria	<1.3	Ud
51	4-Nitrophenol	<0.27	No Criteria	<1,6	Ud
52	3-Methyl 4-Chlorophenol	<0.21	No Criteria	<1.1	Ud
53	Pentachlorophenol	<0.23	7.9	<1.0	No
54	Phenol	<0.22	4,600,000	<1.3	No
55	2,4,6-Trichlorophenol	<0.22	6.5	<1.3	No
56	Acenaphthene	<0.23	2,700	0.0019	No
57	Acenaphthylene	<0.22	No Criteria	0.0013	Ud
58	Anthracene	<0.002	110,000	0.00059	No
59	Benzidine	<0.052	0.00054	<0015	No
60	Benzo(a)Anthracene	<0.002	0.049	0.0053	No
61	Benzo(a)Pyrene	<0.002	0.049	0.0033	No
62	Benzo(b)Fluoranthene	<0.13	0.049	0.0046	No
63	Benzo(ghi)Perylene	<0.002	No Criteria	0.0045	Ud
64	Benzo(k)Fluoranthene	0.002	0.049	0.0018	No
65	Bis(2-Chloroethoxy)Methane	<0.24	No Criteria	<0.3	Ud
66	Bis(2-Chloroethyl)Ether	<0.19	1.4	<0.00015	No
67	Bis(2-Chloroisopropyl)Ether	<0.19	170,000	Not Available	No
68	Bis(2-Ethylhexyl)Phthalate	0.81	5.9	<0.0002	No
69	4-Bromophenyl Phenyl Ether	<0.12	No Criteria	<0.23	Ud
70	Butylbenzyl Phthalate	<0.46	5,200	0.0056	No
71	2-Chloronaphthalene	<0.19	4,300	<0.3	No
72	4-Chlorophenyl Phenyl Ether	<0.001	No Criteria	<0.3	Ud
73	Chrysene	<0.002	0.049	0.0028	No
74	Dibenzo(a,h)Anthracene	<0.001	0.049	0.00064	No
75	1,2-Dichlorobenzene	<0.17	17,000	<0.3	No
76	1,3-Dichlorobenzene	<0.12	2,600	<.0.3	No
77	1,4-Dichlorobenzene	0.23	2,600	<0.3	No
78	3,3 Dichlorobenzidine	<0.41	0.077	<0.001	No
79	Diethyl Phthalate	2.4	120,000	<0.21	No
80	Dimethyl Phthalate	<0.29	2,900,000	<0.21	No
81	Di-n-Butyl Phthalate	NA	12,000	0.016	No
82	2,4-Dinitrotoluene	<0.23	9.1	<0.27	No
83	2,6-Dinitrotoluene	<0.16	No Criteria	<0.29	No
84	Di-n-Octyl Phthalate	<0.036	No Criteria	<0.38	No
85	1,2-Diphenylhydrazine	NA	0.54	0.0037	No
86	Fluoranthene	<0.014	370	0.011	No
87	Fluorene	<0.24	14,000	0.0021	No
88	Hexachlorobenzene	<0.15	0.00077	0.000022	No
89	Hexachlorobutadiene	<0.15	50	<0.3	No

CTR #	Priority Pollutants	MEC or Min. DL ^{[1],[2]} (µg/L)	Governing WQO / WQC (µg/L)	Max. Background or Min. DL ^{[1],[2]} (µg/L)	RPA Results ^[3]
90	Hexachlorocyclopentadiene	<0.11	17,000	<0.3	No
91	Hexachloroethane	<0.13	8.9	<0.2	No
92	Indeno(1,2,3-cd)Pyrene	<0.25	0.049	0.0040	No
93	Isophorone	<0.23	600	<0.3	No
94	Naphthalene	<0.23	No Criteria	0.013	Ud
95	Nitrobenzene	<0.2	1,900	<0.25	No
96	N-Nitrosodimethylamine	<0.06	8.1	<0.3	No
97	N-Nitrosodi-n-Propylamine	<0.21	1.4	<0.001	No
98	N-Nitrosodiphenylamine	<0.09	16	<0.001	No
99	Phenanthrene	<0.01	No Criteria	0.010	No
100	Pyrene	<0.13	11,000	0.019	No
101	1,2,4-Trichlorobenzene	<0.2	No Criteria	<0.3	Ud
102	Aldrin	<0.00075	0.00014	0.0000028	No
103	Alpha-BHC	<0.00059	0.013	0.00050	No
104	beta-BHC	<0.0004	0.046	0.00041	No
105	gamma-BHC	<0.0005	0.063	0.00070	No
106	delta-BHC	<0.00051	No Criteria	0.000053	Ud
107	Chlordane (303d listed)	<0.0014	0.00059	0.00018	No
108	4,4'-DDT (303d listed)	<0.00093	0.00059	0.00017	No
109	4,4'-DDE (linked to DDT)	<0.00038	0.00059	0.00069	No
110	4,4'-DDD	<0.00208	0.00084	0.00031	No
111	Dieldrin (303d listed)	<0.00056	0.00014	0.00026	No
112	Alpha-Endosulfan	<0.00048	0.0087	0.000031	No
113	beta-Endosulfan	<0.00071	0.0087	0.000069	No
114	Endosulfan Sulfate	<0.00284	240	0.000082	No
115	Endrin	<0.00091	0.0023	0.000040	No
116	Endrin Aldehyde	<0.00089	0.81	Not Available	No
117	Heptachlor	<0.00013	0.00021	0.000019	No
118	Heptachlor Epoxide	<0.00056	0.00011	0.000094	No
126	Toxaphene	<0.032	0.0002	Not Available	No
127	Tributyltin	<0.00034	0.0074	Not Available	No
128	Total PAHs	NA	15	Not Available	No
129	Total Ammonia (mg/L)	90	1.6	0.21	Yes

Footnotes

- ^[1] The MEC or maximum background concentration is the actual detected concentration unless there is a “<” sign before it, in which case the value shown is the minimum detection level.
- ^[2] The MEC or maximum background concentration is “Not Available” when there are no monitoring data for the constituent.
- ^[3] RPA Results =Yes, if MEC => WQO/WQC, or B > WQO/WQC and MEC is detected;
 = No, if MEC and B are < WQO/WQC or all effluent data are undetected;
 = Undetermined (Ud), if no criteria have been promulgated;
 = Cannot Determine, if there are insufficient data.
- ^[4] Based on Section 4.7.2.2 of the Basin Plan.

(1) Constituents with limited data. In some cases, reasonable potential cannot be determined because effluent data are limited, or ambient background concentrations are unavailable. The Discharger will continue to monitor for these constituents in the effluent using analytical methods that provide the best feasible detection limitations. When additional data become available, further RPA will be conducted to determine whether numeric effluent limitations are necessary.

(2) Pollutants with no Reasonable Potential. WQBELs are not included in this Order for constituents that do not demonstrate Reasonable Potential; however, monitoring for those pollutants is still required. If concentrations of these constituents are found to have increased significantly the Discharger is required to investigate the sources of the increases. Remedial measures are required if the increases would cause an exceedance of the water quality objectives in receiving water.

e. RPA for Sediment Quality Objectives. Pollutants in some receiving water sediments may be present in quantities that alone or in combination are toxic to benthic communities. Efforts are underway to identify stressors causing such conditions. However, to date there is no evidence directly linking compromised sediment conditions to the discharge subject to this Order; therefore the Regional Water Board cannot draw a conclusion about reasonable potential for the discharges to cause or contribute to exceedances of the sediment quality objectives. Nevertheless, the Discharger continues to participate in the RMP, which monitors San Francisco Bay sediment and seeks to identify stressors responsible for degraded sediment quality. Thus far, the monitoring has provided only limited information about potential stressors and sediment transport. The Regional Water Board is exploring options for obtaining additional information that may inform future RPAs.

4. WQBEL Calculations

a. Pollutants with Reasonable Potential. WQBELs were developed for the toxic and priority pollutants that were determined to have Reasonable Potential to cause or contribute to WQO exceedances. The WQBELs were calculated based on WQOs and the procedures specified in SIP Section 1.4. The WQOs used for each pollutant with Reasonable Potential (ammonia, copper, cyanide, dioxin-TEQ, selenium, and zinc) are discussed below.

b. Dilution Credit. The SIP allows dilution credits for completely-mixed discharges, and under certain circumstances for incompletely-mixed discharges. Airfield Development Engineering Consultant conducted an engineering study on dilution, on behalf of the North Bayside System Unit, and submitted it on December 12, 2000. This was part of a larger study to estimate hydrodynamic impacts on San Francisco Bay by the proposed runway extension. The discharge is pumped through a 60” pipe to a 650-ft diffuser section located approximately 5,200 feet offshore, at a depth of 20 feet below mean lower low water, from Point San Bruno. The diffuser consists of 66 three-inch openings spaced 7 feet apart. The CORMIX model was used to estimate mixing of the effluent under tidal conditions. At a point in the immediate vicinity of the diffuser the instant dilution was calculated to be 74:1.

(1) Bioaccumulative Pollutants. For certain bioaccumulative pollutants, dilution credit is strictly restricted or denied. Specifically, these pollutants include, dioxin and furan compounds, which appear on the CWA section 303(d) list for the Lower San Francisco Bay because, based on available data on concentrations of these pollutants in aquatic organisms, sediment, and the water column, they impair San Francisco Bay beneficial uses. The following factors suggest insufficient assimilative capacity in San Francisco Bay for these pollutants.

Tissue samples taken from fish in San Francisco Bay show the presence of these pollutants at concentrations greater than screening levels (*Contaminant Concentrations in Fish from San Francisco Bay*, May 1997). The results of a 1994 San Francisco Bay pilot study, presented in *Contaminated Levels in Fish Tissue from San Francisco Bay* (Regional Water Board, 1994) also showed elevated levels of chemical contaminants in fish tissues. The Office of Environmental Health and Hazard Assessment completed a preliminary review of the data in the 1994 report and in December 1994 issued an interim consumption advisory covering certain fish species in San Francisco Bay due to the levels of some of these pollutants. The Office of Environmental Health and Hazard Assessment updated this advisory by issuing its May 2011 report *Health Advisory and Safe Eating Guidelines for San Francisco Bay Fish and Shellfish*, which still suggests insufficient assimilative capacity in San Francisco Bay for 303(d)-listed pollutants. Therefore, dilution credits are denied for bioaccumulative pollutants on the 303(d) list for which data are lacking on sources and significant uncertainty about how different sources of these pollutants contribute to bioaccumulation.

- (2) **Non-Bioaccumulative Pollutants.** For non-bioaccumulative pollutants, except ammonia, a conservative dilution allowance of 10:1 ($D = 9$) has been assigned. The 10:1 dilution allowance is consistent with the previous orders and is based, in part, on Basin Plan Prohibition 1 (Table 4-1), which prohibits discharges with less than 10:1 dilution. SIP Section 1.4.2 allows for limiting the dilution credit. The dilution credit is limited for the following reasons:
- (a) San Francisco Bay is a very complex estuarine system with highly variable and seasonal upstream freshwater inflows and diurnal tidal saltwater inputs. SIP Section 1.4.3 allows background conditions to be determined on a discharge-by-discharge or water body-by-water body basis. A water body-by-water body basis approach is taken here due to inherent uncertainties in characterizing ambient background conditions in a complex estuarine system on a discharge-by-discharge basis. The Yerba Buena Island RMP monitoring station, relative to other RMP stations, fits SIP guidance criteria for establishing background conditions. The SIP requires that background water quality data be representative of the ambient receiving water that will mix with the discharge. Water quality data from the Yerba Buena Island monitoring station is recognized as the standard for water that will mix with the discharge under conditions of 10:1 dilution.
 - (b) Because of the complex hydrology of San Francisco Bay, there are uncertainties in accurately determining an appropriate mixing zone. The models used to predict dilution do not consider the three dimensional nature of San Francisco Bay currents resulting from the interaction of tidal flushes and seasonal fresh water outflows. Being heavier and colder than fresh water, ocean salt water enters San Francisco Bay on a twice-daily tidal cycle, generally beneath the warmer fresh water that flows seaward. When these waters mix and interact, complex circulation patterns occur due to varying densities of the fresh and ocean waters. The complex patterns occur throughout San Francisco Bay, but are most prevalent in the San Pablo, Carquinez Strait, and Suisun Bay areas. The locations of this

mixing and interaction change, depending on the strength of each tide. Additionally, sediment loads from the Central Valley change on a long-term basis, affecting the depth of different parts of San Francisco Bay, resulting in alteration of flow patterns, mixing, and dilution at the outfall.

- (c) For ammonia, a conservative estimate of actual initial dilution was used to calculate the effluent limitations. This is justified because ammonia, a non-persistent pollutant, quickly disperses and degrades to a non-toxic state, and cumulative toxicity effects are unlikely. Based on the Discharger's report, the Discharger used the CORMIX model to determine a minimum initial dilution of 74:1.

c. Calculation of Pollutant-Specific WQBELs

(1) Copper

- (a) **WQOs.** The Basin Plan contains chronic and acute marine WQOs for cyanide of 6.0 and 9.4 $\mu\text{g/L}$, expressed as dissolved metal and accounting for a Water Effects Ratio of 2.4 (Basin Plan Table 3-3A). Converting these WQOs to total recoverable metal using the site-specific translators of 0.73 (chronic) and 0.87 (acute), results in a translated acute WQO of 11 $\mu\text{g/L}$ and chronic WQO of 8.2 $\mu\text{g/L}$.
- (b) **RPA Results.** This Order establishes effluent limitations for copper because the MEC (11 $\mu\text{g/L}$) exceeds the governing WQO (8.2 $\mu\text{g/L}$), demonstrating Reasonable Potential by Trigger 1, and because Basin Plan section 7.2.1.2 requires that NPDES permits for municipal and industrial wastewater treatment facilities discharging to San Francisco Bay include copper WQBELs.
- (c) **WQBELs.** Copper WQBELs, calculated according to SIP procedures with an effluent data coefficient of variation (CV) of 0.41 and a dilution credit of $D = 9$ (dilution ratio = 10:1), are an AMEL of 50 $\mu\text{g/L}$ and an MDEL of 85 $\mu\text{g/L}$. The previous orders established an AMEL of 42 $\mu\text{g/L}$ and an MDEL 84 $\mu\text{g/L}$. The newly calculated effluent limitations are less stringent than the effluent limitations in the previous orders. This Order retains the more stringent effluent limitations.
- (d) **Anti-backsliding.** Anti-backsliding requirements are satisfied because the limitations for copper are the same as the limitations in the previous orders.

(2) Cyanide

- (a) **WQOs.** The Basin Plan contains chronic and acute marine WQOs for cyanide of 2.9 $\mu\text{g/L}$ and 9.4 $\mu\text{g/L}$ (site-specific objectives for San Francisco Bay).
- (b) **RPA Results.** This Order establishes effluent limitations for cyanide because the MEC (6.5 $\mu\text{g/L}$) exceeds the governing WQO (2.9 $\mu\text{g/L}$), demonstrating Reasonable Potential by Trigger 1, and because Basin Plan section 7.2.2.2

requires that NPDES permits for municipal and industrial wastewater treatment facilities discharging to San Francisco Bay include cyanide WQBELs.

- (c) **WQBELs.** Cyanide WQBELs, calculated according to SIP procedures with a CV of 0.72 and a dilution credit of $D = 9$, are an AMEL of 20 $\mu\text{g/L}$ and a MDEL of 44 $\mu\text{g/L}$. The previous orders established an AMEL of 20 $\mu\text{g/L}$ and a MDEL of 44 $\mu\text{g/L}$. The limits in this Order are, therefore, unchanged.
- (d) **Anti-backsliding.** Anti-backsliding requirements are satisfied because the cyanide limits are the same as those in the previous orders.

(3) Dioxin – TEQ

- (a) **WQO.** The Basin Plan narrative WQO for bioaccumulative substances states, “Many pollutants can accumulate on particulates, in sediments, or bioaccumulate in fish and other aquatic organisms. Controllable water quality factors shall not cause a detrimental increase in concentrations of toxic substances found in bottom sediments or aquatic life. Effects on aquatic organisms, wildlife, and human health will be considered.”

Because it is the consensus of the scientific community that dioxins and furans associate with particulates, accumulate in sediments, and bioaccumulate in the fatty tissue of fish and other organisms, the Basin Plan’s narrative bioaccumulation WQO is applicable to these pollutants. Elevated levels of dioxins and furans in fish tissue in San Francisco Bay demonstrate that the narrative bioaccumulation WQO is not being met. USEPA has therefore included San Francisco Bay as impaired by dioxin and furan compounds in the current 303(d) listing of receiving waters, where water quality objectives are not being met after imposition of applicable technology-based requirements.

The CTR establishes a numeric WQO for 2,3,7,8-tetrachlorinated dibenzo-p-dioxin (2,3,7,8-TCDD) of 1.4×10^{-8} $\mu\text{g/L}$ for the protection of human health, when aquatic organisms are consumed. When the CTR was promulgated, USEPA stated its support of the regulation of other dioxin and dioxin-like compounds through the use of toxicity equivalencies (TEQs) in NPDES permits. For California waters, USEPA stated specifically, “if the discharge of dioxin or dioxin-like compounds has reasonable potential to cause or contribute to a violation of a narrative criterion, numeric WQBELs for dioxin or dioxin-like compounds should be included in NPDES permits and should be expressed using a TEQ scheme” (65 Fed. Reg. 31682, 31695 [2000]).

This Order uses a TEQ scheme based on a set of toxicity equivalency factors (TEFs) the World Health Organization (WHO) developed in 1998, and a set of bioaccumulation equivalency factors (BEFs) USEPA developed for the Great Lakes region (40 CFR 132, Appendix F) to convert the concentration of any congener of dioxin or furan into an equivalent concentration of 2,3,7,8-TCDD. The CTR criterion is used as a criterion for dioxin-TEQ because dioxin-TEQ represents a toxicity weighted concentration equivalent to 2,3,7,8-TCDD, thus

translating the narrative bioaccumulation objective into a numeric criterion appropriate for the RPA.

To determine if the discharge of dioxin or dioxin-like compounds has Reasonable Potential, TEFs and BEFs were used to express the measured concentrations of 16 dioxin congeners in effluent and background samples as 2,3,7,8-TCDD. These “equivalent” concentrations were then compared to the CTR numeric criterion for 2,3,7,8-TCDD (1.4×10^{-8} µg/L). Although the 1998 WHO scheme includes TEFs for dioxin-like PCBs, they are not included in this Order’s TEQ scheme. The CTR has established a specific water quality standard for PCBs, and dioxin-like PCBs are included in the analysis of total PCBs.

- (b) **RPA Results.** This Order establishes effluent limitations for dioxin-TEQ because the MEC (9.2×10^{-7} µg/L) exceeds the governing WQO (1.4×10^{-8} µg/L), demonstrating Reasonable Potential by Trigger 1.
- (c) **WQBELs.** Dioxin-TEQ WQBELs, calculated according to SIP procedures with a default CV of 0.6 and no dilution credit, are an AMEL of 1.4×10^{-8} µg/L and an MDEL of 2.8×10^{-8} µg/L.
- (d) **Feasibility of Compliance.** The previous orders provided a compliance schedule through September 30, 2017, to comply with final effluent limitations for dioxin-TEQ; however, effluent data over the current permit term indicate no dioxin congeners greater than the applicable minimum levels, as prescribed in Attachment G. Using detected but not quantifiable data (j-flags), the Discharger’s MEC was 9.2×10^{-7} µg/L; however, as specified in Attachment G, j-flag data are not used for compliance determination. Further, the last two years of data indicate no detectable concentrations of dioxin congeners. Thus, it appears feasible for the Discharger to comply with the dioxin-TEQ WQBELs using the reporting method specified in Attachment G, and the compliance schedule established in the previous orders is not retained.
- (e) **Anti-backsliding.** Anti-backsliding requirements are satisfied because the dioxin-TEQ limitations are the same as those in the previous orders.

(4) Selenium

- (a) **WQOs.** The CTR contains chronic and acute marine WQOs for selenium of 20 µg/L and 5 µg/L.
- (b) **RPA Results.** This Order establishes effluent limitations for selenium because the MEC (5.3 µg/L) exceeds the governing WQO (5 µg/L), demonstrating reasonable potential by Trigger 1.
- (c) **WQBELs.** Selenium WQBELs, calculated according to SIP procedures with an effluent data CV of 1.9 and a dilution credit of $D = 0$, are an AMEL of 2.9 µg/L and an MDEL of 8.8 µg/L. Based on a review of 60 available data points, only one data point was observed above the proposed AMEL and MDEL.

- (d) **Feasibility of Compliance.** A feasibility analysis was conducted comparing the 95th percentile of the data (1.0 µg/L) to the AMEL (2.9 µg/L) and the 99th percentile of the data (3.6 µg/L) to the MDEL (8.8 µg/L). The Discharger is expected to be able to comply with the new AMEL and MDEL immediately.
- (e) **Anti-backsliding.** Anti-backsliding requirements are satisfied because the previous orders did not establish selenium effluent limitations.

(5) Zinc

- (a) **WQOs.** The CTR contains chronic and acute marine WQOs for zinc of 86 µg/L and 95 µg/L.
- (b) **RPA Results.** This Order establishes zinc effluent limitations because the MEC (340 µg/L) exceeds the governing WQO (86 µg/L), demonstrating reasonable potential by Trigger 1.
- (c) **WQBELs.** Zinc WQBELs, calculated according to SIP procedures with an effluent data CV of 1.1 and a dilution credit of $D = 9$, are an AMEL of 350 µg/L and an MDEL of 910 µg/L.
- (d) **Anti-backsliding.** Anti-backsliding requirements are satisfied because the previous orders did not establish zinc effluent limitations.

(6) Total Ammonia

- (a) **WQOs.** The Basin Plan contains WQOs for un-ionized ammonia of 0.025 mg/L as an annual median and 0.4 mg/L as a maximum in Lower San Francisco Bay. These WQOs were translated from un-ionized ammonia concentrations to equivalent total ammonia concentrations (as nitrogen) since (1) sampling and laboratory methods are not available to analyze for un-ionized ammonia; and (2) the fraction of total ammonia that exists in the toxic un-ionized form depends on the pH, salinity, and temperature of the receiving water.

To translate the Basin Plan un-ionized ammonia objective, pH, salinity, and temperature data from 1993 through 2001 from the nearest RMP station to the outfall, the Oyster Bay RMP Station (BB30) were used. The following equations were used to determine the fraction of total ammonia that would exist in the toxic un-ionized form in the marine receiving water where the various measurements were taken from 1994-2001 (USEPA, 1989, *Ambient Water Quality Criteria for Ammonia (Saltwater)*–1989, EPA Publication 440/5-88-004):

$$\text{For salinity} > 10 \text{ ppt: fraction of NH}_3 = \frac{1}{1 + 10^{(pK - pH)}}$$

Where:

$$pK = 9.245 + 0.116(I) + 0.0324 (298 - T) + \frac{0.0415(P)}{(T)}$$

$$I = \text{Molal ionic strength of saltwater} = \frac{19.9273(S)}{(1,000 - 1.005109(S))}$$

S = Salinity (parts per thousand)

T = Temperature in degrees Kelvin

P = Pressure (one atmosphere)

The 90th percentile and median un-ionized ammonia fractions were then used to express the daily maximum and the annual average un-ionized objectives as acute and chronic total ammonia objectives. This approach is consistent with USEPA guidance on translating dissolved metal WQOs to total recoverable metal WQOs (USEPA, 1996, *The Metals Translator: Guidance for Calculating a Total Recoverable Limit from a Dissolved Criterion*, EPA Publication 823-B-96-007.)

The equivalent total ammonia chronic and acute criteria are 1.6 mg/L and 14 mg/L.

- (b) **RPA Results.** Based on Basin Plan section 4.5.5.2, the SIP methodology was used as guidance to perform the RPA and to calculate total ammonia effluent limitations. This Order establishes effluent limitations for total ammonia because the MEC of 90 mg/L (as N) exceeds the translated WQO (1.6 mg/L), demonstrating Reasonable Potential by Trigger 1.
- (c) **WQBELs.** Total ammonia WQBELs were calculated separately for chronic and acute conditions. The WQBELs are based on the more stringent chronic results. The WQBELs, calculated according to SIP procedures with an effluent data CV of 0.5 and a dilution credit of $D = 73$ (dilution ratio = 74:1), are an AMEL of 150 mg/L and an MDEL of 270 mg/L.

Statistical adjustments were made to the total ammonia WQBEL calculations because:

- the Basin Plan's chronic WQO for un-ionized ammonia is based on an annual median instead of the typical 4-day average;
- the SIP assumes a 4-day average concentration and a monthly sampling frequency of 4 days per month to calculate effluent limitations based on chronic criteria, whereas a 365-day average and a monitoring frequency of 30 days per month (the maximum daily sampling frequency in a month since the averaging period for the chronic criteria is longer than 30 days) were used.

These statistical adjustments are supported by USEPA's *Water Quality Criteria; Notice of Availability; 1999 Update of Ambient Water Quality Criteria for Ammonia*, published on December 22, 1999, in the Federal Register. Following the SIP methodology, the maximum ambient background total ammonia concentration (0.21 mg/L) was used to calculate effluent limitations based on the acute criterion, and the median background total ammonia concentration (0.10 mg/L) to calculate effluent limitations based on the chronic criterion. Because the Basin Plan's chronic un-ionized ammonia objective is an annual median, the median background concentration is more representative of ambient conditions than a daily maximum.

Because the limitations in the previous orders (AMEL of 120 mg/L and MDEL of 310 mg/L) are more stringent, this Order retains the previous orders limitations.

- (d) **Anti-backsliding.** Anti-backsliding requirements are satisfied because the ammonia limitations are the same as those in the previous orders.
- (e) **Growing Regional Concern with Nutrients.** As described above and in section IV.C.4.b, Dilution Credit, a translated Basin Plan un-ionized ammonia objective and a conservative estimate of actual initial dilution were used to calculate the total ammonia effluent limitations. In the future, the Regional Water Board may grant less dilution credit or change the ammonia limitations in other ways to address growing concerns about nutrients in the receiving water. Currently, a region-wide effort is underway to study and evaluate potential effects. This effort, which is referred to as the San Francisco Bay Nutrient Strategy, includes developing a nutrient assessment framework that can be used to calculate water quality-based effluent limits for nutrients. The Regional Water Board, through its Executive Officer, has also required wastewater dischargers, including this Discharger, to monitor nutrients, including ammonia, in their influent and effluent. This information will be used to compare nutrient loads from wastewater discharges to loads from other sources, to support modeling and evaluation of load reduction scenarios, and to determine the need for additional wastewater treatment to address nutrients.

d. **WQBEL Calculation Summary**

The following table shows the WQBEL calculations for copper, cyanide, selenium, dioxin-TEQ, zinc and ammonia at Discharge Point No. 001, with compliance measured at Monitoring Location EFF-001. Compliance for cyanide may be measured at Monitoring Location EFF-002, following dechlorination.

Table F-11. WQBEL Calculations

PRIORITY POLLUTANTS	Copper	Cyanide	Selenium	Zinc	Dioxin-TEQ	Total Ammonia (acute)	Total Ammonia (Chronic)
Units	µg/L	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L
Basis and Criteria type	Basin Plan SSO	Basin Plan SSO	CTR Aquatic Life	CTR Aquatic Life	CTR HH	Basin Plan Aquatic Life	Basin Plan Aquatic Life
Criteria -Acute	----	----	20	95	----	14	----
Criteria -Chronic	----	----	5	86	----	----	1.6
SSO Criteria -Acute	9.4	9.4	----	----	----	----	----
SSO Criteria -Chronic	6.0	2.9	----	----	----	----	----
Water Effects ratio (WER)	2.4	1	1	1	1	1	1
Lowest WQO	6.0	2.9	5.0	86	1.4E-08	14	1.6
Site Specific Translator - MDEL	0.87	----	----	----	----	----	----
Site Specific Translator - AMEL	0.73	----	----	----	----	----	----
Dilution Factor (D) (if applicable)	9	9	0	9	0	73	73
No. of samples per month	4	4	4	4	4	4	4
Aquatic life criteria analysis required? (Y/N)	Y	Y	Y	Y	N	Y	Y
HH criteria analysis required? (Y/N)	N	Y	N	N	Y	N	N
Applicable Acute WQO	10.8	9.4	20	95	----	14	----
Applicable Chronic WQO	8.2	2.9	5.0	86	----	----	1.6
HH criteria	----	220000	----	----	1.4E-08	----	----
Background (Maximum Conc for Aquatic Life calc)	2.5	0.4	0.39	5	----	0.21	0.10
Background (Average Conc for Human Health calc)	----	0.2	0	0	5.3E-08	----	----
Is the pollutant on the 303d list and/or bioaccumulative (Y/N)?	N	N	N	N	Y	N	N
ECA acute	85.1	90	20	910	----	1100	----
ECA chronic	59.3	25	5.0	820	----	----	110
ECA HH		220000	----	----	1.40E-08	----	----
No. of data points <10 or at least 80 percent of data reported non detect? (Y/N)	N	N	N	N	Y	N	N
Average of effluent data points	1.3	NA	0.4	54	N/A	38	38

PRIORITY POLLUTANTS	Copper	Cyanide	Selenium	Zinc	Dioxin-TEQ	Total Ammonia (acute)	Total Ammonia (Chronic)
Units	µg/L	µg/L	µg/L	µg/L	µg/L	mg/L	mg/L
Std Dev of effluent data points	0.53	NA	0.7	60	N/A	17.98	18
CV calculated	0.41	0.72	1.9	1.1	N/A	0.5	0.5
CV (Selected) - Final	0.41	0.72	1.9	1.1	0.60	0.5	0.5
ECA acute mult99	0.43	0.27	0.12	0.19	----	0.39	----
ECA chronic mult99	0.63	0.47	0.21	0.35	----	----	0.94
LTA acute	36.6	25	2.4	170	----	400	----
LTA chronic	37.6	12	1.0	280	----	----	103
minimum of LTAs	36.6	12	1.0	170	----	400	103
AMEL mult95	1.4	1.7	2.7	2.0	1.6	1.4	1.4
MDEL mult99	2.3	3.7	8.4	5.3	3.1	2.6	2.6
AMEL (aq life)	50.1	20	2.9	350	----	580	148
MDEL(aq life)	85.1	44	8.8	910	----	1100	270
MDEL/AMEL Multiplier	1.7	2.2	3.1	2.6	2.0	1.8	1.8
AMEL (human health)	----	----	----	----	1.4E-08	----	----
MDEL (human health)	----	----	----	----	2.8E-08	----	----
Minimum of AMEL for Aq. life vs HH	50.1	20	2.9	350	1.4E-08	580	150
Minimum of MDEL for Aq. Life vs HH	85	44	8.8	910	2.8E-08	1100	270
Current limit in permit (30-day average)	42	20	----	----	----	120	120
Current limit in permit (daily)	84	44	----	----	----	310	310
Final limit - AMEL	42.0	20	2.9	350	1.4E-08	120	120
Final limit - MDEL	84	44	8.8	910	2.8E-08	310	310
Max Effl Conc (MEC)	11	6.5	5.3	340	9.2E-07	90	90

5. Whole Effluent Acute Toxicity – Discharge Point No. 001

This Order includes effluent limitations for whole effluent acute toxicity based on Basin Plan Table 4-3. All bioassays are to be performed according to the USEPA approved method in 40 CFR 136, *Methods for Measuring the Acute Toxicity of Effluents and Receiving Water*, 5th Edition. The approved test species currently specified in the Monitoring and Reporting Program (Attachment E) is fathead minnow.

If the Discharger can demonstrate that ammonia causes acute toxicity in excess of the acute toxicity limitations in this Order, and that the ammonia in the discharge complies with the ammonia effluent limitations in this Order, then such toxicity will not constitute a violation

of the effluent limitations for whole effluent acute toxicity. This is based on Basin Plan section 3.3.20.

6. Whole Effluent Chronic Toxicity – Discharge Point No. 001

This Order establishes a requirement for the Discharger to conduct chronic toxicity testing once a year to ensure the discharge has acceptable levels of chronic toxicity.

- a. **Toxicity Objective.** Basin Plan section 3.3.18 states, “There shall be no chronic toxicity in ambient waters. Chronic toxicity is a detrimental biological effect on growth rate, reproduction, fertilization success, larval development, population abundance, community composition, or any other relevant measure of health of an organism, population, or community.”
- b. **Reasonable Potential Analysis.** The previous orders included a chronic toxicity trigger of a three sample median of 10 TUC or a single sample maximum of 20 TUC, which would trigger accelerated chronic toxicity testing if exceeded. Chronic toxicity testing results during the previous orders terms using *Dendraster excentricus* and *Storngylocentrotus purpuratus* indicate that the maximum single sample chronic toxicity was 6.67 TUC. These low toxicity values indicate low reasonable potential for chronic toxicity so there is only a narrative chronic toxicity limit in this Order. A numeric limit is unwarranted.
- c. **Permit Requirements.** The Order contains a narrative effluent limitation for chronic toxicity based on the Basin Plan narrative toxicity WQO. The Order also includes requirements for chronic toxicity monitoring to ensure attainment of the Basin Plan narrative WQO and a monitoring “trigger” for initiation of accelerated monitoring requirements when exceeded. The Discharger is required to implement a chronic toxicity reduction evaluation (TRE) in some circumstances. These requirements are consistent with CTR and SIP requirements.
- d. **Screening Phase Study and Monitoring Requirement.** The Discharger initiated a three-phase chronic toxicity screening study from January 2012 through March 2012 to identify the indicator organism most sensitive to the effluent. Results showed that *Storngylocentrotus purpuratus* was the most sensitive of the species tested. Based on these test results, this Order requires the 72-hour echinoderm embryo development test with the *S. purpuratus* (purple sea urchin). (*Echinoderm Dendraster excentricus* is used for the test if *S. purpuratus* is not available due to seasonal spawning. The Discharger is required to conduct another chronic toxicity screening study as described in MRP Appendix E-1 during the term of this Order to determine whether the most sensitive species has changed.
- e. **Chronic Toxicity Triggers.** This Order includes the following chronic toxicity triggers: a three-sample median of 10 chronic toxicity units (TUC) or a single-sample maximum of 20 TUC.

D. Anti-backsliding and Antidegradation

1. Effluent Limitations Retained from Previous Orders.

- a. Discharge Point No. 001-San, Discharge Point No. 001-Ind, and Discharge Point No. 001.** Most effluent limitations have been retained and are unchanged from the previous Order: Because concentration based effluent limitations for BOD₅ and TSS are being retained, and effluent limitations for additional parameters will require the treatment plant continue to be properly operated, the removal of percent removal requirements during periods when sanitary wastewaters are not being discharged to the Industrial Plant is not expected to lower the quality of the treated effluent or negatively impact or degrade the receiving water.
- b. Discharge Point No. 002.** Effluent limitations for Total Residual Chlorine and Cyanide in the combined effluent following chlorination and dechlorination have been retained and are unchanged from the previous orders. Retaining these limitations for these parameters ensures that these limitations are at least as stringent as those in the previous orders, meeting CWA anti-backsliding and antidegradation requirements.

2. New Final Effluent Limitations.

Discharge Point No. 001. This Order establishes new effluent limitations for selenium and zinc based on the RPA. Establishing new effluent limitations creates requirements more stringent than those of the previous orders.

3. Effluent Limitations not Retained.

- a.** As discussed in section IV.B.1.b of this Fact Sheet, the percent removal requirements for BOD₅ and TSS at Discharge Point No. 001-Ind, when only industrial wastewater is processed are not retained. Because concentration based effluent limitations for BOD₅ and TSS are being retained, and effluent limitations for additional parameters will require the Discharger to continue operating the Industrial Plant properly, the removal of percent removal requirements during periods when sanitary wastewaters are not being processed through the industrial plant will not lower the quality of the treated effluent or negatively affect or degrade the receiving water. Therefore, removing the percent removal requirement will not impact anti-backsliding and antidegradation requirements.
- b.** This Order does not retain effluent limitations from the previous orders for: mercury, nickel, lead, aldrin, alpha-BHC, Beta-BHC, 4,4-DDT, 4,4-DDE, Dieldrin, Endrin, Heptachlor, Heptachlor epoxide, and Tributyltin.

This Order does not retain mercury effluent limitations because mercury discharges are now regulated by Regional Board Order No. R2-2012-0096, which is a Watershed Permit that implements the San Francisco Bay Mercury TMDL and establishes wasteload allocations for industrial and municipal mercury discharges.

This Order does not retain the other effluent limitations because the RPA showed that the Facility discharge no longer demonstrates reasonable potential to cause or contribute to

exceedances of their associated water quality criteria. This is consistent with the anti-backsliding provisions of State Water Board Order WQ 2001-16. This is also consistent with antidegradation requirements since these pollutants are no longer present and cannot cause degradation.

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

Receiving water limitations V.A. and V.B. are based on the narrative and numeric objectives in Basin Plan Chapter 3. Receiving water limitation V.C requires compliance with federal and State water quality standards.

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

The Monitoring and Reporting Program (MRP) is a standard requirement in almost all NPDES permits, including this Order. It contains definitions of terms and sets out requirements for reporting routine monitoring data in accordance with NPDES regulations, the CWC, and State and Regional Water Board policies. The MRP also defines sampling stations, the pollutants to be monitored, sampling frequencies, and additional reporting requirements. Pollutants to be monitored include all parameters for which effluent limitations are specified. Monitoring for additional constituents, for which no effluent limitations are established, is also required to provide data for future completion of RPAs and ensure no change in conditions of the discharge.

The following provides the rationale for the monitoring and reporting requirements contained in the MRP

A. Influent Monitoring

Influent monitoring requirements at INF-001-San and INF-001-Ind for CBOD₅, BOD₅, and TSS are necessary to determine compliance with this Order's 85% removal requirements. Flow monitoring is necessary to evaluate compliance with Prohibition III.D (average dry weather flow). Influent cyanide monitoring has been added based on Basin Plan section 4.7.2.

B. Effluent Monitoring

1. Monitoring Locations EFF-001-San and EFF-001-Ind

The MRP retains most effluent monitoring requirements from the previous orders. Monitoring at Monitoring Locations EFF-001-San and EFF-001-Ind is necessary to determine compliance with effluent limitations for conventional and nonconventional pollutants.

2. Monitoring Location EFF-001

The MRP retains most effluent monitoring requirements from the previous orders. Monitoring at Monitoring Location EFF-001 is necessary to determine compliance with effluent limitations for toxic pollutants, bacteria, and toxicity. Monthly monitoring requirements have not been retained for pollutants that no longer have effluent limits in this Order. Provision VI.C.2 requires annual monitoring for the remaining priority pollutants.

3. Monitoring Location EFF-002

The MRP retains effluent monitoring requirements from the previous orders. Monitoring at Monitoring Location EFF-002 is necessary to determine compliance with chlorine and cyanide effluent limitations.

4. Monitoring Locations EFF-003 through 013

With the exception of PCBs, the MRP retains the stormwater effluent monitoring requirements from the previous order for the Industrial Plant. During the term of the previous order, metals identified in MRP Table E-6 were found in stormwater samples.

C. Receiving Water Monitoring

The Discharger is required to continue participating in the Regional Monitoring Program (RMP) for Trace Substances, which involves collecting data on pollutants and toxicity in San Francisco Bay water, sediment, and biota. The Discharger’s participation and support of the RMP is the basis for not including other receiving water monitoring requirements in this permit.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions (Provision VI.A)

Standard Provisions, which in accordance with 40 CFR 122.41 and 122.42 apply to all NPDES discharges and must be included in every NPDES permit, are provided in Attachment D. NPDES regulations at 40 CFR 122.41(a)(1) and (b) through (n) establish conditions that apply to all state-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. NPDES regulations at 40 CFR 123.25(a)(12) allow the state to omit or modify conditions to impose more stringent requirements. The Regional Standard Provisions (Attachment G) supplement the Federal Standard Provisions. In accordance with 40 CFR 123.25, this Order omits federal conditions that address enforcement authority specified in 40 CFR 122.41(j)(5) and (k)(2) because the CWC enforcement authority is more stringent. In lieu of these conditions, this Order incorporates by reference CWC section 13387(e).

B. Monitoring and Reporting Requirements (Provision VI.B)

The Discharger is required to monitor the permitted discharges in order to evaluate compliance with permit conditions. Monitoring requirements are contained in the MRP and the standard provisions in Attachments D and G. This provision requires compliance with these documents and is authorized by 40 CFR 122.41(h) and (j), and CWC sections 13267 and 13383.

The table below summarizes routine monitoring requirements. This table is for informational purposes only. Actual requirements are specified in the MRP and other applicable provisions of this Order.

Table F-12. Monitoring Requirements Summary

Parameter	Influent INF-001-San	Influent INF-001-Ind	Effluent EFF-001-San	Effluent EFF-001-Ind	Effluent EFF-001	Effluent EFF-002	Sludge and Biosolids B-001	Receiving Water
Flow	Cont.	Cont.	Cont.	Cont.	Cont.			
BOD ₅		3/Week		3/Week				

CBOD ₅	3/Week		3/Week					
TSS	3/Week	3/Week	3/Week	3/Week				
Oil and Grease			2/Month	2/Month				
pH			3/Week	3/Week				Support RMP
Dissolved Oxygen								Support RMP
Sulfides								Support RMP
Chlorine Residual						Cont.		
Acute Toxicity					1/Month			Support RMP
Chronic Toxicity					2/Year			Support RMP
Fecal Coliform					2/Week			Support RMP
Enterococcus					1/Month			Support RMP
Copper					1/Month			Support RMP
Cyanide	2/Year	2/Year				1/Month		Support RMP
Selenium					1/Month			
Zinc					1/Month			Support RMP
Total Ammonia					1/Month			Support RMP
Dioxin-TEQ					2/Year			Support RMP
All Other Priority Pollutants					See Order, section VI.C.2.			Support RMP
Metric tons/year							See Att. G § III.B.1	
Paint filter test							See Att. G § III.B.2	

C. Special Provisions

1. Reopener Provisions

These provisions are based on 40 CFR 122.63 and allow modification of this Order and its effluent limitations as necessary in response to updated water quality standards, regulations, or other new relevant information that may become available in the future and other circumstances allowed by law.

2. Effluent Characterization Study and Report

This Order does not include effluent limitations for priority pollutants that do not demonstrate Reasonable Potential, but this provision requires the Discharger to continue monitoring for these pollutants as described in the Regional Standard Provisions and as specified in the MRP. This requirement is authorized pursuant to CWC section 13267, and is necessary to inform the next permit reissuance and to ensure that the Discharger takes proper

and timely steps in response to any changes in unanticipated effluent quality during the term of this Order.

3. Best Management Practices and Pollutant Minimization Program

- a. Provisions VI.C.3.a through d for a Pollutant Minimization Program is based on Basin Plan section 4.13.2 and SIP section 2.4.5.
- b. Provision VI.C.3.e for a Stormwater Pollution Prevention Plan is retained from the previous order for the Industrial Plant. This provision requires ongoing implementation of the Stormwater Pollution Prevention Plan and best management practices to ensure compliance with federal stormwater pollution controls.

4. Special Provisions for POTWs

- a. **Biosolids Management Practices.** This provision is based on Basin Plan Chapter 4, section 4.17, and 40 CFR Parts 257 and 503.
- b. **Sanitary Sewer Overflows and Sewer System Management Plan.** This provision is to explain the Order's requirements as they relate to the Discharger's collection system, and to promote consistency with the State Water Board-adopted General Collection System WDRs (General Order, Order No. 2006-0003-DWQ). The General Order requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the General Order. The General Order requires agencies to develop sanitary sewer management plans and report all sanitary sewer overflows, among other requirements and prohibitions. Furthermore, the General Order contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. Since the airport has more than one mile of pipes then this General Order applies.

The General Order requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the General Order. The General Order requires agencies to develop sanitary sewer management plans and report all sanitary sewer overflows, among other requirements and prohibitions. Furthermore, the General Order contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. Inasmuch that the Discharger's collection system is part of the system that is subject to this Order, certain standard provisions apply as specified in Provisions, section VI.C.4.b, Sanitary Sewer Overflows and Sewer System Management Plan. The Discharger must comply with both the General Order and this Order. The Discharger was required to enroll under the General Order by December 1, 2006.

The State Water Board amended the General Order on February 20, 2008, in Order No. WQ 2008-0002-EXEC, to strengthen the notification and reporting requirements for sanitary sewer overflows. The Regional Standard Provisions contains the same notification and reporting requirements for spills from wastewater treatment facilities.

5. Other Special Provisions

- a. **Copper Action Plan.** This provision is based on Basin Plan section 7.2.1.2. It is necessary to ensure that use of copper site-specific objectives is consistent with antidegradation policies. Data from the San Francisco Estuary Institute compiled for 2008-2010 indicate no degradation of San Francisco Bay water quality with respect to copper (<http://www.sfei.org/content/copper-site-specific-objective-3-year-rolling-averages>).
- b. **Cyanide Action Plan.** This provision is based on Basin Plan section 4.7.2.2. It is necessary to ensure that use of cyanide site-specific objectives is consistent with antidegradation policies.
- c. **Deicing Operations.** Consistent with the requirements of 40 CFR 449.10, this permit prohibits the use of deicing fluid that contains urea and requires that the Discharger certify annually that it does not use airfield deicing products that contain urea.

VIII. PUBLIC PARTICIPATION

The Regional Water Board considered the issuance of waste discharge requirements (WDRs) to serve as an NPDES permit for the Facility. As a step in the WDRs adoption process, Regional Water Board staff developed tentative WDRs. The Regional Water Board encouraged public participation in the WDR adoption process.

A. Notification of Interested Parties

The Regional Water Board notified the Discharger and interested agencies and persons of its intent to prescribe WDRs for the discharge and provided them with an opportunity to submit written comments and recommendations. Notification was provided through the San Mateo Times in February 2013.

B. Written Comments

Staff determinations are tentative. Interested persons were invited to submit written comments concerning the tentative WDRs. Comments were to be submitted either in person or by mail to the Executive Officer at the Regional Water Board at 1515 Clay Street, Suite 1400, Oakland, California 94080, to the attention of Derek Whitworth.

To receive full consideration and a written response, written comments were to be received at the Regional Water Board offices by 5:00 p.m. on March 15, 2013.

C. Public Hearing

The Regional Water Board held a public hearing on the tentative WDRs during its regular meeting at the following date and time, and at the following location:

Date: April 10, 2013
Time: 9:00 a.m.

Location: Elihu Harris State Office Building
1515 Clay Street, 1st Floor Auditorium
Oakland, CA 94612

Contact: Derek Whitworth, (510) 622-2349, email dwhitworth@waterboards.ca.gov

Interested persons were invited to attend. At the public hearing, the Regional Water Board heard testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony, if any, was heard; however, for accuracy of the record, important testimony was to be in writing.

Dates and venues change. The Regional Water Board web address is <http://www.waterboards.ca.gov/sanfranciscobay>, where one can access the current agenda for changes in dates and locations.

D. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

E. Information and Copying

The Report of Waste Discharge (RWD), related documents, tentative effluent limitations, and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 9:00 a.m. and 5:00 p.m., Monday through Friday. Copying of documents may be arranged by calling 510-622-2300.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this order should be directed to Derek Whitworth at 510-622-2349 or e-mail at DWhitworth@waterboards.ca.gov.

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION**

**ATTACHMENT G
REGIONAL STANDARD PROVISIONS AND MONITORING
AND REPORTING REQUIREMENTS
(SUPPLEMENT TO ATTACHMENT D)**

For

NPDES WASTEWATER DISCHARGE PERMITS

March 2010

Contents^[bjj1]

I.	I. STANDARD PROVISIONS - PERMIT COMPLIANCE	G-1
	A. Duty to Comply	G-1
	B. Need to Halt or Reduce Activity Not a Defense	G-1
	C. Duty to Mitigate	G-1
	1. Contingency Plan	G-1
	2. Spill Prevention Plan	G-2
	D. Proper Operation & Maintenance.....	G-2
	1. Operation and Maintenance (O&M) Manual	G-2
	2. Wastewater Facilities Status Report.....	G-2
	3. Proper Supervision and Operation of Publicly Owned Treatment Works (POTWs).....	G-3
	E. Property Rights.....	G-3
	F. Inspection and Entry.....	G-3
	G. Bypass	G-3
	H. Upset.....	G-3
	I. Other.....	G-3
	J. Stormwater.....	G-3
	1. Stormwater Pollution Prevention Plan (SWPP Plan).....	G-3
	2. Source Identification	G-4
	3. Stormwater Management Controls.....	G-5
	4. Annual Verification of SWPP Plan	G-6
	K. Biosolids Management	G-6
II.	STANDARD PROVISIONS – PERMIT ACTION.....	G-7
II.	G-7	
III.	III. STANDARD PROVISIONS – MONITORING.....	G-7
IV.	G-7	
	A. Sampling and Analyses	G-7
	1. Use of Certified Laboratories	G-7
	2. Use of Appropriate Minimum Levels	G-7
	3. Frequency of Monitoring.....	G-7
	B. Biosolids Monitoring.....	G-10
	1. Biosolids Monitoring Frequency.....	G-10
	2. Biosolids Pollutants to Monitor.....	G-12
	C. Standard Observations.....	G-12
	1. Receiving Water Observations.....	G-12
	2. Wastewater Effluent Observations.....	G-12
	3. Beach and Shoreline Observations.....	G-13
	4. Land Retention or Disposal Area Observations	G-13
	5. Periphery of Waste Treatment and/or Disposal Facilities Observations.....	G-13
V.	IV. STANDARD PROVISIONS – RECORDS	G-13
	A. Records to be Maintained.....	G-13
	B. Records of monitoring information shall include.....	G-14
	1. Analytical Information	G-14
	2. Flow Monitoring Data	G-14

3. Wastewater Treatment Process Solids	G-14
4. Disinfection Process	G-14
5. Treatment Process Bypasses	G-15
6. Treatment Facility Overflows	G-15
C. Claims of Confidentiality	G-15
VI. V. STANDARD PROVISIONS – REPORTING	G-15
A. Duty to Provide Information	G-16
B. Signatory and Certification Requirements	G-16
C. Monitoring Reports	G-17
1. Self Monitoring Reports	G-17
D. Compliance Schedules	G-23
E. Twenty-Four Hour Reporting	G-23
1. Spill of Oil or Other Hazardous Material Reports	G-23
2. Unauthorized Discharges from Municipal Wastewater Treatment Plants	G-24
F. Planned Changes	G-27
G. Anticipated Noncompliance.....	G-27
H. Other Noncompliance	G-27
I. Other Information.....	G-27
VI. STANDARD PROVISIONS – ENFORCEMENT	G-27
VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS	G-27
VIII. DEFINITIONS.....	G-27

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION**

**REGIONAL STANDARD PROVISIONS, AND MONITORING AND
REPORTING REQUIREMENTS
(SUPPLEMENT TO ATTACHMENT D)**

FOR

NPDES WASTEWATER DISCHARGE PERMITS

APPLICABILITY

This document applies to dischargers covered by a National Pollutant Discharge Elimination System (NPDES) permit. This document does not apply to Municipal Separate Storm Sewer System (MS4) NPDES permits.

The purpose of this document is to supplement the requirements of Attachment D, Standard Provisions. The requirements in this supplemental document are designed to ensure permit compliance through preventative planning, monitoring, recordkeeping, and reporting. In addition, this document requires proper characterization of issues as they arise, and timely and full responses to problems encountered. To provide clarity on which sections of Attachment D this document supplements, this document is arranged in the same format as Attachment D.

I. I. STANDARD PROVISIONS - PERMIT COMPLIANCE

A. Duty to Comply – Not Supplemented

B. Need to Halt or Reduce Activity Not a Defense – Not Supplemented

C. Duty to Mitigate – This supplements I.C. of Standard Provisions (Attachment D)

1. Contingency Plan - The Discharger shall maintain a Contingency Plan as originally required by Regional Water Board Resolution 74-10 and as prudent in accordance with current municipal facility emergency planning. The Contingency Plan shall describe procedures to ensure that existing facilities remain in, or are rapidly returned to, operation in the event of a process failure or emergency incident, such as employee strike, strike by suppliers of chemicals or maintenance services, power outage, vandalism, earthquake, or fire. The Discharger may combine the Contingency Plan and Spill Prevention Plan into one document. Discharge in violation of the permit where the Discharger has failed to develop and implement a Contingency Plan as described below will be the basis for considering the discharge a willful and negligent violation of the permit pursuant to California Water Code section 13387. The Contingency Plan shall, at a minimum, contain the provisions of a. through g. below.

- a. Provision of personnel for continued operation and maintenance of sewerage facilities during employee strikes or strikes against contractors providing services.
 - b. Maintenance of adequate chemicals or other supplies and spare parts necessary for continued operations of sewerage facilities.
 - c. Provisions of emergency standby power.
 - d. Protection against vandalism.
 - e. Expeditious action to repair failures of, or damage to, equipment and sewer lines.
 - f. Report of spills and discharges of untreated or inadequately treated wastes, including measures taken to clean up the effects of such discharges.
 - g. Programs for maintenance, replacement, and surveillance of physical condition of equipment, facilities, and sewer lines.
2. Spill Prevention Plan - The Discharger shall maintain a Spill Prevention Plan to prevent accidental discharges and minimize the effects of such events. The Spill Prevention Plan shall:
- a. Identify the possible sources of accidental discharge, untreated or partially treated waste bypass, and polluted drainage;
 - b. Evaluate the effectiveness of present facilities and procedures, and state when they became operational; and
 - c. Predict the effectiveness of the proposed facilities and procedures, and provide an implementation schedule containing interim and final dates when they will be constructed, implemented, or operational.

This Regional Water Board, after review of the Contingency and Spill Prevention Plans or their updated revisions, may establish conditions it deems necessary to control accidental discharges and to minimize the effects of such events. Such conditions may be incorporated as part of the permit upon notice to the Discharger.

D. Proper Operation & Maintenance – This supplements I.D of Standard Provisions (Attachment D)

1. Operation and Maintenance (O&M) Manual - The Discharger shall maintain an O&M Manual to provide the plant and regulatory personnel with a source of information describing all equipment, recommended operational strategies, process control monitoring, and maintenance activities. To remain a useful and relevant document, the O&M Manual shall be kept updated to reflect significant changes in treatment facility equipment and operational practices. The O&M Manual shall be maintained in usable condition and be available for reference and use by all relevant personnel and Regional Water Board staff.
2. Wastewater Facilities Status Report - The Discharger shall regularly review, revise, or update, as necessary, its Wastewater Facilities Status Report. This report shall document how

the Discharger operates and maintains its wastewater collection, treatment, and disposal facilities to ensure that all facilities are adequately staffed, supervised, financed, operated, maintained, repaired, and upgraded as necessary to provide adequate and reliable transport, treatment, and disposal of all wastewater from both existing and planned future wastewater sources under the Discharger's service responsibilities.

3. Proper Supervision and Operation of Publicly Owned Treatment Works (POTWs) - POTWs shall be supervised and operated by persons possessing certificates of appropriate grade pursuant to Division 4, Chapter 14, Title 23 of the California Code of Regulations.

E. Property Rights – Not Supplemented

F. Inspection and Entry – Not Supplemented

G. Bypass – Not Supplemented

H. Upset – Not Supplemented

I. Other – This section is an addition to Standard Provisions (Attachment D)

1. Neither the treatment nor the discharge of pollutants shall create pollution, contamination, or nuisance as defined by California Water Code section 13050.
2. Collection, treatment, storage, and disposal systems shall be operated in a manner that precludes public contact with wastewater, except in cases where excluding the public is infeasible, such as private property. If public contact with wastewater could reasonably occur on public property, warning signs shall be posted.
3. If the Discharger submits a timely and complete Report of Waste Discharge for permit reissuance, this permit continues in force and effect until a new permit is issued or the Regional Water Board rescinds the permit.

J. Stormwater – This section is an addition to Standard Provisions (Attachment D)

These provisions apply to facilities that do not direct all stormwater flows from the facility to the wastewater treatment plant headworks.

1. Stormwater Pollution Prevention Plan (SWPP Plan)

The SWPP Plan shall be designed in accordance with good engineering practices and shall address the following objectives:

- a. To identify pollutant sources that may affect the quality of stormwater discharges; and
- b. To identify, assign, and implement control measures and management practices to reduce pollutants in stormwater discharges.

The SWPP Plan may be combined with the existing Spill Prevention Plan as required in accordance with section C.2. The SWPP Plan shall be retained on-site and made available upon request of a representative of the Regional Water Board.

2. Source Identification

The SWPP Plan shall provide a description of potential sources that may be expected to add significant quantities of pollutants to stormwater discharges, or may result in non-stormwater discharges from the facility. The SWPP Plan shall include, at a minimum, the following items:

- a. A topographical map (or other acceptable map if a topographical map is unavailable), extending one-quarter mile beyond the property boundaries of the facility, showing the wastewater treatment facility process areas, surface water bodies (including springs and wells), and discharge point(s) where the facility's stormwater discharges to a municipal storm drain system or other points of discharge to waters of the State. The requirements of this paragraph may be included in the site map required under the following paragraph if appropriate.
- b. A site map showing the following:
 - 1) Stormwater conveyance, drainage, and discharge structures;
 - 2) An outline of the stormwater drainage areas for each stormwater discharge point;
 - 3) Paved areas and buildings;
 - 4) Areas of actual or potential pollutant contact with stormwater or release to stormwater, including but not limited to outdoor storage and process areas; material loading, unloading, and access areas; and waste treatment, storage, and disposal areas;
 - 5) Location of existing stormwater structural control measures (i.e., berms, coverings, etc.);
 - 6) Surface water locations, including springs and wetlands; and
 - 7) Vehicle service areas.
- c. A narrative description of the following:
 - 1) Wastewater treatment process activity areas;
 - 2) Materials, equipment, and vehicle management practices employed to minimize contact of significant materials of concern with stormwater discharges;
 - 3) Material storage, loading, unloading, and access areas;
 - 4) Existing structural and non-structural control measures (if any) to reduce pollutants in stormwater discharges; and

- 5) Methods of on-site storage and disposal of significant materials.
- d. A list of pollutants that have a reasonable potential to be present in stormwater discharges in significant quantities.

3. Stormwater Management Controls

The SWPP Plan shall describe the stormwater management controls appropriate for the facility and a time schedule for fully implementing such controls. The appropriateness and priorities of controls in the SWPP Plan shall reflect identified potential sources of pollutants. The description of stormwater management controls to be implemented shall include, as appropriate:

- a. Stormwater pollution prevention personnel

Identify specific individuals (and job titles) that are responsible for developing, implementing, and reviewing the SWPP Plan.

- b. Good housekeeping

Good housekeeping requires the maintenance of clean, orderly facility areas that discharge stormwater. Material handling areas shall be inspected and cleaned to reduce the potential for pollutants to enter the storm drain conveyance system.

- c. Spill prevention and response

Identify areas where significant materials can spill into or otherwise enter stormwater conveyance systems and their accompanying drainage points. Specific material handling procedures, storage requirements, and cleanup equipment and procedures shall be identified, as appropriate. The necessary equipment to implement a cleanup shall be available, and personnel shall be trained in proper response, containment, and cleanup of spills. Internal reporting procedures for spills of significant materials shall be established.

- d. Source control

Source controls include, for example, elimination or reduction of the use of toxic pollutants, covering of pollutant source areas, sweeping of paved areas, containment of potential pollutants, labeling of all storm drain inlets with “No Dumping” signs, isolation or separation of industrial and non-industrial pollutant sources so that runoff from these areas does not mix, etc.

- e. Stormwater management practices

Stormwater management practices are practices other than those that control the sources of pollutants. Such practices include treatment or conveyance structures, such as drop inlets, channels, retention and detention basins, treatment vaults, infiltration galleries, filters, oil/water separators, etc. Based on assessment of the potential of various sources to contribute pollutants to stormwater discharges in significant quantities, additional

stormwater management practices to remove pollutants from stormwater discharges shall be implemented and design criteria shall be described.

f. Sediment and erosion control

Measures to minimize erosion around the stormwater drainage and discharge points, such as riprap, revegetation, slope stabilization, etc., shall be described.

g. Employee training

Employee training programs shall inform all personnel responsible for implementing the SWPP Plan. Training shall address spill response, good housekeeping, and material management practices. New employee and refresher training schedules shall be identified.

h. Inspections

All inspections shall be done by trained personnel. Material handling areas shall be inspected for evidence of, or the potential for, pollutants entering stormwater discharges. A tracking or follow up procedure shall be used to ensure appropriate response has been taken in response to an inspection. Inspections and maintenance activities shall be documented and recorded. Inspection records shall be retained for five years.

i. Records

A tracking and follow-up procedure shall be described to ensure that adequate response and corrective actions have been taken in response to inspections.

4. Annual Verification of SWPP Plan

An annual facility inspection shall be conducted to verify that all elements of the SWPP Plan are accurate and up-to-date. The results of this review shall be reported in the Annual Report to the Regional Water Board described in section V.C.f.

K. Biosolids Management – This section is an addition to Standard Provisions (Attachment D)

Biosolids must meet the following requirements prior to land application. The Discharger must either demonstrate compliance or, if it sends the biosolids to another party for further treatment or distribution, must give the recipient the information necessary to ensure compliance.

1. Exceptional quality biosolids meet the pollutant concentration limits in Table III of 40 CFR Part 503.13, Class A pathogen limits, and one of the vector attraction reduction requirements in 503.33(b)(1)-(b)(8). Such biosolids do not have to be tracked further for compliance with general requirements (503.12) and management practices (503.14).
2. Biosolids used for agricultural land, forest, or reclamation shall meet the pollutant limits in Table I (ceiling concentrations) and Table II or Table III (cumulative loadings or pollutant concentration limits) of 503.13. They shall also meet the general requirements (503.12) and management practices (503.14) (if not exceptional quality biosolids) for Class A or Class B

pathogen levels with associated access restrictions (503.32) and one of the 10 vector attraction reduction requirements in 503.33(b)(1)-(b)(10).

3. Biosolids used for lawn or home gardens must meet exceptional quality biosolids limits.
4. Biosolids sold or given away in a bag or other container must meet the pollutant limits in either Table III or Table IV (pollutant concentration limits or annual pollutant loading rate limits) of 503.13. If Table IV is used, a label or information sheet must be attached to the biosolids packing that explains Table IV (see 503.14). The biosolids must also meet the Class A pathogen limits and one of the vector attraction reduction requirements in 503.33(b)(1)-(b)(8).

II. STANDARD PROVISIONS – PERMIT ACTION – Not Supplemented

II.

III.III.STANDARD PROVISIONS – MONITORING

IV.

A. Sampling and Analyses – This section is a supplement to III.A and III.B of Standard Provisions (Attachment D)

1. Use of Certified Laboratories

Water and waste analyses shall be performed by a laboratory certified for these analyses in accordance with California Water Code section 13176.

2. Use of Appropriate Minimum Levels

Table C lists the suggested analytical methods for the 126 priority pollutants and other toxic pollutants that should be used, unless a particular method or minimum level (ML) is required in the MRP.

For priority pollutant monitoring, when there is more than one ML value for a given substance, the Discharger may select any one of the analytical methods cited in Table C for compliance determination, or any other method described in 40 CFR part 136 or approved by USEPA (such as the 1600 series) if authorized by the Regional Water Board. However, the ML must be below the effluent limitation and water quality objective. If no ML value is below the effluent limitation and water quality objective, then the method must achieve an ML no greater than the lowest ML value indicated in Table C. All monitoring instruments and equipment shall be properly calibrated and maintained to ensure accuracy of measurements.

3. Frequency of Monitoring

The minimum schedule of sampling analysis is specified in the MRP portion of the permit.

a. Timing of Sample Collection

- 1) The Discharger shall collect samples of influent on varying days selected at random and shall not include any plant recirculation or other sidestream wastes, unless otherwise stipulated by the MRP.
 - 2) The Discharger shall collect samples of effluent on days coincident with influent sampling unless otherwise stipulated by the MRP or the Executive Officer. The Executive Officer may approve an alternative sampling plan if it is demonstrated to be representative of plant discharge flow and in compliance with all other permit requirements.
 - 3) The Discharger shall collect grab samples of effluent during periods of day-time maximum peak effluent flows (or peak flows through secondary treatment units for facilities that recycle effluent flows).
 - 4) Effluent sampling for conventional pollutants shall occur on at least one day of any multiple-day bioassay test the MRP requires. During the course of the test, on at least one day, the Discharger shall collect and retain samples of the discharge. In the event a bioassay test does not comply with permit limits, the Discharger shall analyze these retained samples for pollutants that could be toxic to aquatic life and for which it has effluent limits.
 - i. The Discharger shall perform bioassay tests on final effluent samples; when chlorine is used for disinfection, bioassay tests shall be performed on effluent after chlorination-dechlorination; and
 - ii. The Discharger shall analyze for total ammonia nitrogen and calculate the amount of un-ionized ammonia whenever test results fail to meet the percent survival specified in the permit.
- b. Conditions Triggering Accelerated Monitoring
- 1) If the results from two consecutive samples of a constituent monitored in a 30-day period exceed the monthly average limit for any parameter (or if the required sampling frequency is once per month and the monthly sample exceeds the monthly average limit), the Discharger shall, within 24 hours after the results are received, increase its sampling frequency to daily until the results from the additional sampling show that the parameter is in compliance with the monthly average limit.
 - 2) If any maximum daily limit is exceeded, the Discharger shall increase its sampling frequency to daily within 24 hours after the results are received that indicate the exceedance of the maximum daily limit until two samples collected on consecutive days show compliance with the maximum daily limit.
 - 3) If final or intermediate results of an acute bioassay test indicate a violation or threatened violation (e.g., the percentage of surviving test organisms of any single acute bioassay test is less than 70 percent), the Discharger shall initiate a new test as soon as practical, and the Discharger shall investigate the cause of the mortalities and report its findings in the next self monitoring report (SMR).

- 4) The Discharger shall calibrate chlorine residual analyzers against grab samples as frequently as necessary to maintain accurate control and reliable operation. If an effluent violation is detected, the Discharger shall collect grab samples at least every 30 minutes until compliance with the limit is achieved, unless the Discharger monitors chlorine residual continuously. In such cases, the Discharger shall continue to conduct continuous monitoring as required by its permit.
- 5) When a bypass occurs (except one subject to provision III.A.3.b.6 below), the Discharger shall monitor flows and collect samples on a daily basis for all constituents at affected discharge points that have effluent limits for the duration of the bypass (including acute toxicity using static renewals), except chronic toxicity, unless otherwise stipulated by the MRP.
- 6) Unless otherwise stipulated by the MRP, when a bypass approved pursuant to Attachment D, Standard Provisions, sections I.G.2 or I.G.4, occurs, the Discharger shall monitor flows and, using appropriate procedures as specified in the MRP, collect and retain samples for affected discharge points on a daily basis for the duration of the bypass. The Discharger shall analyze for total suspended solids (TSS) using 24-hour composites (or more frequent increments) and for bacteria indicators with effluent limits using grab samples. If TSS exceeds 45 mg/L in any composite sample, the Discharger shall also analyze the retained samples for that discharge for all other constituents that have effluent limits, except oil and grease, mercury, dioxin-TEQ, and acute and chronic toxicity. Additionally, at least once each year, the Discharger shall analyze the retained samples for one approved bypass discharge event for all other constituents that have effluent limits, except oil and grease, mercury, dioxin-TEQ, and acute and chronic toxicity. This monitoring shall be in addition to the minimum monitoring specified in the MRP.

c. Stormwater Monitoring

The requirements of this section only apply to facilities that are not covered by an NPDES permit for stormwater discharges and where not all site storm drainage from process areas (i.e., areas of the treatment facility where chemicals or wastewater could come in contact with stormwater) is directed to the headworks. For stormwater not directed to the headworks during the wet season (October 1 to April 30), the Discharger shall:

- 1) Conduct visual observations of the stormwater discharge locations during daylight hours at least once per month during a storm event that produces significant stormwater discharge to observe the presence of floating and suspended materials, oil and grease, discoloration, turbidity, and odor, etc.
- 2) Measure (or estimate) the total volume of stormwater discharge, collect grab samples of stormwater discharge from at least two storm events that produce significant stormwater discharge, and analyze the samples for oil and grease, pH, TSS, and specific conductance.

The grab samples shall be taken during the first 30 minutes of the discharge. If collection of the grab samples during the first 30 minutes is impracticable, grab samples may be taken during the first hour of the discharge, and the Discharger

shall explain in the Annual Report why the grab sample(s) could not be taken in the first 30 minutes.

- 3) Testing for the presence of non-stormwater discharges shall be conducted no less than twice during the dry season (May 1 to September 30) at all stormwater discharge locations. Tests may include visual observations of flows, stains, sludges, odors, and other abnormal conditions; dye tests; TV line surveys; or analysis and validation of accurate piping schematics. Records shall be maintained describing the method used, date of testing, locations observed, and test results.
- 4) Samples shall be collected from all locations where stormwater is discharged. Samples shall represent the quality and quantity of stormwater discharged from the facility. If a facility discharges stormwater at multiple locations, the Discharger may sample a reduced number of locations if it establishes and documents through the monitoring program that stormwater discharges from different locations are substantially identical.
- 5) Records of all stormwater monitoring information and copies of all reports required by the permit shall be retained for a period of at least three years from the date of sample, observation, or report.

d. Receiving Water Monitoring

The requirements of this section only apply when the MRP requires receiving water sampling.

- 1) Receiving water samples shall be collected on days coincident with effluent sampling for conventional pollutants.
- 2) Receiving water samples shall be collected at each station on each sampling day during the period within one hour following low slack water. Where sampling during lower slack water is impractical, sampling shall be performed during higher slack water. Samples shall be collected within the discharge plume and down current of the discharge point so as to be representative, unless otherwise stipulated in the MRP.
- 3) Samples shall be collected within one foot of the surface of the receiving water, unless otherwise stipulated in the MRP.

B. Biosolids Monitoring – This section supplements III.B of Standard Provisions (Attachment D)

When biosolids are sent to a landfill, sent to a surface disposal site, or applied to land as a soil amendment, they must be monitored as follows:

1. Biosolids Monitoring Frequency

Biosolids disposal must be monitored at the following frequency:

Metric tons biosolids/365 days	Frequency
---------------------------------------	------------------

0-290	Once per year
290-1500	Quarterly
1500-15,000	Six times per year
Over 15,000	Once per month

(Metric tons are on a dry weight basis)

2. Biosolids Pollutants to Monitor

Biosolids shall be monitored for the following constituents:

Land Application: arsenic, cadmium, copper, mercury, molybdenum, nickel, lead, selenium, and zinc

Municipal Landfill: Paint filter test (pursuant to 40 CFR 258)

Biosolids-only Landfill or Surface Disposal Site (if no liner and leachate system): arsenic, chromium, and nickel

C. Standard Observations – This section is an addition to III of Standard Provisions (Attachment D)

1. Receiving Water Observations

The requirements of this section only apply when the MRP requires standard observations of the receiving water. Standard observations shall include the following:

- a. *Floating and suspended materials* (e.g., oil, grease, algae, and other macroscopic particulate matter): presence or absence, source, and size of affected area.
- b. *Discoloration and turbidity*: description of color, source, and size of affected area.
- c. *Odor*: presence or absence, characterization, source, distance of travel, and wind direction.
- d. *Beneficial water use*: presence of water-associated waterfowl or wildlife, fisher people, and other recreational activities in the vicinity of each sampling station.
- e. *Hydrographic condition*: time and height of corrected high and low tides (corrected to nearest National Oceanic and Atmospheric Administration location for the sampling date and time of sample collection).
- f. *Weather conditions*:
 - 1) Air temperature; and
 - 2) Total precipitation during the five days prior to observation.

2. Wastewater Effluent Observations

The requirements of this section only apply when the MRP requires wastewater effluent standard observations. Standard observations shall include the following:

- a. *Floating and suspended material of wastewater origin* (e.g., oil, grease, algae, and other macroscopic particulate matter): presence or absence.

- b. *Odor*: presence or absence, characterization, source, distance of travel, and wind direction.

3. Beach and Shoreline Observations

The requirements of this section only apply when the MRP requires beach and shoreline standard observations. Standard observations shall include the following:

- a. *Material of wastewater origin*: presence or absence, description of material, estimated size of affected area, and source.
- b. *Beneficial use*: estimate number of people participating in recreational water contact, non-water contact, or fishing activities.

4. Land Retention or Disposal Area Observations

The requirements of this section only apply to facilities with on-site surface impoundments or disposal areas that are in use. This section applies to both liquid and solid wastes, whether confined or unconfined. The Discharger shall conduct the following for each impoundment:

- a. Determine the amount of freeboard at the lowest point of dikes confining liquid wastes.
- b. Report evidence of leaching liquid from area of confinement and estimated size of affected area. Show affected area on a sketch and volume of flow (e.g., gallons per minute [gpm]).
- c. Regarding odor, describe presence or absence, characterization, source, distance of travel, and wind direction.
- d. Estimate number of waterfowl and other water-associated birds in the disposal area and vicinity.

5. Periphery of Waste Treatment and/or Disposal Facilities Observations

The requirements of this section only apply when the MRP specifies periphery standard observations. Standard observations shall include the following:

- a. *Odor*: presence or absence, characterization, source, and distance of travel.
- b. *Weather conditions*: wind direction and estimated velocity.

V. IV. STANDARD PROVISIONS – RECORDS

A. Records to be Maintained – This supplements IV.A of Standard Provisions (Attachment D)

The Discharger shall maintain records in a manner and at a location (e.g., wastewater treatment plant or Discharger offices) such that the records are accessible to Regional Water Board staff. The minimum period of retention specified in section IV, Records, of the Federal Standard Provisions shall be extended during the course of any unresolved litigation regarding the subject discharge, or when requested by the Regional Water Board or Regional Administrator of USEPA, Region IX.

A copy of the permit shall be maintained at the discharge facility and be available at all times to operating personnel.

B. Records of monitoring information shall include – This supplements IV.B of Standard Provision (Attachment D)

1. Analytical Information

Records shall include analytical method detection limits, minimum levels, reporting levels, and related quantification parameters.

2. Flow Monitoring Data

For all required flow monitoring (e.g., influent and effluent flows), the additional records shall include the following, unless otherwise stipulated by the MRP:

- a. Total volume for each day; and
- b. Maximum, minimum, and average daily flows for each calendar month.

3. Wastewater Treatment Process Solids

- a. For each treatment unit process that involves solids removal from the wastewater stream, records shall include the following:
 - 1) Total volume or mass of solids removed from each collection unit (e.g., grit, skimmings, undigested biosolids, or combination) for each calendar month or other time period as appropriate, but not to exceed annually; and
 - 2) Final disposition of such solids (e.g., landfill, other subsequent treatment unit).
- b. For final dewatered biosolids from the treatment plant as a whole, records shall include the following:
 - 1) Total volume or mass of dewatered biosolids for each calendar month;
 - 2) Solids content of the dewatered biosolids; and
 - 3) Final disposition of dewatered biosolids (disposal location and disposal method).

4. Disinfection Process

For the disinfection process, these additional records shall be maintained documenting process operation and performance:

- a. For bacteriological analyses:
 - 1) Wastewater flow rate at the time of sample collection; and
 - 2) Required statistical parameters for cumulative bacterial values (e.g., moving median or geometric mean for the number of samples or sampling period identified in this Order).
- b. For the chlorination process, when chlorine is used for disinfection, at least daily average values for the following:
 - 1) Chlorine residual of treated wastewater as it enters the contact basin (mg/L);
 - 2) Chlorine dosage (kg/day); and
 - 3) Dechlorination chemical dosage (kg/day).

5. Treatment Process Bypasses

A chronological log of all treatment process bypasses, including wet weather blending, shall include the following:

- a. Identification of the treatment process bypassed;
- b. Dates and times of bypass beginning and end;
- c. Total bypass duration;
- d. Estimated total bypass volume; and
- e. Description of, or reference to other reports describing, the bypass event, the cause, the corrective actions taken (except for wet weather blending that is in compliance with permit conditions), and any additional monitoring conducted.

6. Treatment Facility Overflows

This section applies to records for overflows at the treatment facility. This includes the headworks and all units and appurtenances downstream. The Discharger shall retain a chronological log of overflows at the treatment facility and records supporting the information provided in section V.E.2.

C. Claims of Confidentiality – Not Supplemented

VI.V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information – Not Supplemented

B. Signatory and Certification Requirements – Not Supplemented

C. Monitoring Reports – This section supplements V.C of Standard Provisions (Attachment D)

1. Self Monitoring Reports

For each reporting period established in the MRP, the Discharger shall submit an SMR to the Regional Water Board in accordance with the requirements listed in this document and at the frequency the MRP specifies. The purpose of the SMR is to document treatment performance, effluent quality, and compliance with the waste discharge requirements of this Order.

a. Transmittal letter

Each SMR shall be submitted with a transmittal letter. This letter shall include the following:

- 1) Identification of all violations of effluent limits or other waste discharge requirements found during the reporting period;
- 2) Details regarding violations: parameters, magnitude, test results, frequency, and dates;
- 3) Causes of violations;
- 4) Discussion of corrective actions taken or planned to resolve violations and prevent recurrences, and dates or time schedule of action implementation (if previous reports have been submitted that address corrective actions, reference to the earlier reports is satisfactory);
- 5) Data invalidation (Data should not be submitted in an SMR if it does not meet quality assurance/quality control standards. However, if the Discharger wishes to invalidate any measurement after it was submitted in an SMR, a letter shall identify the measurement suspected to be invalid and state the Discharger's intent to submit, within 60 days, a formal request to invalidate the measurement. This request shall include the original measurement in question, the reason for invalidating the measurement, all relevant documentation that supports invalidation [e.g., laboratory sheet, log entry, test results, etc.], and discussion of the corrective actions taken or planned [with a time schedule for completion] to prevent recurrence of the sampling or measurement problem.);
- 6) If the Discharger blends, the letter shall describe the duration of blending events and certify whether blended effluent was in compliance with the conditions for blending; and
- 7) Signature (The transmittal letter shall be signed according to section V.B of this Order, Attachment D – Standard Provisions.).

b. Compliance evaluation summary

Each report shall include a compliance evaluation summary. This summary shall include each parameter for which the permit specifies effluent limits, the number of samples taken during the monitoring period, and the number of samples that exceed applicable effluent limits.

c. Results of analyses and observations

- 1) Tabulations of all required analyses and observations, including parameter, date, time, sample station, type of sample, test result, method detection limit, method minimum level, and method reporting level, if applicable, signed by the laboratory director or other responsible official.
- 2) When determining compliance with an average monthly effluent limitation and more than one sample result is available in a month, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of detected but not quantified (DNQ) or nondetect (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:
 - i. The data set shall be ranked from low to high, reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
 - ii. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

If a sample result, or the arithmetic mean or median of multiple sample results, is below the reporting limit, and there is evidence that the priority pollutant is present in the effluent above an effluent limitation and the Discharger conducts a Pollutant Minimization Program, the Discharger shall not be deemed out of compliance.

- 3) Dioxin-TEQ Reporting: The Discharger shall report for each dioxin and furan congener the analytical results of effluent monitoring, including the quantifiable limit (reporting level), the method detection limit, and the measured concentration. The Discharger shall report all measured values of individual congeners, including data qualifiers. When calculating dioxin-TEQ, the Discharger shall set congener concentrations below the minimum levels (ML) to zero. The Discharger shall calculate and report dioxin-TEQs using the following formula, where the MLs, toxicity equivalency factors (TEFs), and bioaccumulation equivalency factors (BEFs) are as provided in Table A:

$$\text{Dioxin-TEQ} = \sum (C_x \times \text{TEF}_x \times \text{BEF}_x)$$

where: C_x = measured or estimated concentration of congener x
 TEF_x = toxicity equivalency factor for congener x
 BEF_x = bioaccumulation equivalency factor for congener x

Table A

Minimum Levels, Toxicity Equivalency Factors,
 and Bioaccumulation Equivalency Factors

Dioxin or Furan Congener	Minimum Level (pg/L)	1998 Toxicity Equivalency Factor (TEF)	Bioaccumulation Equivalency Factor (BEF)
2,3,7,8-TCDD	10	1.0	1.0
1,2,3,7,8-PeCDD	50	1.0	0.9
1,2,3,4,7,8-HxCDD	50	0.1	0.3
1,2,3,6,7,8-HxCDD	50	0.1	0.1
1,2,3,7,8,9-HxCDD	50	0.1	0.1
1,2,3,4,6,7,8-HpCDD	50	0.01	0.05
OCDD	100	0.0001	0.01
2,3,7,8-TCDF	10	0.1	0.8
1,2,3,7,8-PeCDF	50	0.05	0.2
2,3,4,7,8-PeCDF	50	0.5	1.6
1,2,3,4,7,8-HxCDF	50	0.1	0.08
1,2,3,6,7,8-HxCDF	50	0.1	0.2
1,2,3,7,8,9-HxCDF	50	0.1	0.6
2,3,4,6,7,8-HxCDF	50	0.1	0.7
1,2,3,4,6,7,8-HpCDF	50	0.01	0.01
1,2,3,4,7,8,9-HpCDF	50	0.01	0.4
OCDF	100	0.0001	0.02

d. Data reporting for results not yet available

The Discharger shall make all reasonable efforts to obtain analytical data for required parameter sampling in a timely manner. Certain analyses require additional time to complete analytical processes and report results. For cases where required monitoring parameters require additional time to complete analytical processes and reports, and results are not available in time to be included in the SMR for the subject monitoring period, the Discharger shall describe such circumstances in the SMR and include the data for these parameters and relevant discussions of any observed exceedances in the next SMR due after the results are available.

e. Flow data

The Discharger shall provide flow data tabulation pursuant to section IV.B.2.

f. Annual self monitoring report requirements

By the date specified in the MRP, the Discharger shall submit an annual report to the Regional Water Board covering the previous calendar year. The report shall contain the following:

- 1) Annual compliance summary table of treatment plant performance, including documentation of any blending events;
- 2) Comprehensive discussion of treatment plant performance and compliance with the permit (This discussion shall include any corrective actions taken or planned, such as changes to facility equipment or operation practices that may be needed to achieve compliance, and any other actions taken or planned that are intended to improve performance and reliability of the Discharger’s wastewater collection, treatment, or disposal practices.);
- 3) Both tabular and graphical summaries of the monitoring data for the previous year if parameters are monitored at a frequency of monthly or greater;
- 4) List of approved analyses, including the following:
 - (i) List of analyses for which the Discharger is certified;
 - (ii) List of analyses performed for the Discharger by a separate certified laboratory (copies of reports signed by the laboratory director of that laboratory shall not be submitted but be retained onsite); and
 - (iii) List of “waived” analyses, as approved;
- 5) Plan view drawing or map showing the Discharger’s facility, flow routing, and sampling and observation station locations;
- 6) Results of annual facility inspection to verify that all elements of the SWPP Plan are accurate and up to date (only required if the Discharger does not route all stormwater to the headworks of its wastewater treatment plant); and
- 7) Results of facility report reviews (The Discharger shall regularly review, revise, and update, as necessary, the O&M Manual, the Contingency Plan, the Spill Prevention Plan, and Wastewater Facilities Status Report so that these documents remain useful and relevant to current practices. At a minimum, reviews shall be conducted annually. The Discharger shall include, in each Annual Report, a description or summary of review and evaluation procedures, recommended or planned actions, and an estimated time schedule for implementing these actions. The Discharger shall complete changes to these documents to ensure they are up-to-date.).

g. Report submittal

The Discharger shall submit SMRs to:

California Regional Water Quality Control Board
San Francisco Bay Region
1515 Clay Street, Suite 1400
Oakland, CA 94612
Attn: NPDES Wastewater Division

h. Reporting data in electronic format

The Discharger has the option to submit all monitoring results in an electronic reporting format approved by the Executive Officer. If the Discharger chooses to submit SMRs electronically, the following shall apply:

- 1) *Reporting Method*: The Discharger shall submit SMRs electronically via a process approved by the Executive Officer (see, for example, the letter dated December 17, 1999, “Official Implementation of Electronic Reporting System [ERS]” and the progress report letter dated December 17, 2000).
- 2) *Monthly or Quarterly Reporting Requirements*: For each reporting period (monthly or quarterly as specified in the MRP), the Discharger shall submit an electronic SMR to the Regional Water Board in accordance with the provisions of section V.C.1.a-e, except for requirements under section V.C.1.c(1) where ERS does not have fields for dischargers to input certain information (e.g., sample time). However, until USEPA approves the electronic signature or other signature technologies, Dischargers that use ERS shall submit a hard copy of the original transmittal letter, an ERS printout of the data sheet, and a violation report (a receipt of the electronic transmittal shall be retained by the Discharger). This electronic SMR submittal suffices for the signed tabulations specified under section V.C.1.c(1).
- 3) *Annual Reporting Requirements*: Dischargers who have submitted data using the ERS for at least one calendar year are exempt from submitting the portion of the annual report required under section V.C.1.f(1) and (3).

D. Compliance Schedules – Not supplemented

E. Twenty-Four Hour Reporting – This section supplements V.E of Standard Provision (Attachment D)

1. Spill of Oil or Other Hazardous Material Reports

- a. Within 24 hours of becoming aware of a spill of oil or other hazardous material that is not contained onsite and completely cleaned up, the Discharger shall report by telephone to the Regional Water Board at (510) 622-2369.
- b. The Discharger shall also report such spills to the State Office of Emergency Services [telephone (800) 852-7550] only when the spills are in accordance with applicable reporting quantities for hazardous materials.
- c. The Discharger shall submit a written report to the Regional Water Board within five working days following telephone notification unless directed otherwise by Regional Water Board staff. A report submitted electronically is acceptable. The written report shall include the following:
 - 1) Date and time of spill, and duration if known;

- 2) Location of spill (street address or description of location);
- 3) Nature of material spilled;
- 4) Quantity of material involved;
- 5) Receiving water body affected, if any;
- 6) Cause of spill;
- 7) Estimated size of affected area;
- 8) Observed impacts to receiving waters (e.g., oil sheen, fish kill, water discoloration);
- 9) Corrective actions taken to contain, minimize, or clean up the spill;
- 10) Future corrective actions planned to be taken to prevent recurrence, and schedule of implementation; and
- 11) Persons or agencies notified.

2. Unauthorized Discharges from Municipal Wastewater Treatment Plants¹

The following requirements apply to municipal wastewater treatment plants that experience an unauthorized discharge at their treatment facilities and are consistent with and supercede requirements imposed on the Discharger by the Executive Officer by letter of May 1, 2008, issued pursuant to California Water Code section 13383.

a. Two (2)-Hour Notification

For any unauthorized discharges that result in a discharge to a drainage channel or a surface water, the Discharger shall, as soon as possible, but not later than two (2) hours after becoming aware of the discharge, notify the State Office of Emergency Services (telephone 800-852-7550), the local health officers or directors of environmental health with jurisdiction over the affected water bodies, and the Regional Water Board. The notification to the Regional Water Board shall be via the Regional Water Board's online reporting system at www.wbers.net, and shall include the following:

- 1) Incident description and cause;
- 2) Location of threatened or involved waterway(s) or storm drains;
- 3) Date and time the unauthorized discharge started;

¹ California Code of Regulations, Title 23, section 2250(b), defines an unauthorized discharge to be a discharge, not regulated by waste discharge requirements, of treated, partially treated, or untreated wastewater resulting from the intentional or unintentional diversion of wastewater from a collection, treatment or disposal system.

- 4) Estimated quantity and duration of the unauthorized discharge (to the extent known), and the estimated amount recovered;
- 5) Level of treatment prior to discharge (e.g., raw wastewater, primary treated, undisinfected secondary treated, and so on); and
- 6) Identity of the person reporting the unauthorized discharge.

b. 24-hour Certification

Within 24 hours, the Discharger shall certify to the Regional Water Board, at www.wbers.net, that the State Office of Emergency Services and the local health officers or directors of environmental health with jurisdiction over the affected water bodies have been notified of the unauthorized discharge.

c. 5-Day Written Report

Within five business days, the Discharger shall submit a written report, via the Regional Water Board's online reporting system at www.wbers.net, that includes, in addition to the information required above, the following:

- 1) Methods used to delineate the geographical extent of the unauthorized discharge within receiving waters;
- 2) Efforts implemented to minimize public exposure to the unauthorized discharge;
- 3) Visual observations of the impacts (if any) noted in the receiving waters (e.g., fish kill, discoloration of water) and the extent of sampling if conducted;
- 4) Corrective measures taken to minimize the impact of the unauthorized discharge;
- 5) Measures to be taken to minimize the chances of a similar unauthorized discharge occurring in the future;
- 6) Summary of Spill Prevention Plan or O&M Manual modifications to be made, if necessary, to minimize the chances of future unauthorized discharges; and
- 7) Quantity and duration of the unauthorized discharge, and the amount recovered.

d. Communication Protocol

To clarify the multiple levels of notification, certification, and reporting, the current communication requirements for unauthorized discharges from municipal wastewater treatment plants are summarized in Table B that follows.

Table B

Summary of Communication Requirements for Unauthorized Discharges¹ from Municipal Wastewater Treatment Plants

Discharger is required to:	Agency Receiving Information	Time frame	Method for Contact
1. Notify	California Emergency Management Agency (Cal EMA)	As soon as possible, but not later than 2 hours after becoming aware of the unauthorized discharge.	Telephone – (800) 852-7550 (obtain a control number from Cal EMA)
	Local health department	As soon as possible, but not later than 2 hours after becoming aware of the unauthorized discharge.	Depends on local health department
	Regional Water Board	As soon as possible, but not later than 2 hours after becoming aware of the unauthorized discharge.	Electronic ² www.wbers.net
2. Certify	Regional Water Board	As soon as possible, but not later than 24 hours after becoming aware of the unauthorized discharge.	Electronic ³ www.wbers.net
3. Report	Regional Water Board	Within 5 business days of becoming aware of the unauthorized discharge.	Electronic ⁴ www.wbers.net

¹ California Code of Regulations, Title 23, section 2250(b), defines an unauthorized discharge to be a discharge, not regulated by waste discharge requirements, of treated, partially treated, or untreated wastewater resulting from the intentional or unintentional diversion of wastewater from a collection, treatment or disposal system.

² In the event that the Discharger is unable to provide online notification within 2 hours of becoming aware of an unauthorized discharge, it shall phone the Regional Water Board’s spill hotline at (510) 622-2369 and convey the same information contained in the notification form. In addition, within 3 business days of becoming aware of the unauthorized discharge, the Discharger shall enter the notification information into the Regional Water Board’s online system in electronic format.

³ In most instances, the 2-hour notification will also satisfy 24-hour certification requirements. This is because the notification form includes fields for documenting that OES and the local health department have been contacted. In other words, if the Discharger is able to complete all the fields in the notification form within 2 hours, certification requirements are also satisfied. In the event that the Discharger is unable to provide online certification within 24 hours of becoming aware of an unauthorized discharge, it shall phone the Regional Water Board’s spill hotline at (510) 622-2369 and convey the same information contained in the certification form. In addition, within 3 business days of becoming aware of the unauthorized discharge, the Discharger shall enter the certification information into the Regional Water Board’s online system in electronic format.

⁴ If the Discharger cannot satisfy the 5-day reporting requirements via the Regional Water Board’s online reporting system, it shall submit a written report (preferably electronically in pdf) to the appropriate Regional Water Board case manager. In cases where the Discharger cannot satisfy the 5-day reporting requirements via the online reporting system, it must still complete the Regional Water Board’s online reporting requirements within 15 calendar days of becoming aware of the unauthorized discharge.

F. Planned Changes – Not supplemented

G. Anticipated Noncompliance – Not supplemented

H. Other Noncompliance – Not supplemented

I. Other Information – Not supplemented

VI. STANDARD PROVISIONS – ENFORCEMENT – Not Supplemented

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS – Not Supplemented

VIII. DEFINITIONS – This section is an addition to Standard Provisions (Attachment D)

More definitions can be found in Attachment A of this NPDES Permit.

1. Arithmetic Calculations

- a. Geometric mean is the antilog of the log mean or the back-transformed mean of the logarithmically transformed variables, which is equivalent to the multiplication of the antilogarithms. The geometric mean can be calculated with either of the following equations:

$$\text{Geometric Mean} = \text{Anti log} \left(\frac{1}{N} \sum_{i=1}^N \text{Log}(C_i) \right)$$

or

$$\text{Geometric Mean} = (C_1 * C_2 * \dots * C_N)^{1/N}$$

Where “N” is the number of data points for the period analyzed and “C” is the concentration for each of the “N” data points.

- b. Mass emission rate is obtained from the following calculation for any calendar day:

$$\text{Mass emission rate (lb/day)} = \frac{8.345}{N} \sum_{i=1}^N Q_i C_i$$

$$\text{Mass emission rate (kg/day)} = \frac{3.785}{N} \sum_{i=1}^N Q_i C_i$$

In which “N” is the number of samples analyzed in any calendar day and “Q_i” and “C_i” are the flow rate (MGD) and the constituent concentration (mg/L) associated with each of the “N” grab samples that may be taken in any calendar day. If a composite sample is taken, “C_i” is the concentration measured in the composite sample and “Q_i” is the average flow rate occurring during the period over which the samples are composited. The daily concentration

of a constituent measured over any calendar day shall be determined from the flow-weighted average of the same constituent in the combined waste streams as follows:

$$C_d = \text{Average daily concentration} = \frac{1}{Q_t} \sum_{i=1}^N Q_i C_i$$

In which “N” is the number of component waste streams and “Q” and “C” are the flow rate (MGD) and the constituent concentration (mg/L) associated with each of the “N” waste streams. “Q_t” is the total flow rate of the combined waste streams.

- c. Maximum allowable mass emission rate, whether for a 24-hour, weekly 7-day, monthly 30-day, or 6-month period, is a limitation expressed as a daily rate determined with the formulas in the paragraph above, using the effluent concentration limit specified in the permit for the period and the specified allowable flow.
- d. POTW removal efficiency is the ratio of pollutants removed by the treatment facilities to pollutants entering the treatment facilities (expressed as a percentage). The Discharger shall determine removal efficiencies using monthly averages (by calendar month unless otherwise specified) of pollutant concentration of influent and effluent samples collected at about the same time and using the following equation (or its equivalent):

$$\text{Removal Efficiency (\%)} = 100 \times [1 - (\text{Effluent Concentration} / \text{Influent Concentration})]$$

2. Biosolids means the solids, semi-liquid suspensions of solids, residues, screenings, grit, scum, and precipitates separated from or created in wastewater by the unit processes of a treatment system. It also includes, but is not limited to, all supernatant, filtrate, centrate, decantate, and thickener overflow and underflow in the solids handling parts of the wastewater treatment system.
3. Blending is the practice of recombining wastewater that has been biologically treated with wastewater that has bypassed around biological treatment units.
4. Bottom sediment sample is (1) a separate grab sample taken at each sampling station for the determination of selected physical-chemical parameters, or (2) four grab samples collected from different locations in the immediate vicinity of a sampling station while the boat is anchored and analyzed separately for macroinvertebrates.
5. Composite sample is a sample composed of individual grab samples collected manually or by an automatic sampling device on the basis of time or flow as specified in the MRP. For flow-based composites, the proportion of each grab sample included in the composite sample shall be within plus or minus five percent (+/-5%) of the representative flow rate of the waste stream being measured at the time of grab sample collection. Alternatively, equal volume grab samples may be individually analyzed with the flow-weighted average calculated by averaging flow-weighted ratios of each grab sample analytical result. Grab samples comprising time-based composite samples shall be collected at intervals not greater than those specified in the MRP. The quantity of each grab sample comprising a time-based composite sample shall be a set of flow proportional volumes as specified in the MRP. If a particular time-based or flow-based composite sampling protocol is not specified in the MRP, the Discharger shall determine and implement the most representative sampling protocol for the given parameter subject to Executive Officer approval.

6. Depth-integrated sample is defined as a water or waste sample collected by allowing a sampling device to fill during a vertical traverse in the waste or receiving water body being sampled. The Discharger shall collect depth-integrated samples in such a manner that the collected sample will be representative of the waste or water body at that sampling point.
7. Flow sample is an accurate measurement of the average daily flow volume using a properly calibrated and maintained flow measuring device.
8. Grab sample is an individual sample collected in a short period of time not exceeding 15 minutes. Grab samples represent only the condition that exists at the time the wastewater is collected.
9. Initial dilution is the process that results in the rapid and irreversible turbulent mixing of wastewater with receiving water around the point of discharge.
10. Overflow is the intentional or unintentional spilling or forcing out of untreated or partially treated wastes from a transport system (e.g., through manholes, at pump stations, and at collection points) upstream from the treatment plant headworks or from any part of a treatment plant facility.
11. Priority pollutants are those constituents referred to in 40 CFR Part 122 as promulgated in the Federal Register, Vol. 65, No. 97, Thursday, May 18, 2000, also known as the California Toxics Rule, the presence or discharge of which could reasonably be expected to interfere with maintaining designated uses.
12. Stormwater means stormwater runoff, snow melt runoff, and surface runoff and drainage. It excludes infiltration and runoff from agricultural land.
13. Toxic pollutant means any pollutant listed as toxic under federal Clean Water Act section 307(a)(1) or under 40 CFR 401.15.
14. Untreated waste is raw wastewater.
15. Waste, waste discharge, discharge of waste, and discharge are used interchangeably in the permit. The requirements of the permit apply to the entire volume of water, and the material therein, that is disposed of to surface and ground waters of the State of California.

Table C

List of Monitoring Parameters and Analytical Methods

CTR No.	Pollutant/Parameter	Analytical Method ¹	Minimum Levels ² (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
1.	Antimony	204.2					10	5	50	0.5	5	0.5		1000
2.	Arsenic	206.3				20		2	10	2	2	1		1000
3.	Beryllium						20	0.5	2	0.5	1			1000
4.	Cadmium	200 or 213					10	0.5	10	0.25	0.5			1000
5a.	Chromium (III)	SM 3500												
5b.	Chromium (VI)	SM 3500				10	5							1000
	Chromium (total) ³	SM 3500					50	2	10	0.5	1			1000
6.	Copper	200.9					25	5	10	0.5	2			1000
7.	Lead	200.9					20	5	5	0.5	2			10,000
8.	Mercury	1631 (note) ⁴												
9.	Nickel	249.2					50	5	20	1	5			1000
10.	Selenium	200.8 or SM 3114B or C						5	10	2	5	1		1000
11.	Silver	272.2					10	1	10	0.25	2			1000
12.	Thallium	279.2					10	2	10	1	5			1000
13.	Zinc	200 or 289					20		20	1	10			
14.	Cyanide	SM 4500 CN ⁻ C or I				5								
15.	Asbestos (only required for dischargers to MUN waters) ⁵	0100.2 ⁶												
16.	2,3,7,8-TCDD and 17 congeners (Dioxin)	1613												
17.	Acrolein	603	2.0	5										
18.	Acrylonitrile	603	2.0	2										
19.	Benzene	602	0.5	2										
33.	Ethylbenzene	602	0.5	2										
39.	Toluene	602	0.5	2										
20.	Bromoform	601	0.5	2										
21.	Carbon Tetrachloride	601	0.5	2										
22.	Chlorobenzene	601	0.5	2										
23.	Chlorodibromomethane	601	0.5	2										
24.	Chloroethane	601	0.5	2										

¹ The suggested method is the USEPA Method unless otherwise specified (SM = Standard Methods). The Discharger may use another USEPA-approved or recognized method if that method has a level of quantification below the applicable water quality objective. Where no method is suggested, the Discharger has the discretion to use any standard method.

² Minimum levels are from the *State Implementation Policy*. They are the concentration of the lowest calibration standard for that technique based on a survey of contract laboratories. Laboratory techniques are defined as follows: GC = Gas Chromatography; GCMS = Gas Chromatography/Mass Spectrometry; LC = High Pressure Liquid Chromatography; Color = Colorimetric; FAA = Flame Atomic Absorption; GFAA = Graphite Furnace Atomic Absorption; ICP = Inductively Coupled Plasma; ICPMS = Inductively Coupled Plasma/Mass Spectrometry; SPGFAA = Stabilized Platform Graphite Furnace Atomic Absorption (i.e., USEPA 200.9); Hydride = Gaseous Hydride Atomic Absorption; CVAA = Cold Vapor Atomic Absorption; DCP = Direct Current Plasma.

³ Analysis for total chromium may be substituted for analysis of chromium (III) and chromium (VI) if the concentration measured is below the lowest hexavalent chromium criterion (11 µg/L).

⁴ The Discharger shall use ultra-clean sampling (USEPA Method 1669) and ultra-clean analytical methods (USEPA Method 1631) for mercury monitoring. The minimum level for mercury is 2 ng/l (or 0.002 µg/L).

⁵ MUN = Municipal and Domestic Supply. This designation, if applicable, is in the Findings of the permit.

⁶ Determination of Asbestos Structures over 10 [micrometers] in Length in Drinking Water Using MCE Filters, USEPA 600/R-94-134, June 1994.

CTR No.	Pollutant/Parameter	Analytical Method ¹	Minimum Levels ² (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
25.	2-Chloroethylvinyl Ether	601	1	1										
26.	Chloroform	601	0.5	2										
75.	1,2-Dichlorobenzene	601	0.5	2										
76.	1,3-Dichlorobenzene	601	0.5	2										
77.	1,4-Dichlorobenzene	601	0.5	2										
27.	Dichlorobromomethane	601	0.5	2										
28.	1,1-Dichloroethane	601	0.5	1										
29.	1,2-Dichloroethane	601	0.5	2										
30.	1,1-Dichloroethylene or 1,1-Dichloroethene	601	0.5	2										
31.	1,2-Dichloropropane	601	0.5	1										
32.	1,3-Dichloropropylene or 1,3-Dichloropropene	601	0.5	2										
34.	Methyl Bromide or Bromomethane	601	1.0	2										
35.	Methyl Chloride or Chloromethane	601	0.5	2										
36.	Methylene Chloride or Dichloromethane	601	0.5	2										
37.	1,1,2,2-Tetrachloroethane	601	0.5	1										
38.	Tetrachloroethylene	601	0.5	2										
40.	1,2-Trans-Dichloroethylene	601	0.5	1										
41.	1,1,1-Trichloroethane	601	0.5	2										
42.	1,1,2-Trichloroethane	601	0.5	2										
43.	Trichloroethene	601	0.5	2										
44.	Vinyl Chloride	601	0.5	2										
45.	2-Chlorophenol	604	2	5										
46.	2,4-Dichlorophenol	604	1	5										
47.	2,4-Dimethylphenol	604	1	2										
48.	2-Methyl-4,6-Dinitrophenol or Dinitro-2-methylphenol	604	10	5										
49.	2,4-Dinitrophenol	604	5	5										
50.	2-Nitrophenol	604		10										
51.	4-Nitrophenol	604	5	10										
52.	3-Methyl-4-Chlorophenol	604	5	1										
53.	Pentachlorophenol	604	1	5										
54.	Phenol	604	1	1		50								
55.	2,4,6-Trichlorophenol	604	10	10										
56.	Acenaphthene	610 HPLC	1	1	0.5									
57.	Acenaphthylene	610 HPLC		10	0.2									
58.	Anthracene	610 HPLC		10	2									
60.	Benzo(a)Anthracene or 1,2 Benzanthracene	610 HPLC	10	5										
61.	Benzo(a)Pyrene	610 HPLC		10	2									
62.	Benzo(b)Fluoranthene or 3,4 Benzofluoranthene	610 HPLC		10	10									
63.	Benzo(ghi)Perylene	610 HPLC		5	0.1									
64.	Benzo(k)Fluoranthene	610 HPLC		10	2									
74.	Dibenzo(a,h)Anthracene	610 HPLC		10	0.1									
86.	Fluoranthene	610 HPLC	10	1	0.05									
87.	Fluorene	610 HPLC		10	0.1									
92.	Indeno(1,2,3-cd) Pyrene	610 HPLC		10	0.05									
100.	Pyrene	610 HPLC		10	0.05									

CTR No.	Pollutant/Parameter	Analytical Method ¹	Minimum Levels ² (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
68.	Bis(2-Ethylhexyl)Phthalate	606 or 625	10	5										
70.	Butylbenzyl Phthalate	606 or 625	10	10										
79.	Diethyl Phthalate	606 or 625	10	2										
80.	Dimethyl Phthalate	606 or 625	10	2										
81.	Di-n-Butyl Phthalate	606 or 625		10										
84.	Di-n-Octyl Phthalate	606 or 625		10										
59.	Benzidine	625		5										
65.	Bis(2-Chloroethoxy)Methane	625		5										
66.	Bis(2-Chloroethyl)Ether	625	10	1										
67.	Bis(2-Chloroisopropyl)Ether	625	10	2										
69.	4-Bromophenyl Phenyl Ether	625	10	5										
71.	2-Chloronaphthalene	625		10										
72.	4-Chlorophenyl Phenyl Ether	625		5										
73.	Chrysene	625		10	5									
78.	3,3'-Dichlorobenzidine	625		5										
82.	2,4-Dinitrotoluene	625	10	5										
83.	2,6-Dinitrotoluene	625		5										
85.	1,2-Diphenylhydrazine (note) ⁷	625		1										
88.	Hexachlorobenzene	625	5	1										
89.	Hexachlorobutadiene	625	5	1										
90.	Hexachlorocyclopentadiene	625	5	5										
91.	Hexachloroethane	625	5	1										
93.	Isophorone	625	10	1										
94.	Naphthalene	625	10	1	0.2									
95.	Nitrobenzene	625	10	1										
96.	N-Nitrosodimethylamine	625	10	5										
97.	N-Nitrosodi-n-Propylamine	625	10	5										
98.	N-Nitrosodiphenylamine	625	10	1										
99.	Phenanthrene	625		5	0.05									
101.	1,2,4-Trichlorobenzene	625	1	5										
102.	Aldrin	608	0.005											
103.	α-BHC	608	0.01											
104.	β-BHC	608	0.005											
105.	γ-BHC (Lindane)	608	0.02											
106.	δ-BHC	608	0.005											
107.	Chlordane	608	0.1											
108.	4,4'-DDT	608	0.01											
109.	4,4'-DDE	608	0.05											
110.	4,4'-DDD	608	0.05											
111.	Dieldrin	608	0.01											
112.	Endosulfan (alpha)	608	0.02											
113.	Endosulfan (beta)	608	0.01											
114.	Endosulfan Sulfate	608	0.05											
115.	Endrin	608	0.01											
116.	Endrin Aldehyde	608	0.01											
117.	Heptachlor	608	0.01											

⁷ Measurement for 1,2-Diphenylhydrazine may use azobenzene as a screen: if azobenzene is measured at >1 µg/L, then the Discharger shall analyze for 1,2-Diphenylhydrazine.

CTR No.	Pollutant/Parameter	Analytical Method ¹	Minimum Levels ² (µg/l)											
			GC	GCMS	LC	Color	FAA	GFAA	ICP	ICP MS	SPGFAA	HYD RIDE	CVAA	DCP
118.	Heptachlor Epoxide	608	0.01											
119-125	PCBs: Aroclors 1016, 1221, 1232, 1242, 1248, 1254, 1260	608	0.5											
126.	Toxaphene	608	0.5											