

STATE OF CALIFORNIA
REGIONAL WATER QUALITY CONTROL BOARD
SAN FRANCISCO BAY REGION

STAFF SUMMARY REPORT: William Burrell
MEETING DATE: December 14, 2022

ITEM: 5A

North San Mateo County Sanitation District; North San Mateo County Sanitation District Wastewater Treatment Plant and Collection System; Daly City; San Mateo County –
Reissuance of NPDES Permit

DISCUSSION:

This Tentative Order (Appendix A) would reissue an NPDES permit for the North San Mateo County Sanitation District Wastewater Treatment Plant and its wastewater collection system. The District collects, treats, and disinfects about 5.3 million gallons per day of domestic wastewater from the City of Daly City, portions of unincorporated San Mateo County, the Town of Colma, the San Francisco County Jail, and the Westborough Water District within the City of South San Francisco. The service area population is about 132,000. Following dechlorination, the secondary-treated wastewater is discharged through an outfall extending 2,500 feet into the Pacific Ocean.

This Tentative Order would continue to allow the discharge described above. It would also update effluent limits for enterococcus and include new receiving water limits for enterococcus and fecal coliform that conform to the 2019 *Bacteria Provisions and a Water Quality Standards Variance Policy* amendment to the California Ocean Plan.

We received no comments on the Tentative Order and expect this item to remain uncontested.

APPENDIX:

A. Tentative Order

Appendix A
Tentative Order