

Appendix 6
Underground Storage Tank
Spill Containment Testing Report Form

TESTING TYPE ☐ Installation ☐ Repair ☐ 12 Month

1. FACILITY INFORMATION		
CERS ID	Test Date	
Facility Name		
Facility Address	City	ZIP Code

2. SERVICE TECHNICIAN INFORMATION	
Company Performing Testing	Phone
Mailing Address	
Service Technician Performing Testing	
Contractor License Number	
ICC Certification	ICC Expiration Date

3. TRAINING AND CERTIFICATIONS	
Manufacturer and Test Equipment Training Certifications	Training Expiration Date

4. TEST PROCEDURE INFORMATION	
Test Procedures Used	Components Tested

5. CERTIFICATION BY SERVICE TECHNICIAN CONDUCTING TEST		
<i>I hereby certify that each spill containment was tested in accordance with California Code of Regulations, title 23, division 3, chapter 16, section 2664; that required supporting documentation is attached; and all information contained herein is accurate. I understand that test procedures must be made available upon request by the governing authority.</i>		
Service Technician Signature	Date	Total # of Pages

CERS = California Environmental Reporting System, ICC = International Code Council,
ID = Identification

Underground Storage Tank Spill Containment Testing Report Form

6. SPILL CONTAINMENT DETAILS

Test Method Developed by ☐ Manufacturer ☐ Industry Standard ☐ Professional Engineer

Test Type ☐ Pressure ☐ Vacuum ☐ Hydrostatic

☐ Check this box if Appendix 6.1 continuation page is attached.

Tank ID				
Spill Containment Manufacturer:				
Method of Cathodic Protection	☐ Nonmetallic ☐ Other	☐ Nonmetallic ☐ Other	☐ Nonmetallic ☐ Other	☐ Nonmetallic ☐ Other
Is the spill containment minimum capacity five gallons excluding riser volume?	☐ Yes ☐ No*	☐ Yes ☐ No*	☐ Yes ☐ No*	☐ Yes ☐ No*
Method to keep spill containment empty	☐ Drain ☐ Pump ☐ Other	☐ Drain ☐ Pump ☐ Other	☐ Drain ☐ Pump ☐ Other	☐ Drain ☐ Pump ☐ Other
Spill Containment Test Results	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail

Tank ID				
Spill Containment Manufacturer:				
Method of Cathodic Protection	☐ Nonmetallic ☐ Other	☐ Nonmetallic ☐ Other	☐ Nonmetallic ☐ Other	☐ Nonmetallic ☐ Other
Is the spill containment minimum capacity five gallons excluding riser volume?	☐ Yes ☐ No*	☐ Yes ☐ No*	☐ Yes ☐ No*	☐ Yes ☐ No*
Method to keep spill containment empty	☐ Drain ☐ Pump ☐ Other	☐ Drain ☐ Pump ☐ Other	☐ Drain ☐ Pump ☐ Other	☐ Drain ☐ Pump ☐ Other
Spill Containment Test Results	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail	☐ Pass ☐ Fail

7. COMMENTS

* ☐ Check this box if any spill containment has less than 5 gallons capacity and requires replacement.

*Describe all answers marked "Other," "No," or "Fail" and each proposed remedy in **Section 7**.*