

All Water Year Types			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	8 cfs	88 cfs	88 cfs
December	8 cfs	88 cfs	88 cfs
January	8 cfs	88 cfs	88 cfs
February	8 cfs	88 cfs	88 cfs
March	8 cfs	100 cfs	100 cfs

*Federal Energy Regulatory Commission has issued a new license to the Pacific Gas and Electric Company for the Hat Creek 1 & 2 Power Project, which asserts minimum instream flow requirement on Hat Creek below the Cassel Diversion Dam to the No. 1 Powerhouse as summarized in the above table. A compliance gage has not been identified for this stream section. Please contact the State Water Resources Control Board for further guidance.

Web Link to Water Quality Certification:

[Water Quality Certification for the Hat Creek 1 & 2 Power Project](#)