

All Water Year Types			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	2 cfs	10 cfs	<b>10 cfs</b>
December	2 cfs	10 cfs	<b>10 cfs</b>
January	2 cfs	13 cfs	<b>13 cfs</b>
February	2 cfs	11 cfs	<b>11 cfs</b>
March	2 cfs	10 cfs	<b>10 cfs</b>

\*Federal Energy Regulatory Commission has issued a new license to the Pacific Gas and Electric Company for the DeSabla-Centerville Hydroelectric Project, which asserts minimum instream flow requirement on Philbrook Creek below Philbrook Dam to its confluence with the West Branch Feather River as summarized in the above table. A compliance gage has not been identified for this stream section. Please contact the State Water Resources Control Board for further guidance.

**Web Link to Water Quality Certification:**

[Water Quality Certification for the DeSabla-Centerville Hydroelectric Project](#)