

Dry Water Year Type			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	7 cfs	65 cfs	65 cfs
December	7 cfs	72 cfs	72 cfs
January	7 cfs	94 cfs	94 cfs
February	7 cfs	89 cfs	89 cfs
March	15 cfs	65 cfs	65 cfs

Normal Water Year Type			
Month	Existing Flow Requirement*	Cannabis Policy Flow Requirement	Effective Flow Requirement
November	15 cfs	65 cfs	65 cfs
December	15 cfs	72 cfs	72 cfs
January	15 cfs	94 cfs	94 cfs
February	15 cfs	89 cfs	89 cfs
March	15 cfs	65 cfs	65 cfs

*Federal Energy Regulatory Commission has issued a new license to the Pacific Gas and Electric Company for the DeSabra-Centerville Hydroelectric Project, which asserts minimum instream flow requirement at CDEC Station ID: WFR; as summarized in the above table.

Web Link to Water Quality Certification:

[Water Quality Certification for the DeSabra-Centerville Hydroelectric Project](#)