

Issue Date: April 15, 2022

Franklin Fueling Systems

**Franklin Fueling Systems EVO200, EVO400, EVO600, EVO6000 with
FMP-HIS-U Hydrostatic Interstitial Float Sensor, and FMP-HIS-XL-U Hydrostatic Interstitial
Float Sensor**

INTERSTITIAL DETECTOR (LIQUID-PHASE)

Detector:

Output type: qualitative
Sampling frequency: continuous
Operating principle: float switch

Test Results:

FMP-HIS-U	<u>brine</u>
Detection time (min)	<1
Fall time (min)	<1
Threshold Level	
Low level (in)	1.0167
High level (in)	7.3218
FMP-HIS-XL-U	<u>brine</u>
Detection time (min)	<1
Fall time (min)	<1
Threshold Level	1.0678
Low level (in)	0.9895
High level (in)	10.8398

Applicability:

California Code of Regulations require a written statement of compatibility for systems containing products other than those used in this evaluation.

Comments:

Sensors can be removed, cleaned and reinstalled if an alarm is triggered or if the sensor is periodically tested.

3760 Marsh Road

Madison, WI 53718

Tel: (800) 225-9787

email: info@franklinfueling.com

URL: www.franklinfueling.com

Tel: (816) 443-2494

Date of Evaluation: 05/02/2017, 11/08/2018