

Issue Date: April 15, 2022

Franklin Fueling Systems

EVO 600 and EVO 6000 Console with TSP-DMS Discriminating Magnetostrictive Sensor

INTERSTITIAL DETECTOR (LIQUID-PHASE)

Detector:

Output type: Qualitative
Sampling frequency: Continuous
Operating Principle: Liquid specific floats

Test Results:

	<u>unleaded gasoline</u>	<u>diesel</u>	<u>water</u>
TSP-DMS			
Detection time (min)	<1	<1	<1
Fall time (min)	<1	<1	<1
Threshold Level (in)	1.55	1.87	1.98

Applicability:

California Code of Regulations require a written statement of compatibility for systems containing products other than those used in this evaluationn.

Comments:

Sensors are reusable.

Franklin Fueling Systems

Evaluator: Ken Wilcox Associates

3760 Marsh Road

Tel: (816) 443-2494

Madison, WI 53718

Date of Evaluation: 08/23/2013, 12/17/2018

Tel: (800) 225-9787

E-mail: info@franklinfueling.com

URL: www.franklinfueling.com

| [Home](#) | [Vendors: A - F](#) | [Vendors: G - M](#) | [Vendors: N - S](#) | [Vendors: T - Z](#) | [Method Index](#) |

Appearance on this list is not to be construed as an endorsement by any regulatory agency nor is it any guarantee of the performance of the method or equipment. Equipment should be installed and operated in accordance with all applicable laws and regulations.

For full details, please refer to our expanded "[DISCLAIMER](#)" page.