

PERMIT TERM 43B – Single Reservoir Built

Title: Outlet Pipe - Dam Built

When Used: For constructed onstream reservoirs which will impound more than 10 acre-feet regardless of the locality and for onstream reservoirs of any size, either constructed or unconstructed, in critical watersheds such as Stony Creek and Putah Creek where the entire supply is controlled in normal years. For dams under the jurisdiction of the Division of Safety of Dams, only the first sentence should be used.

Term:

Permittee shall install and maintain an outlet pipe of adequate capacity in the dam as near as practicable to the bottom of the natural stream channel, or provide other means satisfactory to the State Water Resources Control Board, in order that water entering the reservoir which is not authorized for appropriation under this permit can be released. Before storing water in the reservoir, permittee shall furnish evidence which substantiates that the outlet pipe, or alternative facility, has been installed in the dam. Evidence shall include photographs showing completed works or certification by a registered Civil or Agricultural Engineer.

(0050043B)